

C 05/24/78

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)
DISTRIBUTION FOR INCOMING MATERIAL 50-305

REC: KEPPLER J G
NRC

ORG: JAMES E W
WI PUB SVC

DOCDATE: 05/19/78
DATE RCVD: 05/22/78

DOCTYPE: LETTER NOTARIZED: NO
SUBJECT:

COPIES RECEIVED
LTR 1 ENCL 1

FORWARDING LICENSEE EVENT REPT (RO 50-305/78-014) ON 04/20/78 CONCERNING
SURVEILLANCE TESTING DURING FULL PWR OPERATION INDICATED THAT ONE SHIELD BLDG
VENT TRAIN WOULD NOT DRAW A MEASURABLE VACUUM IN THE ANNULUS, PLACING FACILITY
UNDER LOC TECH SPEC 3.6.B.1.

PLANT NAME: KEWAUNEE

REVIEWER INITIAL: XJM
DISTRIBUTOR INITIAL: *mu*

***** DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS *****

NOTES:

- 1. I & E - 3 CYS ALL MATERIAL
- 2. LAWRENCE(DEL) - 1 COPY ALL MATERIAL

INCIDENT REPORTS
(DISTRIBUTION CODE A002)

FOR ACTION: BR CHIEF SCHWENCER**W/4 ENCL

INTERNAL:

REG FILE**W/ENCL
 I & E**W/3 ENCL
 IPPOLITO**W/ENCL
 NOVAK/CHECK**W/ENCL
 KNIGHT**W/ENCL
 HANAUER**W/ENCL
 EISENHUT**W/ENCL
 SHAD**W/ENCL
 KREGER/J. COLLINS**W/ENCL
 K SEYFRIT/IE**W/ENCL

NRC PDR**W/ENCL
 MIPC**W/3 ENCL
 HOUSTON**W/ENCL
 EEB**W/ENCL
 BUTLER**W/ENCL
 TEDESCO**W/ENCL
 BAER**W/ENCL
 VOLLMER/BUNCH**W/ENCL
 ROSA**W/ENCL

EXTERNAL:

LPDR'S
 KEWAUNEE, WI**W/ENCL
 TIC**W/ENCL
 NSIC**W/ENCL
 ACRS CAT B**W/16 ENCL

COPIES NOT SUBMITTED PER
REGULATORY GUIDE 10.1

DISTRIBUTION: LTR 45 ENCL 45
SIZE: 1P+1P

CONTROL NBR: 781440021

20460

***** THE END *****

WISCONSIN PUBLIC SERVICE CORPORATION



P.O. Box 1200, Green Bay, Wisconsin 54305

May 19, 1978

Mr. J. G. Keppler, Regional Director
Office of Inspection & Enforcement
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Dear Mr. Keppler:

Docket 50-305
Operating License DPR-43
Reportable Occurrence LER 78-014/03L-0

In accordance with the requirements of Technical Specifications, Section 6.9, the attached Licensee Event Report for reportable occurrence LER 78-014/03L-0 is being submitted.

Very truly yours,

A handwritten signature in cursive script, appearing to read "E. W. James".

E. W. James
Senior Vice President
Power Supply & Engineering

sna

Attach.

cc - Dir, Office of Inspection & Enforcement
US NRC, Washington, D. C. 20555
Dir, Office of Mgt Info & Program Control
US NRC, Washington, D. C. 20555

781440021

A002
5/11

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01	WIKNP1	000-00000-000	41111	
7 8	9 14 15	25 26	30	57 58
LICENSEE CODE		LICENSE NUMBER	LICENSE TYPE	CAT 58

01	L	05000305	042078	051978
7 8	60	61 68	69 74 75	80
REPORT SOURCE		DOCKET NUMBER	EVENT DATE	REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | Surveillance testing during full power operation indicated that one Shield Building

03 | Vent (SBV) train would not draw a measurable vacuum in the annulus. This placed

04 | the facility under LCO TS 3.6.b.1. The other train of SBV was tested satisfactorily.

05 | Since the other SBV train was operable, there was no effect on plant operation or

06 | public safety. A similar event was reported by LER 77-035/03L-0 dated 1/5/78.

07 | _____

08 | _____

09	SH	E	G	INSTRU	S	Z		
7 8	9 10	11	12	13 18	19	20		
SYSTEM CODE		CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE		
17	78		014		03	L		0
LER/RO REPORT NUMBER	EVENT YEAR	SEQUENTIAL REPORT NO.	OCCURRENCE CODE	REPORT TYPE	REVISION NO.			
18	Z	Z	0000	N	Y	A	J073	
ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The recirculation fan exhaust check damper failed to open because of a faulted

11 | static pressure controller. The controller was replaced with a spare and the SBV

12 | train was returned to service. A transistor and capacitor were replaced in the

13 | removed controller. Similar component replacement has been completed for all SBV

14 | static pressure controllers. No further problems are anticipated.

15	E	100	NA	B	Surveillance Testing
7 8	9	10 12	13	44 45	46
FACILITY STATUS	% POWER	OTHER STATUS	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION	

16	Z	Z	NA	NA
7 8	9	10 11	44	45
ACTIVITY CONTENT	RELEASED OF RELEASE	AMOUNT OF ACTIVITY	LOCATION OF RELEASE	

17	000	Z	NA
7 8	9	11 12	13
PERSONNEL EXPOSURES NUMBER	TYPE	DESCRIPTION	

18	000	NA
7 8	9	11 12
PERSONNEL INJURIES NUMBER	DESCRIPTION	

19	Z	NA
7 8	9	11 12
LOSS OF OR DAMAGE TO FACILITY TYPE	DESCRIPTION	

20	N	NA
7 8	9	10
PUBLICITY ISSUED	DESCRIPTION	

WISCONSIN PUBLIC SERVICE CORPORATION



P.O. Box 1200, Green Bay, Wisconsin 54305

FILE

May 19, 1978

Mr. J. G. Keppler, Regional Director
Office of Inspection & Enforcement
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Dear Mr. Keppler:

Docket 50-305
Operating License DPR-43
Reportable Occurrence LER 78-014/03L-0

In accordance with the requirements of Technical Specifications, Section 6.9, the attached Licensee Event Report for reportable occurrence LER 78-014/03L-0 is being submitted.

Very truly yours,


E. W. James
Senior Vice President
Power Supply & Engineering

sna

Attach.

cc - Dir, Office of Inspection & Enforcement
US NRC, Washington, D. C. 20555
Dir, Office of Mgt Info & Program Control
US NRC, Washington, D. C. 20555

MAY 22 1978

