

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:7906280086 DOC.DATE: 79/06/25 NOTARIZED: NO DOCKET #
 FACIL:50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Service 05000305
 AUTH.NAME AUTHOR AFFILIATION
 RUITER,G.H. Wisconsin Public Service Corp.
 RECIP.NAME RECIPIENT AFFILIATION
 Region 3, Chicago, Office of the Director

SUBJECT: LER 79-010/03L-0 on 790527:auxiliary bldg special
 ventilation zone boundary door found blocked open.Caused by
 failure to post proper notice on door.Notice subsequently
 posted.

DISTRIBUTION CODE: A002S COPIES RECEIVED:LTR -- ENCL -- SIZE:-----
 TITLE: INCIDENT REPORTS

NOTES:-----

| | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL |
|-----------|---------------------------|---------------------|---------------------------|---------------------|
| ACTION: | 05 BC | 4 4 | | |
| INTERNAL: | 01 REG FILE | 1 1 | 02 NRC PDR | 1 1 |
| | 09 I&E | 2 2 | 11 MPA | 3 3 |
| | 14 TA/EDO | 1 1 | 15 NOVAK/KNIEL | 1 1 |
| | 16 EEB | 1 1 | 17 AD FOR ENGR | 1 1 |
| | 18 PLANT SYS BR | 1 1 | 19 I&C SYS BR | 1 1 |
| | 20 AD PLANT SYS | 1 1 | 21 AD SYS/PROJ | 1 1 |
| | 22 REAC SAFT BR | 1 1 | 23 ENGR BR | 1 1 |
| | 24 KREGER | 1 1 | 25 PWR SYS BR | 1 1 |
| | 26 AD/SITE ANAL | 1 1 | 27 OPERA LIC BR | 1 1 |
| | 28 ACCIDENT ANALYS | 1 1 | 29 AUX SYS BR | 1 1 |
| | E JORDAN/IE | 1 1 | HANAUER,S. | 1 1 |
| | TMI DOC CENTER | 1 1 | | |
| EXTERNAL: | 03 LPDR | 1 1 | 04 NSIC | 1 1 |
| | 29 ACKS | 16 16 | | |

TOTAL NUMBER OF COPIES REQUIRED: LTTR 48 ENCL 48

LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 W I K N P 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
 7 8 9 14 15 25 26 30 57 CAT 58

CON'T
01 L 6 0 5 0 0 0 3 0 5 7 0 5 2 7 7 9 8 0 6 2 5 7 9 9
 7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 With the reactor at hot shutdown conditions during normal operation preparatory to
03 entering refueling, one Auxiliary Building Special ventilation zone (ASV) boundary
04 door was found blocked open. With the plant above cold shutdown condition contain-
05 ment system integrity was required; therefore, the facility was under LCO TS 3.6.b.2.
06 All other components of ASV were operational and the reactor was shutdown during the
07 time this condition existed. The ASV-system is designed & tested capable of per-
08 forming its safeguard function even with one door open, therefore, there was no ef-
 7 8 9 80

09 S H 11 X 12 Z 13 Z Z Z Z Z 14 Z 15 Z 16
 9 10 11 12 13 18 19 20
 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
17 7 9 0 1 0 0 3 L 0
 21 22 23 24 26 27 28 29 30 31 32
 LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
 ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
X 18 Z 19 Z 20 Z 21 0 0 0 0 N 23 N 24 Z 25 Z 9 9 9 9 26
 33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 This door was recently replaced as part of required facility security modifications.
11 A CAUTION notice regarding ASV boundary requirements had not been transferred to the
12 new door. In the absence of this notice, plant personnel did not immediately realize
13 that the door was part of the ASV boundary. The door was shut upon identification.
14 The proper notice has been posted on the door. No further action required.
 7 8 9 80

15 G 28 0 0 0 29 Hot Shutdown 30 A 31 Operator observation 32
 7 8 9 10 12 13 44 45 46 80

16 Z 33 Z 34 NA 35 NA 36
 7 8 9 10 11 44 45 80

17 0 0 0 37 Z 38 NA 39
 7 8 9 10 11 12 13 80

18 0 0 0 40 NA 41
 7 8 9 10 11 12 80

19 Z 42 NA 43
 7 8 9 10 11 12 80

20 N 44 NA 45
 7 8 9 10 80

NAME OF PREPARER G. H. Ruiter

PHONE: (414) 433-1329

7906280086

LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 WIKNP1 200-00000-00 341111 4 5
7 8 9 14 15 25 26 30 57 CAT 58
 LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CON'T 01 REPORT SOURCE L 605000305 7052779 8062579 9
60 61 68 69 74 75 80
 DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 With the reactor at hot shutdown conditions during normal operation preparatory to
03 entering refueling, one Auxiliary Building Special ventilation zone (ASV) boundary
04 door was found blocked open. With the plant above cold shutdown condition contain-
05 ment system integrity was required; therefore, the facility was under LCO TS 3.6.b.2.
06 All other components of ASV were operational and the reactor was shutdown during the
07 time this condition existed. The ASV-system is designed & tested capable of per-
08 forming its safeguard function even with one door open, therefore, there was no ef-
7 8 9 fect on plant operation or Public safety.

09 SH X Z ZZZZZZ Z Z
9 10 11 12 13 18 19 20
 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
79 010 03 L 0
21 22 23 24 26 27 28 29 30 31 32
 EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
 (17) LER/RO REPORT NUMBER XZ Z Z 000 N N Z Z9999
33 34 35 36 37 40 41 42 43 44 47
 ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRO-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 This door was recently replaced as part of required facility security modifications.
11 A CAUTION notice regarding ASV boundary requirements had not been transferred to the
12 new door. In the absence of this notice, plant personnel did not immediately realize
13 that the door was part of the ASV boundary. The door was shut upon identification.
14 The proper notice has been posted on the door. No further action required.

15 G 000 A Operatorobservation
7 8 9 10 12 13 44 45 46
 FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

16 Z Z NA NA NA
7 8 9 10 11 44 45
 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

17 000 Z NA
7 8 9 11 12 13
 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

18 000 NA
7 8 9 11 12
 PERSONNEL INJURIES NUMBER DESCRIPTION

19 Z NA
7 8 9 11 12
 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

20 N NA
7 8 9 10
 PUBLICITY ISSUED DESCRIPTION

NAME OF PREPARER G. H. Ruiter

PHONE: (414) 433-1329

NRC USE ONLY

LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 W I K N P 12 00 - 000000 - 0034111145

CON'T

01 REPORT SOURCE L6 05 000305 7052779 8062579 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 With the reactor at hot shutdown conditions during normal operation preparatory to
03 entering refueling, one Auxiliary Building Special ventilation zone (ASV) boundary
04 door was found blocked open. With the plant above cold shutdown condition contain-
05 ment system integrity was required; therefore, the facility was under LCO TS 3.6.b.2.
06 All other components of ASV were operational and the reactor was shutdown during the
07 time this condition existed. The ASV-system is designed & tested capable of per-
08 forming its safeguard function even with one door open, therefore, there was no ef-
09 fect on plant operation or Public safety.

SYSTEM CODE SH 11 CAUSE CODE X 12 CAUSE SUBCODE Z 13 COMPONENT CODE ZZZZZZ14 COMP. SUBCODE Z 15 VALVE SUBCODE Z 16
 EVENT YEAR 79 SEQUENTIAL REPORT NO. 010 OCCURRENCE CODE 03 REPORT TYPE L REVISION NO. 0
 LER/RO REPORT NUMBER 17 ACTION TAKEN X 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0000 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER Z 25 COMPONENT MANUFACTURER Z9999 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 This door was recently replaced as part of required facility security modifications.
11 A CAUTION notice regarding ASV boundary requirements had not been transferred to the
12 new door. In the absence of this notice, plant personnel did not immediately realize
13 that the door was part of the ASV boundary. The door was shut upon identification.
14 The proper notice has been posted on the door. No further action required.

FACILITY STATUS G 28 % POWER 000 29 OTHER STATUS Hot Shutdown 39 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Operator observation 32

ACTIVITY CONTENT Z 33 RELEASED OF RELEASE Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

PERSONNEL EXPOSURES NUMBER 000 37 TYPE Z 38 DESCRIPTION NA 39

PERSONNEL INJURIES NUMBER 000 40 DESCRIPTION NA 41

LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

PUBLICITY ISSUED N 44 DESCRIPTION NA 45

20 NAME OF PREPARER G. H. Ruiter PHONE: (414) 433-1329

NRC USE ONLY

GPO 917-926