

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8005290422 DOC. DATE: 80/05/23 NOTARIZED: NO DOCKET #  
 FACIL: 50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Service 05000305  
 AUTH. NAME: WALLACE, J. AUTHOR AFFILIATION: Wisconsin Public Service Corp.  
 RECIP. NAME: REGION 3, Chicago, Office of the Director

SUBJECT: LER 80-021/03L-0: on 800328, monthly vibration test on component cooling pump IWP-3400a, ASME Section 9, was not performed per inservice insp program requirements. Cause not stated. Measurements made three days beyond grace period.

DISTRIBUTION CODE: A002S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+1  
 TITLE: Incident Reports

NOTES: I+E - 3 cys ALL MATERIAL

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	L	ENCL	ID CODE/NAME	L	ENCL
	05 BC <u>ORB #1</u>	4	4			
INTERNAL:	<u>01 REG FILE</u>	1	1	02 NRC PDR	1	1
	09 I&E	2	2	11 MPA	3	3
	15 NOVAK/KNIEL	1	1	16 EEB	1	1
	17 AD FOR ENGR	1	1	18 PLANT SYS BR	1	1
	19 I&C SYS BR	1	1	20 AD PLANT SYS	1	1
	22 REAC SAFT BR	1	1	23 ENGR BR	1	1
	24 KREGER	1	1	25 PWR SYS BR	1	1
	26 AD/SITE ANAL	1	1	27 OPERA LIC BR	1	1
	28 ACCIDENT ANLYS	1	1	29 AUX SYS BR	1	1
	AD/ORP-DOR	1	1	AEOD	10	10
	BERLINGER, C.	3	3	DOUG MAY-TERA	1	1
	HANAUER, S.	1	1	JORDAN, E./IE	1	1
EXTERNAL:	03 LPDR	1	1	04 NSIC	1	1
	29 ACRS	16	16			

MAY 30 1980

TOTAL NUMBER OF COPIES REQUIRED: LTR 63 ENCL 63

*Handwritten initials and marks*

# LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | WIKNP1 | 200-00000-00 | 341111 | 4 | 5  
7 8 9 14 15 25 26 30 57 CAT 58  
 LICENSEE CODE      LICENSE NUMBER      LICENSE TYPE      57 CAT 58

CONT  
01 | L | 605000305 | 7032880 | 8 | 9  
7 8 60 61 68 69 74 75 80  
 REPORT SOURCE      DOCKET NUMBER      EVENT DATE      REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | The monthly vibration test required by the Inservice Inspection Program was not per-

03 | formed within the required time interval on one component cooling pump (IWP-3400(a),

04 | ASME section XI). Since the component cooling pumps are alternately placed in service

05 | during normal plant operation the pump had been operated during the test interval;

06 | this event had no effect on plant operation or public safety.

07 | \_\_\_\_\_

08 | \_\_\_\_\_

09 | WB | A | C | PUMPXX | B | Z  
7 8 9 10 11 12 13 18 19 20  
 SYSTEM CODE      CAUSE CODE      CAUSE SUBCODE      COMPONENT CODE      COMP. SUBCODE      VALVE SUBCODE

17 | 80 | 021 | 03 | L | 0  
7 8 21 22 23 24 26 27 28 29 30 31 32  
 LER/RO REPORT NUMBER      EVENT YEAR      SEQUENTIAL REPORT NO.      OCCURRENCE CODE      REPORT TYPE      REVISION NO.

18 | H | Z | Z | 0000 | N | N | Z | Z999  
7 8 33 34 35 36 37 40 41 42 43 44 47  
 ACTION TAKEN      FUTURE ACTION      EFFECT ON PLANT      SHUTDOWN METHOD      HOURS      ATTACHMENT SUBMITTED      NPRD-4 FORM SUB.      PRIME COMP. SUPPLIER      COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The performance of the monthly vibration test is normally coordinated with routine

11 | operation of the pump as allowed by IWP-3400(b). The vibration measurements were made

12 | 3 days beyond the allowable grace period. Continued awareness of ISI requirements

13 | will minimize recurrence of this event.

14 | \_\_\_\_\_

15 | E | 100 | NA | B | Administrative Review  
7 8 9 10 12 13 44 45 46 80  
 FACILITY STATUS      % POWER      OTHER STATUS      METHOD OF DISCOVERY      DISCOVERY DESCRIPTION

16 | Z | Z | NA | NA | NA  
7 8 9 10 11 44 45 80  
 ACTIVITY CONTENT      RELEASED OF RELEASE      AMOUNT OF ACTIVITY      LOCATION OF RELEASE

17 | 000 | Z | NA  
7 8 9 11 12 13 80  
 PERSONNEL EXPOSURES      NUMBER      TYPE      DESCRIPTION

18 | 000 | NA  
7 8 9 11 12 80  
 PERSONNEL INJURIES      NUMBER      DESCRIPTION

19 | Z | NA  
7 8 9 11 12 80  
 LOSS OF OR DAMAGE TO FACILITY      TYPE      DESCRIPTION

20 | N | NA  
7 8 9 10 80  
 PUBLICITY      ISSUED      DESCRIPTION

8005290 422

NRC USE ONLY

\_\_\_\_\_  
68 69 80  
 (414) 433-1329

NAME OF PREPARER John Wallace

PHONE: \_\_\_\_\_