

Power Reactor

Event # 46955

Site: OCONEE		Notification Date / Time: 06/13/2011 16:04 (EDT)	
Unit: 1 2 3		Region: 2	State : SC
Reactor Type: [1] B&W-L-LP,[2] B&W-L-LP,[3] B&W-L-LP		Event Date / Time: 06/07/2011 11:52 (EDT)	
Containment Type: DRY AMB DRY AMB DRY AMB		Last Modification: 06/13/2011	
NRC Notified by: SANDRA SEVERANCE		Notifications: MIKE ERNSTES R2DO	
HQ Ops Officer: MARK ABRAMOVITZ		PART 21 GROUP	
Emergency Class: NON EMERGENCY			
10 CFR Section:			
21.21	UNSPECIFIED PARAGRAPH		

Unit	Scram Code	RX Crit	Init Power	Initial RX Mode	Curr Power	Current RX Mode
1	N	No	0	Refueling	100	Power Operation
2	N	Yes	100	Power Operation	100	Power Operation
3	N	Yes	100	Power Operation	100	Power Operation

NONCONSERVATIVE VALVE ACTUATOR PROGRAM SOFTWARE

"In Kalsi Engineering Valve and Actuator Program (KVAP) Error Report 2011-02, Kalsi Engineering identified an error in the KVAP software that provides default flow and torque coefficients for ball and plug valves which can affect margin predictions. Communication between Kalsi and Duke Energy personnel confirmed that non-conservative torque values were calculated for select ball valves used at Oconee for containment isolation. As a result of the Kalsi error, the non-conservatively calculated torque values resulted in negative actuator margins, calling into question the actuators' capability to close the valves under all design conditions. Therefore, it has been determined that the KVAP software program error constitutes a defect, reportable under 10CFR21.

"Four safety-related containment isolation valves in the High Pressure Injection system were impacted, requiring entry into TS 3.6.3, Containment Isolation Valves, on two Oconee units [Units 2 and 3]."

Unit 1 was shutdown for a refueling outage at the time of this event and the actuator spring was replaced during the outage. The valves on units 2 and 3 required a Notification of Enforcement Discretion (NOED) which occurred on June 2, 2011. Three of the four valves were declared operable on June 10, 2011 and the remaining valve was declared operable the next day.

The licensee notified the NRC Resident Inspector.

IE19
NRK

Attachment B

OMP 1-14

NRC Event Notification Worksheet

NRC Event Notification Worksheet				
Notification Time	Facility or Organization	Unit	Caller's Name	Call Back #
	Oconee Nuclear Station	1, 2, 3	Sandra Severance	ENS 256-9931 (864) 873-3466

NRC Operations Officer Contacted:	NRC Event Number:

Event Time/Zone	Event Date	Power/Mode Before	Power/Mode After
1152 EST	6/7/2011	Unit 1: Mode 6 Unit 2: 100% Unit 3: 100%	Unit 1: 100% Unit 2: 100% Unit 3: 100%

Event Classifications

- General Emergency
- Site Area Emergency
- Alert

- Unusual Event
- 50.72 Non-emergency (see other columns)
- 72.75 Spent Fuel (ISFSI)
- 73.71 Physical Security
- Transportation
- 20.2202 Material/Exposure
- 26.73 Fitness for Duty
- Other: 21.21(d)(3)(i)

1-Hour Non-emergency 10 CFR 50.72 (b)(1)

- Deviation from TS per 50.54(x)

4-Hour Non-Emergency 10 CFR 50.72 (b)(2)

- (i) TS Required Shutdown
- (iv) (A) ECCS Discharge into RCS
- (iv) (B) RPS Actuation (while critical)
- (xi) News release/notification to other government agencies

8-Hour Non-Emergency 10 CFR 50.72 (b) (3)

- (ii) (A) Degraded Condition
- (ii) (B) Unanalyzed Condition
- (xiii) Loss of emergency assessment capability/offsite communications
- (iv) (A) System Actuation
 - RPS
 - Containment isolation
 - ECCS
 - EFW
 - Containment spray/coolers
 - Emergency AC (Keowee Hydro)
- (v) (A) Safe Shutdown Capability
- (v) (B) Residual Heat Removal Capability
- (v) (C) Control of radiological material
- (v) (D) Accident Mitigation
- (xii) Transport contaminated person to offsite medical facility

Attachment B

OMP 1-14

NRC Event Notification Worksheet

Event Description
<i>(Include systems affected, actuations and their initiating signals, causes, effect of event on plant, actions taken or planned, etc.)</i>
Event: In KVAP Error Report 2011-02, Kalsi Engineering identified an error in the Kalsi Engineering Valve and Actuator Program (KVAP) software that provides default flow and torque coefficients for ball and plug valves which can affect margin predictions. Communication between Kalsi and Duke Energy personnel confirmed that non-conservative torque values were calculated for select ball valves used at Oconee for containment isolation. As a result of the Kalsi error, the non-conservatively calculated torque values resulted in negative actuator margins, calling into question the actuators' capability to close the valves under all design conditions. Therefore, it has been determined that the KVAP software program error constitutes a defect, reportable under 10CFR21.
Initial Safety Significance: Four safety-related containment isolation valves in the High Pressure Injection system were impacted, requiring entry into TS 3.6.3, Containment Isolation Valves, on two Oconee units.
Corrective Action(s): 1. Upon further calculation, two of the containment isolation valves were determined to have adequate margin and were declared operable. 2. Two other containment isolation valves required modifications to restore operability.

Anything unusual or not understood?	<input type="checkbox"/> Yes (Explain above)	<input checked="" type="checkbox"/> No
Did all systems function as required?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No (Explain above)
Mode of operations until corrected:	Estimated restart date:	

Does event result in a radiological release, RCS leak, or steam generator tube leak?	<input type="checkbox"/> Yes (complete page 3)	<input checked="" type="checkbox"/> No
--	--	--

Does the event result in any of the units experiencing a transient?	<input type="checkbox"/> Yes (complete Oconee Plant Status sheet)	<input checked="" type="checkbox"/> No
---	---	--

Notifications			
NRC Resident: <i>Andy Sabisch</i>	<input checked="" type="checkbox"/> Y/N/will be	Plant Manager:	Y/N/will be
Notified By: <i>Kent Alter</i>	Time: <i>1540</i>	Notified By:	Time:
State(s): <i>N/A</i>	<input checked="" type="checkbox"/> Y/N/will be	Operations Superintendent:	Y/N/will be
Notified By:	Time:	Notified By:	Time:
Local: <i>N/A</i>	<input checked="" type="checkbox"/> Y/N/will be	Other Government Agencies:	Y/N/will be
Notified By:	Time:	Notified By:	Time:
Media/Press Release: <i>N/A</i>	<input checked="" type="checkbox"/> Y/N/will be	Other: <i>Preston Gillespie</i>	<input checked="" type="checkbox"/> Y/N/will be
Notified By:	Time:	Notified By: <i>S.N. Sewerany</i>	Time: <i>1235</i>

Operations Shift Manager/Emergency Coordinator Approval:	Date/Time:
<i>[Signature]</i>	<i>06-13-11 1556</i>
NRC Notification Complete by Caller/NRC Communicator:	Date/Time: