

PMSTPCOL PEmails

From: Foster, Rocky
Sent: Wednesday, June 01, 2011 5:10 AM
To: Pohida, Marie
Cc: STPCOL
Subject: FW: Open Items call 6/1/11, Subsection 19.9.3

Marie,

Below is proposed wording to address the issue of discussion for this morning's telecom w/ NINA in regards to section 19.9.3.

Thanks,

Rocky

From: Chappell, Coley [<mailto:ccchappell@STPEGS.COM>]
Sent: Tuesday, May 31, 2011 5:40 PM
To: Foster, Rocky
Cc: Eudy, Michael
Subject: Open Items call 6/1/11, Subsection 19.9.3

Rocky,

The site-specific supplement (COM 19.9-3) provided in Subsection 19.9.3 states that the STP 3&4 operating procedure for severe external flooding will direct that all watertight doors are to be verified closed in the event of potential severe external flooding. Specifically, this requirement is included in supplement items (1) and (3), which were updated in COLA Revision 4 in accordance with the FSAR changes included in Revision 2 of the response to RAI 19-30, dated 7/28/2010. The operating procedure requirements listed in supplement items (1) through (4) are in addition to the guidelines (1) through (5) which are also provided in the same subsection.

Based on the discussion with NRC during the Open Items call on 5/25/11, the following proposed changes, indicated by gray highlight, are provided for consideration in order to clarify guidelines (2) and (3) in Subsection 19.9.3.

- (2) **As an additional protection, consider placing sandbags at** ~~Sandbag~~ **the external doors** ~~above~~ **the design flood level** ~~to the~~
- (3) **Check that** ~~Close and dog~~ **all external water tight doors in the reactor and control buildings** ~~are~~ **closed and dogged.**

Regards,

Coley Chappell
NINA Licensing STP 3&4

Hearing Identifier: SouthTexas34Public_EX
Email Number: 2879

Mail Envelope Properties (26E42474DB238C408C94990815A02F095FA46B88D4)

Subject: FW: Open Items call 6/1/11, Subsection 19.9.3
Sent Date: 6/1/2011 5:09:31 AM
Received Date: 6/1/2011 5:09:32 AM
From: Foster, Rocky

Created By: Rocky.Foster@nrc.gov

Recipients:
"STPCOL" <STP.COL@nrc.gov>
Tracking Status: None
"Pohida, Marie" <Marie.Pohida@nrc.gov>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	1635	6/1/2011 5:09:32 AM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: