



PROPRIETARY

Nuclear Innovation  
North America LLC  
4000 Avenue F, Suite A  
Bay City, Texas 77414

June 20, 2011  
U7-C-NINA-NRC-110080  
10 CFR 2.390

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
One White Flint North  
11555 Rockville Pike  
Rockville, MD 20852-2738

South Texas Project  
Units 3 and 4  
Docket Number PROJ0772  
Responses to Request for Additional Information

Reference: Request for Additional Information RE: South Texas Nuclear Operating Company  
Project Topical Report (TR) WCAP-17202-P, "Supplement 4 to Bison Topical Report  
RPA 90-90-P-A" (TAC No. RG0026) (ML111050109)

Attached are the responses to NRC staff questions included in the reference. The following RAI  
questions are addressed:

RAI 15.00.02-3	RAI 15.00.02-17
RAI 15.00.02-4	RAI 15.00.02-23
RAI 15.00.02-7	RAI 15.00.02-25
RAI 15.00.02-8	RAI 15.00.02-27
RAI 15.00.02-11	RAI 15.00.02-28
RAI 15.00.02-12	RAI 15.00.02-41

The responses to RAI 15.00.02-7, RAI 15.00.02-12, RAI 15.00.02-17, RAI 15.00.02-23, and  
RAI 15.00.02-41 contain information proprietary to Westinghouse Electric Corporation. Since  
these responses contain information proprietary to Westinghouse Electric Company LLC, they  
are supported by an affidavit signed by Westinghouse, the owner of the information. The  
affidavit sets forth the basis on which the information may be withheld from public disclosure by  
the Commission and addresses with specificity the considerations listed in paragraph (b) (4) of  
Section 2.390 of the Commission's regulations.

STI 32883320

T007  
NRO

Accordingly, it is respectfully requested that the information which is proprietary to Westinghouse be withheld from public disclosure in accordance with 10 CFR Section 2.390 of the Commission's regulations.

Attachments 1 through 12 contain the responses to the above RAI questions. Attachments 13 through 17 contain the non-proprietary versions of the five (5) proprietary responses. Attachment 18 contains the request for withholding of proprietary information, the affidavit, the proprietary information notice, and the copyright notice.


Correspondence with respect to the copyright or proprietary aspects of this information or the supporting Westinghouse Affidavit should reference letter CAW-11-3175 and should be addressed to: J. A. Gresham, Manager, Regulatory Compliance and Plant Licensing, Westinghouse Electric Company LLC, Suite 428, 1000 Westinghouse Drive, Cranberry Township, Pennsylvania, 16066. If this letter becomes separated from the proprietary material it is no longer proprietary.

There are no commitments in this letter.

If you have any questions other than those relating to the proprietary aspects of this response, please contact Scott Head at (361) 972-7136, or Bill Mookhoek at (361) 972-7274.

I declare under penalty of perjury that the foregoing is true and correct.

Executed on 6/20/11



Mark McBurnett

Senior Vice President, Oversight & Regulatory Affairs  
Nuclear Innovation North America LLC

jet

Attachments:

1. RAI 15.00.02-3
2. RAI 15.00.02-4
3. RAI 15.00.02-7 (Proprietary)
4. RAI 15.00.02-8
5. RAI 15.00.02-11
6. RAI 15.00.02-12 (Proprietary)
7. RAI 15.00.02-17 (Proprietary)
8. RAI 15.00.02-23 (Proprietary)
9. RAI 15.00.02-25
10. RAI 15.00.02-27
11. RAI 15.00.02-28
12. RAI 15.00.02-41 (Proprietary)

13. RAI 15.00.02-7 (Non-Proprietary)
14. RAI 15.00.02-12 (Non-Proprietary)
15. RAI 15.00.02-17 (Non-Proprietary)
16. RAI 15.00.02-23 (Non-Proprietary)
17. RAI 15.00.02-41 (Non-Proprietary)
18. Request for Withholding Proprietary Information

cc: w/o enclosure except\*  
(paper copy)

Director, Office of New Reactors  
U. S. Nuclear Regulatory Commission  
One White Flint North  
11555 Rockville Pike  
Rockville, MD 20852-2738

Regional Administrator, Region IV  
U. S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 400  
Arlington, Texas 76011-8064

Richard A. Ratliff  
Bureau of Radiation Control  
Texas Department of State Health Services  
1100 West 49th Street  
Austin, TX 78756-3189

\*Steven P. Frantz, Esquire  
A. H. Gutterman, Esquire  
Morgan, Lewis & Bockius LLP  
1111 Pennsylvania Ave. NW  
Washington D.C. 20004

\*Tekia Govan  
Two White Flint North  
11545 Rockville Pike  
Rockville, MD 20852

(electronic copy)

\*George F. Wunder  
\*Tekia Govan  
Charles Casto  
U. S. Nuclear Regulatory Commission

Jamey Seely  
Nuclear Innovation North America

Peter G. Nemeth  
Crain, Caton & James, P.C.

Richard Peña  
Kevin Pollo  
L. D. Blaylock  
CPS Energy

**RAI 15.00.02-3**

The "Nomenclature for Equations" is found on pages vi-viii of WCAP-17202.

a. Please add  $\xi_{wind}$  and  $\xi_{stat}$  (from Equations 2-2 and 2-3) and C, CONDR,  $k_0$ ,  $k_1$ ,  $k_2$ ,  $\Delta T_{surf}$ , CA and  $A_{eff}$  (from Equations 3-49 and 3-50) to this list.

b. Because the units associated with the nomenclature are not always identified in the text, please add the units to each item in this tabulation.

**Response to RAI 15.00.02-3 (a and b)**

The nomenclature will be updated with units in the approved version of the topical report. Also, some updates and correction of minor errors will be inserted in the nomenclature and unused definitions will be deleted. All changes and insertions, except unit insertions, are highlighted in yellow and the deleted definitions are marked with a strikethrough for traceability. The following is the motivation for deletions and changes:

F: Not used in LTR2.

G: Not used in LTR2.

Leid:  $T_{leid}$  is used in LTR2.

R: this is the *specific* gas constant for nitrogen gas and should be so denoted.

$\xi_1$  to  $\xi_{32}$ : These are called loss coefficients, not drag coefficients.

**NOMENCLATURE FOR EQUATIONS**

$A_1$	[m <sup>2</sup> ]	Inner area for the gas tank-scrum valve line
$A_3$	[m <sup>2</sup> ]	Inner area of the main line after the water tank
$A_{32}$	[m <sup>2</sup> ]	Inner area of branch line to rotary actuator
$A_4$	[m <sup>2</sup> ]	Plunge area of the rotary actuator
$A_{41}$	[m <sup>2</sup> ]	Effective leakage area in the rotary actuator
$A_{eff}$	[m <sup>2</sup> ]	Free area outside the separators
$A_{rel}$	[m <sup>2</sup> ]	Relative opening area for a scrum valve in the water line
$A_{wl}$	[m <sup>2</sup> ]	Inner wall area of the gas tank (for heat transfer)
$A_{w2}$	[m <sup>2</sup> ]	Heat transfer area in the water tank
C	[kg/s·K]	Steam condensation on the water level
CA	[kg/s·K·m <sup>2</sup> ]	Steam condensation per unit area on the water level
CONDR	[-]	Fitting parameter in the steam dome water surface condensation model
$C_p$	[J/kg·K]	Heat capacity
$c_p$	[J/kg·K]	Isobaric thermal capacity for nitrogen gas
$c_v$	[J/kg·K]	Isochoric thermal capacity for nitrogen gas
Dh	[m]	Hydraulic diameter
Eta	[Pa·s]	Dynamic viscosity
<del>F</del>	<del>[]</del>	<del>Notation for water</del>
$F_R$	[N]	Frictional force in an actuator
g	[m/s <sup>2</sup> ]	Gravity constant
<del>G</del>	<del></del>	<del>Notation for steam</del>
$G_1$	[kg/s]	Gas flow between the gas tank and the water tank
$G_2$	[kg/s]	Mass flow water in the main line from the water tank
$G_{21}$	[kg/s]	Mass flow to the extracted actuators

$G_{22}$	[kg/s]	Mass flow to the non extracted actuators
$G_3$	[kg/s]	Mass flow water in the branch line to the rotary actuator
$G_{41}$	[kg/s]	Leakage flow past the plunge in the rotary actuator
$h_1$	[J]	Enthalpy for the gas in the gas tank
$h_2$	[J]	Enthalpy for the gas after the water tank
$h_{fg}$	[J]	Latent heat of vaporization
$h_G$	[J]	Stagnation enthalpy for the gas flow G1
$HP_3$	[m]	Plus height for the water tank
$HP_4$	[m]	Plus height for the rotary actuator
$HP_5$	[m]	Plus height for the water surface in the reactor tank
$k_0$	[-]	Constant coefficient in the steam dome water surface condensation model
$k_1$	[-]	Constant coefficient in the steam dome water surface condensation model
$k_2$	[-]	Constant coefficient in the steam dome water surface condensation model
$L_3$	[m]	Length of the main line after the water tank
$L_{32}$	[m]	Length of a branch line from the main line to rotary actuator (average for the group)
$T_{leid}$		Leidenfrost (see $T_{leid}$ )
$M_{don}$	[kg]	Weight of moving parts (including control rods) for a rotary actuator
$M_1$	[kg]	Mass for the gas in the gas tank
$M_2$	[kg]	Mass for the gas in the water tank
$N_{don}$	[-]	Number of rotary actuators in the group in question
$N_{don1}$	[-]	Number of extracted rotary actuators in the group
$N_{don2}$	[-]	Number of fully inserted rotary actuators in the group
$Pr$	[-]	Prandtl's number
$p_1$	[Pa]	Pressure in the gas tank
$p_{12}$	[Pa]	Pressure in smallest section or the venturi nozzle
$p_2$	[Pa]	Pressure in the water tank
$p_4$	[Pa]	Pressure in rotary actuator (under plunger)
$p_5$	[Pa]	Reactor steam dome pressure
$p_{45}$	[Pa]	Pressure difference across the plunger in the rotary actuator
$p_{br}$	[Pa]	Specific breaking pressure from the hydraulic brake
$q_1$	[J/s]	Heat flow from the gas tank wall to the gas in the tank
$q_2$	[J/s]	Heat flow from the pipe walls and water to the gas in the water tank
$r$	[m]	Radius
$R_{spec}$	[J/kg·K]	The specific gas constant for nitrogen gas
$Re$	[-]	Reynold's number
$T_{sat}$	[K]	Saturation temperature
$T_{wall}$	[K]	Cladding outside temperature
$T_{leid}$	[K]	Leidenfrost temperature
$T$	[K]	Temperature
$T_1$	[K]	Gas temperature in the gas tank
$T_2$	[K]	Gas temperature in the water tank
$T_{10}$	[K]	Initial temperature for the gas in the gas tank. The tank walls are presumed to maintain this temperature
$T_{20}$	[K]	Initial value for T2. Pipe and tank walls are presumed to stay at this temperature

$T_G$	[K]	Stagnation temperature for the gas flowing through the reactor scram valve
$\Delta T_{surf}$	[°C]	BISON calculated subcooling in the water surface
$t_{open}$	[s]	Time to when the scram valve starts to open (cone leaves its seat)
$t_v$	[s]	Effective valve opening time for the scram valve
$u_1$	[J]	Internal energy for the gas in the gas tank
$u_2$	[J]	Internal energy in the water tank
$V_1$	[m <sup>3</sup> ]	Volume of the gas tank
$V_2$	[m <sup>3</sup> ]	Volume of the gas in the water tank including feed line
$V_3$	[m <sup>3</sup> ]	Volume of the water in the water tank
$V_{23}$	[m <sup>3</sup> ]	The total volume of the water tank
$w$	[m/s]	Speed of the actuators moving parts
$x$	[m]	Coordinate for rotary actuator position
$X$	[-]	Steam quality
$\alpha$	[-]	Factor to account for the impact of water when accelerating the rotary actuator's moving parts
$\alpha_1$	[kg/K·s <sup>3</sup> ]	Effective thermal exchange constant between the gas in the gas tank and the walls of the tank
$\alpha_2$	[kg/K·s <sup>3</sup> ]	Effective heat exchange constant between the gas in the water tank and pipe and tank walls as well as water
$\alpha_{void}$	[-]	Void reactivity feedback of a recirculation flow change
$\varepsilon$	[-]	Emissivity
$\lambda$	[J/m·s·K]	Thermal conductivity
$\xi_1$	[-]	Loss coefficient for the line between gas tank and water tank
$\xi_3$	[-]	Loss coefficient for the main line after the water tank
$\xi_{32}$	[-]	Loss coefficient for the branch line to a rotary actuator (average within a group)
$\xi_{wind}$	[-]	Loss coefficient for a wind-milling pump
$\xi_{stat}$	[-]	Loss coefficient for a stationary pump
$\kappa$	[-]	Isentropic exponent for nitrogen gas
$\rho$	[kg/m <sup>3</sup> ]	Density
$\rho_1$	[kg/m <sup>3</sup> ]	Density of the gas in the gas tank
$\rho_2$	[kg/m <sup>3</sup> ]	Density for the water in the water tank
$\rho_g$	[kg/m <sup>3</sup> ]	Density for gas
$\rho_s$	[kg/m <sup>3</sup> ]	Density of the material in the moving parts of the rotary actuator
$\sigma$	[N/m]	Water surface tension

**RAI 15.00.02-04**

Provide the specific programs and procedures that are in place to train the future users of the BISON code both at Westinghouse and potential licensees (e.g., STP).

**Response to RAI 15.00.02-04**

Westinghouse regularly provides basic training in the BISON code, both for Westinghouse employees and licensees. The basic training gives the user knowledge of how to use the BISON code both for input preparation (modeling of reactor system and input data needed) and interpretation of the output. The training gives hands-on experience to get the code running and knowledge of how to prepare output figures.

There are a number of internal Westinghouse procedures that describe the process to perform transient analysis using BISON. These procedures can be made available for an audit.

**RAI 15.00.02-08**

Per Section 3.1.2.3 of WCAP-17202, the VALVE factor is zero for a fully opened valve. Depending on the type of valve, a fully open valve can also have a finite form loss. Provide justification for not including the form loss for a fully open scram valve in the general formulation of the model.

**Response to RAI 15.00.02-08**

The loss coefficient for a fully open valve is included in  $\xi_3$ , the loss coefficient for the main line where the valve is situated, as seen in Figure 3-1. The VALVE equation in section 3.1.2.3 describes the additional pressure drop of an opening valve, which is not included in  $\xi_3$ .

**RAI 15.00.02-11**

Equation 3-11 of WCAP-17202 provides an energy balance for the gas space in the water tank. Please explain why the heat transfer from the gas tank wall,  $q_1$ , is used in the energy balance for the water tank.

**Response to RAI 15.00.02-11:**

The term " $q_1$ " in Equation 3-11 is incorrect. The term " $q_1$ " should be " $q_2$ " ( $q_2$  is defined in Equation 3-18). This correction will be made in the approved version of the topical report. The correction only affects the description provided in the topical report. The correct equation described by Equation 3-11 is programmed in the BISON code.

The existing Equation 3-11:

$$q_1 + G_1 \cdot h_G - p_2 \cdot \frac{dV_2}{dt} = \frac{d}{dt} \cdot (M_2 \cdot u_2)$$

Will be replaced in the approved version of WCAP-17202 with the correct Equation 3-11, indicated below:

$$q_2 + G_1 \cdot h_G - p_2 \cdot \frac{dV_2}{dt} = \frac{d}{dt} \cdot (M_2 \cdot u_2)$$

**RAI 15.00.02-25**

The BISON asynchronous pump model presented in Section 3.3.2.1 of WCAP-17202 includes a slip parameter  $k_s$ , defined as the relative difference between the stator and rotor angular speeds. Stator speed in this model is a time-dependent control input from SAFIR, while the rotor speed is described as a time-dependent output.

- a. Please clarify the procedure by which the slip parameter is calculated in BISON (e.g., using old timestep values of the angular speeds to calculate slip used in obtaining the new timestep rotor speed).
- b. Discuss how impedance  $Z_2$  was derived.

**Response to RAI 15.00.02-25**

- a. The slip parameter definition in Equation 3-41 is not correctly described in the Topical Report.

The current definition is:


$$k_s = \frac{\omega_s - \omega_r}{\omega_r}$$

It will be updated in the approved version of the topical report to:


$$k_s = \frac{\omega_s - \omega_r}{\omega_s}$$

In the BISON ASYNC model, the slip parameter is calculated in every time step according to the updated definition provided above. The terms " $\omega_s$ " and " $\omega_r$ " are both boundary conditions and when combined with the slip, and the generated power over  $R_2$  the angular momentum ( $T_{\text{motor}}$ ) can be found. The  $\omega_{\text{motor}}$  in Figure 3-15 is misplaced and hence the figure will be updated in the approved version of the topical.

The current figure is:



The updated figure will be:




The reason for this update is that equation 3-39 is not actually solved in the asynchronous motor model.

b. The impedance  $Z_2$  should be consistent with Figure 3-16, defined as  $\frac{R_2}{s} + jX_2$  in our derivation. It will be updated in the approved version of the topical report. This is because when the machine is rotating, the relative field/rotor motion is no longer at the synchronous speed, and all rates of flux change affecting the rotor are modified in proportion to the slip factor. Consequently the voltage over the rotor becomes  $sE_1$ , the rotor circuit frequency becomes  $sf_1$ , and hence the rotor leakage reactance changes from the standstill value  $X_2'$  to  $sX_2'$  (see figure on next page). From Ohm's law we have the following relation:

$$sE_1 = I_2(sX_2 + R_2)$$

To make this correspond to the simplified equivalent scheme in Figure 3-16, the voltage is scaled to  $E_1$ .

This yields the expression for  $Z_2$  stated above.



**RAI 15.00.02-27**

Section 3.4 of WCAP-17202 describes the BISON/SAFIR interface for level measurement and states that it uses the BISON nozzle-component. However, the description of a BISON nozzle-component is neither provided in WCAP-17202 nor in RPA-90-90-P-A. If a new component is being introduced into the BISON code, provide an explanation of the new component and its integration into the BISON code, using the same level of detail as other BISON components described Section 3.8 of RPA-90-90-P-A. If the BISON nozzle-component already exists, provide a reference to its description.

**Response to RAI 15.00.02-27**

The level measurement model presented in RPA-90-90-P-A, Section 3.9.2, has been replaced by the functionality of the SAFIR code system in conjunction with the new BISON nozzle component. The BISON nozzle component can calculate the pressure at an arbitrary axial elevation in the Reactor Pressure Vessel (RPV). The calculated pressure is determined according to Equation 3-44 in the subject LTR.

**RAI 15.00.02-28**

With respect to the equations in Section 3.4 of WCAP-17202

- a. Does the non-modified BISON level,  $Z_0$ , represent the two-phase (mixture) level or the collapsed water level (void fraction = 0)?
- b. Is the density used in these equations a single phase density or a mixture density?

**Response to RAI 15.00.02-28**

- a) The non-modified BISON level,  $Z_0$ , represents the two-phase mixture level.
- b) The density used in this equation is a mixture density, as both the steam density and the water density are taken into account.

**RAI 15.00.02-07**

In proprietary Equation 3-3 of WCAP-17202, the form loss for the valve appears to be given by the expression in parenthesis. Provide justification for using this expression as the form loss.

**Response to RAI 15.00.02-07**

The constant pressure drop from a fully open valve is included in  $\xi_3$ , the loss coefficient for the main line where the valve is situated. The VALVE term shown below is intended to describe the additional pressure drop due to an opening or closing of the valve.

$$\left[ \quad \quad \quad \right]^{a,c}$$

The VALVE term is based on the general formula for a local pressure loss divided by the flow squared:

$$\frac{\Delta p}{U^2} = \frac{1}{2\rho A^2}$$

The term in parenthesis is to account for the changes in pressure drop due to opening of the scram valve. This term is valid for both the condition of  $A_{rel} = 1$  for the completely open valve (pressure drop determined by  $\xi_3$  and  $A_3$  and therefore no additional pressure loss), and  $A_{rel} = 0$  for the closed valve (infinite pressure drop – no flow through the valve). The exponent on the term in the parenthesis comes from the fact that it is the square of the relative area that correctly affects the total pressure loss.

**RAI 15.00.02-12**

Section 3.1.2.7 of WCAP-17202 describes the water flow from the water tank to the rotary actuator using level descriptors (HP<sub>3</sub>, HP<sub>4</sub>, HP<sub>5</sub>) from Figure 3-1. If the levels are calculated dynamically, provide the relevant equations. If not, justify the use of constant values.

**Response to RAI 15.00.02-12**

HP<sub>3</sub> and HP<sub>5</sub> are used as constant values during the transient to account for the elevation pressure drop between the water tank level and the reactor water level. The reactor water level may increase or decrease during the transient, affecting the pressure drop. However, the contribution to the overall pressure drop is insignificant as compared to the elevation difference between the nominal water tank level and the reactor water level (approximately 21 m in the ABWR). Hence, if the reactor water level increases or decreases by 0.5 m (for example in the ABWR), the contribution from the water tank level and the reactor water level elevation pressure drop would change by only a few percent. Furthermore, the elevation pressure drop to the total pressure drop from the gas tank to the control rod drive mechanism is of much smaller importance than the pressure drop in the pipes caused by frictional pressure drop and local pressure drop. [

] <sup>a,c</sup> Thus, the elevation pressure drop is of much smaller order of magnitude than the pressure drop caused by friction or local losses. Therefore, using constant values for HP<sub>3</sub> and HP<sub>5</sub> is an adequate assumption.

While HP<sub>3</sub> and HP<sub>5</sub> are constant values, HP<sub>4</sub> is dynamic. HP<sub>4</sub> is used to determine the contribution from the elevation pressure drops according to Equations 3-21 and 3-22 in the LTR. During the hydraulic scram as the control rods move upward, and the distance between the control rod and the reactor water level decreases the position of the control rod actuator is dynamically calculated according to Equation 3-33. However, as noted above, the contribution from the elevation pressure drop is of minor importance in determining the control rod velocity during a hydraulic scram.

**RAI 15.00.02-17**

In proprietary Figure 3-3, the model shows good agreement for the third and fourth data points. In Figure 3-2, please explain the BISON data with regard to validation of the model corresponding to the same x-values.

**Response to RAI 15.00.02-17**

At normal rated conditions for [ ]<sup>a,c</sup>, the pressure difference between the reactor tank and the gas tanks is [ ]<sup>a,c</sup> (the third and fourth data points in Figure 3-3). At normal rated conditions for [ ]<sup>a,c</sup> (Figure 3-2), the pressure difference between the reactor tank and the gas tanks is [ ]<sup>a,c</sup>. Both plant models show a good agreement with measurements for normal rated conditions in their respective pressure ranges.

It can be seen in Figure 3-2 that the experimental insertion time tends to vary approximately [ ]<sup>a,c</sup> s at each pressure. The variation of both the measured and predicted data over the range [ ]<sup>a,c</sup> bar is similarly within the range of [ ]<sup>a,c</sup> s. This means that the model for [ ]<sup>a,c</sup> is consistent with the measured data. In addition, the Westinghouse methodology takes into account these experimental uncertainties.

**RAI 15.00.02-23**

Section 3.2 of WCAP-17202 plots the reactivity change associated with a specified perturbation in recirculation flow, but does not report the nominal flow value.

- Please indicate what change in steady state power is equivalent to this change in flow.
- Please comment on whether this level of perturbation is intended to establish any limits on the applicability of the method.
- Please explain how this level of perturbation qualifies the improved Method B for use on limiting transients where the changes to reactivity and power distribution would seem to be larger than what was plotted.

**Response to RAI 15.00.02-23**

- The table below lists the relevant nominal data and the changes in steady-state data incurred by a change of [ ]<sup>a,c</sup> in core total mass flow rate.

Table 1 – Relevant Nominal Data for Verification Cases

Parameter	Homogeneous Core	Mixed Core	Peach Bottom 2
Thermal Power [MW]	2300.1	3926.0	TT1: 1560.9 TT2: 2030.1 TT3: 2275.1
Core Recirculation Flow [kg/s]	5500.0	13050.0	TT1: 12763.8 TT2: 10445.4 TT3: 12839.4
Steam Dome Pressure [bar]	70.00	71.70	TT1: 68.35 TT2: 67.31 TT3: 68.02
Core Inlet Enthalpy [kJ/kg]	1177.13	1222.00	TT1: 1229.05 TT2: 1209.07 TT3: 1217.84

Table 2 – [ ]<sup>a,c</sup>

--

- This level of perturbation (i.e. [ ]<sup>a,c</sup>) is not intended to establish any limits on the applicability of the method. Since the cross-section representation model (polynomial coefficients) is generated in such a manner that the entire expected range of variation in

state conditions during a transient is covered, the flow variation is not used for establishing any limits on the method applicability. This particular variation in flow was employed merely to compute a reactivity change for comparison between BISON and the nodal code POLCA7, to demonstrate that the two codes yield similar responses around a given reference steady-state condition. The main purpose of the BISON versus POLCA7 comparison was to verify that the improved Multiple Fuel Type cross-section model (improved Method B) actually produces a good initial steady-state axial power distribution without the need for an axial burnup or control rod density search to match the input POLCA7 power distribution. Since the original Method B requires such a search in order to obtain a reasonable axial power profile, the “improved” model can indeed be considered an improvement over the old one.

The homogeneous and mixed core evaluations can be considered verification cases. Likewise, the reactivity plots comparing BISON, and POLCA7 to measured data for Peach Bottom 2 can be considered validation cases.

- c) As pointed out in b) the [ ]<sup>a,c</sup> perturbation was used only for demonstrative purposes and does not constitute a principle of methodology nor was it done in an effort to validate the application of the improved Method B. The Peach Bottom 2 transient comparisons, on the other hand, serve to validate the application of the improved Method B to limiting transients. Therefore, the improved Method B is appropriate for application to both limiting and non-limiting transient analyses.

**RAI 15.00.02-41**

Proprietary Figure 3-22 of WCAP-17202 shows the comparisons of predicted and measured temperature increases for one fuel type and proprietary Figures 3-24 to 3-26 show similar comparisons for a second fuel type. The correlation shows relatively large scatter for the prediction of the first fuel type compared to the prediction of the second fuel type. Please describe the reason this difference and discuss any differences between the two experiments.

**Response to RAI 15.00.02-41**

The experimental results shown in Figure 3-22 corresponds to fuel type [ ]<sup>a,c</sup>  
and the experimental results in Figures 3-24 through 3-26 corresponds to fuel type [ ]<sup>a,c</sup>. All these dryout experiments were carried out in the [ ]

] <sup>a,c</sup> .

The test rod bundles were composed of a fuel channel, electrically heated fuel rod simulators, tie plates and spacer grids. [ ]

] <sup>a,c</sup>

[ ]

] <sup>a,c</sup>

[ ]

] <sup>a,c</sup>


AFFIDAVIT

COMMONWEALTH OF PENNSYLVANIA:


ss


COUNTY OF BUTLER:

Before me, the undersigned authority, personally appeared J. A. Gresham, who, being by me duly sworn according to law, deposes and says that he is authorized to execute this Affidavit on behalf of Westinghouse Electric Company LLC (Westinghouse), and that the averments of fact set forth in this Affidavit are true and correct to the best of his knowledge, information, and belief:

  
\_\_\_\_\_  
J. A. Gresham, Manager  
Regulatory Compliance

Sworn to and subscribed before me  
this 13th day of June 2011

  
\_\_\_\_\_  
Notary Public



- (1) I am Manager, Regulatory Compliance, in Nuclear Services, Westinghouse Electric Company LLC (Westinghouse), and as such, I have been specifically delegated the function of reviewing the proprietary information sought to be withheld from public disclosure in connection with nuclear power plant licensing and rule making proceedings, and am authorized to apply for its withholding on behalf of Westinghouse.
- (2) I am making this Affidavit in conformance with the provisions of 10 CFR Section 2.390 of the Commission's regulations and in conjunction with the Westinghouse Application for Withholding Proprietary Information from Public Disclosure accompanying this Affidavit.
- (3) I have personal knowledge of the criteria and procedures utilized by Westinghouse in designating information as a trade secret, privileged or as confidential commercial or financial information.
- (4) Pursuant to the provisions of paragraph (b)(4) of Section 2.390 of the Commission's regulations, the following is furnished for consideration by the Commission in determining whether the information sought to be withheld from public disclosure should be withheld.
  - (i) The information sought to be withheld from public disclosure is owned and has been held in confidence by Westinghouse.
  - (ii) The information is of a type customarily held in confidence by Westinghouse and not customarily disclosed to the public. Westinghouse has a rational basis for determining the types of information customarily held in confidence by it and, in that connection, utilizes a system to determine when and whether to hold certain types of information in confidence. The application of that system and the substance of that system constitutes Westinghouse policy and provides the rational basis required.

Under that system, information is held in confidence if it falls in one or more of several types, the release of which might result in the loss of an existing or potential competitive advantage, as follows:

    - (a) The information reveals the distinguishing aspects of a process (or component, structure, tool, method, etc.) where prevention of its use by any of

Westinghouse's competitors without license from Westinghouse constitutes a competitive economic advantage over other companies.

- (b) It consists of supporting data, including test data, relative to a process (or component, structure, tool, method, etc.), the application of which data secures a competitive economic advantage, e.g., by optimization or improved marketability.
- (c) Its use by a competitor would reduce his expenditure of resources or improve his competitive position in the design, manufacture, shipment, installation, assurance of quality, or licensing a similar product.
- (d) It reveals cost or price information, production capacities, budget levels, or commercial strategies of Westinghouse, its customers or suppliers.
- (e) It reveals aspects of past, present, or future Westinghouse or customer funded development plans and programs of potential commercial value to Westinghouse.
- (f) It contains patentable ideas, for which patent protection may be desirable.

There are sound policy reasons behind the Westinghouse system which include the following:

- (a) The use of such information by Westinghouse gives Westinghouse a competitive advantage over its competitors. It is, therefore, withheld from disclosure to protect the Westinghouse competitive position.
- (b) It is information that is marketable in many ways. The extent to which such information is available to competitors diminishes the Westinghouse ability to sell products and services involving the use of the information.
- (c) Use by our competitor would put Westinghouse at a competitive disadvantage by reducing his expenditure of resources at our expense.

- (d) Each component of proprietary information pertinent to a particular competitive advantage is potentially as valuable as the total competitive advantage. If competitors acquire components of proprietary information, any one component may be the key to the entire puzzle, thereby depriving Westinghouse of a competitive advantage.
  - (e) Unrestricted disclosure would jeopardize the position of prominence of Westinghouse in the world market, and thereby give a market advantage to the competition of those countries.
  - (f) The Westinghouse capacity to invest corporate assets in research and development depends upon the success in obtaining and maintaining a competitive advantage.
- (iii) The information is being transmitted to the Commission in confidence and, under the provisions of 10 CFR Section 2.390; it is to be received in confidence by the Commission.
- (iv) The information sought to be protected is not available in public sources or available information has not been previously employed in the same original manner or method to the best of our knowledge and belief.
- (v) The proprietary information sought to be withheld in this submittal is that which is appropriately marked in "Response to the NRC's Request for Additional Information for WCAP-17202, 'Supplement 4 to BISON Topical Report RPA 90-90-P-A'" (Proprietary), for submittal to the Commission, being transmitted by South Texas Project Nuclear Operating Company (STPNOC) letter and Application for Withholding Proprietary Information from Public Disclosure, to the Document Control Desk. The proprietary information as submitted by Westinghouse is that associated with the NRC review of WCAP-17202, and may be used only for that purpose.

This information is part of that which will enable Westinghouse to:

- (a) Assist customers in obtaining NRC review of the Westinghouse Fast Transient and ATWS Methodology topical as applied to current BWR and ABWR plant designs.

Further this information has substantial commercial value as follows:

- (a) Assist customer to obtain license changes.
- (b) The information requested to be withheld reveals the distinguishing aspects of a methodology which was developed by Westinghouse.

Public disclosure of this proprietary information is likely to cause substantial harm to the competitive position of Westinghouse because it would enhance the ability of competitors to provide similar fuel design and licensing defense services for commercial power reactors without commensurate expenses. Also, public disclosure of the information would enable others to use the information to meet NRC requirements for licensing documentation without purchasing the right to use the information.

The development of the technology described in part by the information is the result of applying the results of many years of experience in an intensive Westinghouse effort and the expenditure of a considerable sum of money.

In order for competitors of Westinghouse to duplicate this information, similar technical programs would have to be performed and a significant manpower effort, having the requisite talent and experience, would have to be expended.

Further the deponent sayeth not.

### **PROPRIETARY INFORMATION NOTICE**

Transmitted herewith are proprietary and/or non-proprietary versions of documents furnished to the NRC in connection with requests for generic and/or plant-specific review and approval.

In order to conform to the requirements of 10 CFR 2.390 of the Commission's regulations concerning the protection of proprietary information so submitted to the NRC, the information which is proprietary in the proprietary versions is contained within brackets, and where the proprietary information has been deleted in the non-proprietary versions, only the brackets remain (the information that was contained within the brackets in the proprietary versions having been deleted). The justification for claiming the information so designated as proprietary is indicated in both versions by means of lower case letters (a) through (f) located as a superscript immediately following the brackets enclosing each item of information being identified as proprietary or in the margin opposite such information. These lower case letters refer to the types of information Westinghouse customarily holds in confidence identified in Sections (4)(ii)(a) through (4)(ii)(f) of the affidavit accompanying this transmittal pursuant to 10 CFR 2.390(b)(1).

### **COPYRIGHT NOTICE**

The reports transmitted herewith each bear a Westinghouse copyright notice. The NRC is permitted to make the number of copies of the information contained in these reports which are necessary for its internal use in connection with generic and plant-specific reviews and approvals as well as the issuance, denial, amendment, transfer, renewal, modification, suspension, revocation, or violation of a license, permit, order, or regulation subject to the requirements of 10 CFR 2.390 regarding restrictions on public disclosure to the extent such information has been identified as proprietary by Westinghouse, copyright protection notwithstanding. With respect to the non-proprietary versions of these reports, the NRC is permitted to make the number of copies beyond those necessary for its internal use which are necessary in order to have one copy available for public viewing in the appropriate docket files in the public document room in Washington, DC and in local public document rooms as may be required by NRC regulations if the number of copies submitted is insufficient for this purpose. Copies made by the NRC must include the copyright notice in all instances and the proprietary notice if the original was identified as proprietary.