

PMSTPCOL PEmails

From: Govan, Tekia
Sent: Wednesday, June 01, 2011 11:55 AM
To: Harvey, Brad
Cc: Schaaf, Robert; STPCOL
Subject: RE: STP: Post Chapter Day actions for Chapter 2.3

Done.

Tekia V. Govan, Project Manager
U.S. Nuclear Regulatory Commission
Office of New Reactors
MS T-6-D48
Washington DC 20555-0001
301-415-6197
Tekia.Govan@nrc.gov

From: Harvey, Brad
Sent: Tuesday, May 31, 2011 9:07 AM
To: Govan, Tekia
Cc: Schaaf, Robert; STPCOL
Subject: STP: Post Chapter Day actions for Chapter 2.3

Tekia:

As a result of my review of SER Section 2.3 in preparing for the upcoming ACRS meeting on Phase 4 of Chapter 2, I would like to suggest the following change to pg 2-49 (from "SER Sections 2 1-2 3_OGC incorp_5-10-11.docx"):

- STD DEP 5.0-1 Site Parameter

FSAR Tier 2, Table 2.0-2 shows that the ABWR DCD zero-percent exceedance noncoincident and the one-percent exceedance coincident and noncoincident wet-bulb temperatures do not bound the corresponding STP Units 3 and 4 site characteristics. This finding is identified as Departure STP DEP T1 5.0-1 and is addressed in SER Section ~~9.4.3~~ 9.4.6.

In P2 of the SER, the staff's discussion on STP DEP 5.0-1 appears in Section 9.4.6, not 9.4.3.

Thanks.

Brad
415-4118

Hearing Identifier: SouthTexas34Public_EX
Email Number: 2891

Mail Envelope Properties (F5A4366DF596BF458646C9D433EA37D7937D89C9C8)

Subject: RE: STP: Post Chapter Day actions for Chapter 2.3
Sent Date: 6/1/2011 11:54:41 AM
Received Date: 6/1/2011 11:54:43 AM
From: Govan, Tekia

Created By: Tekia.Govan@nrc.gov

Recipients:

"Schaaf, Robert" <Robert.Schaaf@nrc.gov>
Tracking Status: None
"STPCOL" <STP.COL@nrc.gov>
Tracking Status: None
"Harvey, Brad" <Brad.Harvey@nrc.gov>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

| Files | Size | Date & Time |
|--------------|-------------|------------------------|
| MESSAGE | 1179 | 6/1/2011 11:54:43 AM |

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: