

## PMSTPCOL PEmails

---

**From:** Tai, Tom  
**Sent:** Monday, June 06, 2011 2:46 PM  
**To:** Price, John E  
**Cc:** STPCOL  
**Subject:** June 8, 2011 FIV Telecon Issues

John,

For the Wednesday telephone conference, we need for NINA/WEC to address the following:

In the May 5, 2011 meeting in Rockville, NINA/WEC said they will investigate the difference between the dryer non-acoustic stress analysis and the non-dryer pump pulsation stress analysis. In the non-acoustic stress analysis, stress will be multiplied by a safety factor to get peak stress, but no factor will be applied in the pump pulsation stress analysis. Please add this issue in the agenda for discussion.

I am still waiting for Dr. Ziada if he has any comments or wish list for Wednesday. As soon as I receive them, I'll forward to you.

Regards

Tom Tai  
DNRL/NRO  
(301) 415-8484  
[Tom.Tai@NRC.GOV](mailto:Tom.Tai@NRC.GOV)

**Hearing Identifier:** SouthTexas34Public\_EX  
**Email Number:** 2918

**Mail Envelope Properties** (0A64B42AAA8FD4418CE1EB5240A6FED12E0A9DD6A7)

**Subject:** June 8, 2011 FIV Telecon Issues  
**Sent Date:** 6/6/2011 2:45:38 PM  
**Received Date:** 6/6/2011 2:45:39 PM  
**From:** Tai, Tom

**Created By:** Tom.Tai@nrc.gov

**Recipients:**  
"STPCOL" <STP.COL@nrc.gov>  
Tracking Status: None  
"Price, John E" <jeprice@STPEGS.COM>  
Tracking Status: None

**Post Office:** HQCLSTR02.nrc.gov

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	749	6/6/2011 2:45:39 PM

**Options**  
**Priority:** Standard  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**