

Fiorelli

WISCONSIN PUBLIC SERVICE CORPORATION



P.O. Box 1200, Green Bay, Wisconsin 54305

July 25, 1980

Note: ~~stop report~~  
have been attached.

Mr. G. Fiorelli, Chief  
Office of Inspection & Enforcement  
Region III  
U. S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

Dear Mr. Fiorelli:

Docket 50-305  
Operating License DPR-43  
I&E Inspection Report No. 80-09

The subject inspection report presents the findings of an inspection conducted at the Kewaunee Nuclear Power Plant by Messrs. W. J. Key and J. Schapker of your office. One item of noncompliance, identified as an infraction, was cited for which our response is given below.

INFRACTION: 10 CFR 50, Appendix B, Criterion II, requires the establishment of a program for indoctrination and training of personnel performing activities affecting quality as necessary to assure that suitable proficiency is achieved and maintained.

Wisconsin Public Service Corporation (WPS) procedure, OQAP 13, Revision 1, Subsection 2.4, commits to Regulatory Guide 1.58 "Qualification of Nuclear Power Plant Inspection, Examination and Testing of Personnel" which endorses ANSI N45.2.6. Subsection 3.2.5, states, "Plant personnel performing inspections, examinations and testing activities shall be trained and qualified in accordance with Subsection 2.4. ANSI N45.2.6, Section 2.2, requires that each person who verifies conformance of work activities to quality requirements be certified by his employer as being qualified to perform his assigned work.

Contrary to the above, on May 15, 1980, during an inspection of ISI activities it was determined that no program or procedures were developed for qualifying and training of WPS plant maintenance quality control personnel.

JUL 28 1980

8008200519

Mr. G. Fiorelli  
July 25, 1980  
Page 2

RESPONSE: A training program has been developed and initiated for the qualification and training of Wisconsin Public Service Corporation (WPS) Plant Maintenance Quality Control Personnel in accordance with WPS procedure OQAP, Section 13. We expect to have the documentation complete and up to date by October 1, 1980.

Very truly yours,

*E. R. Mathews*

E. R. Mathews, Vice President  
Power Supply & Engineering

snf