

**NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)**

CONTROL NO: 12512

FILE: _____

FROM: Wisconsin Public Svc. Corp. Green Bay, Wisconsin E.W. James			DATE OF DOC 10-28-75	DATE REC'D 10-30-75	LTR XXX	TWX	RPT	OTHER
TO: Mr. Robert Purple			ORIG 1 Signed	CC 0	OTHER	SENT NRC PDR XXX		XXX
						SENT LOCAL PDR XXX		
CLASS	UNCLASS XXX	PROP INFO	INPUT	NO CYS REC'D 1		DOCKET NO: 50-305		

DESCRIPTION:

Letter trans teh following.....

ENCLOSURES:

Proposed Amdt. # 11 to the 0L/Change # 13 to the Tech. Specs. Consisting of revisions to Tech. Specs with regard to Hydraulic Snubbers...W/ Attached list of Hydraulic Snubbers..

(1 Copy Received)

PLANT NAME: Kewaunee

APP-2

FOR ACTION/INFORMATION

SAB 11-5-75

BUTLER (L) W/ Copies	SCHWENCER (L) W/ Copies	ZIEMANN (L) W/ Copies	REGAN (E) W/ Copies
CLARK (L) W/ Copies	STOLZ (L) W/ Copies	DICKER (E) W/ Copies	LEAR (L) W/ Copies
PARR (L) W/ Copies	VASSALLO (L) W/ Copies	KNIGHTON (E) W/ Copies	SPIES W/ Copies
KNIEL (L) W/ Copies	PURPLE (L) W/ Copies	YOUNGBLOOD (E) W/ Copies	LPM W/ Copies

ACKNOWLEDGED

DO NOT REMOVE

INTERNAL DISTRIBUTION

<u>REG FILE</u> NRC PDR OGC, ROOM P-506A GOSSICK/STAFF CASE GIAMBUSO BOYD MOORE (L) DEYOUNG (L) SKOVHOLT (L) GOLLER (L) (Ltr) P. COLLINS DENISE REG OPR FILE & REGION XX MIPC	<u>TECH REVIEW</u> SCHROEDER MACCARY KNIGHT PAWLICKI SHAO STELLO HOUSTON NOVAK ROSS IPPOLITO TEDESCO J. COLLINS LAINAS BENAROYA VOLLMER	DENTON GRIMES GAMMILL KASTNER BALLARD SPANGLER ENVIRO MULLER DICKER KNIGHTON YOUNGBLOOD REGAN PROJECT LDR HARLESS	<u>LIC ASST</u> R. DIGGS (L) H. GEARIN (L) E. GOULBOURNE (L) P. KREUTZER (E) J. LEE (L) M. RUSHBROOK (L) S. REED (E) M. SERVICE (L) S. SHEPPARD (L) M. SLATER (E) H. SMITH (L) S. TEETS (L) G. WILLIAMS (E) V. WILSON (L) R. INGRAM (L) M. DUNCAN (E)	<u>A/T IND.</u> BRAITMAN SALTZMAN MELTZ <u>PLANS</u> MCDONALD CHAPMAN DUBE (Ltr) E. COUPE PETERSON HARTFIELD (2) KLECKER EISENHUT WIGGINTON
---	--	--	---	--

EXTERNAL DISTRIBUTION

1 - LOCAL PDR Kewaunee, Wisconsin	1 - NATIONAL LABS	1 - PDR-SAN/LA/NY
1 - TIC (ABERNATHY) (1)(2)(10)	1 - W. PENNINGTON, Rm E-201 GT	1 - BROOKHAVEN NAT LAB
1 - NSIC (BUCHANAN)	1 - CONSULTANTS	1 - G. ULRIKSON ORNL
1 - ASLB	NEWMARK/BLUME/AGBABIAN	
1 - Newton Anderson		
16 - ACRS XXXXXX SENT to L.A. S. Sheppard		

WISCONSIN PUBLIC SERVICE CORPORATION



P.O. Box 1200, Green Bay, Wisconsin 54305

October 28, 1975 ^{Regulatory}



File Cy_a

Director of Nuclear Reactor Regulation
Operating Reactors Branch #1
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

ATTN: Mr. Robert A. Purple, Chief

Dear Sir:

REF: Docket No. 50-305
Operating License DPR-43
Proposed Amendment No. 11, Change No. 13
to the Technical Specifications and
Operating License - Kewaunee Nuclear
Power Plant



Attached is a list of hydraulic snubbers which are designed either to prevent unrestrained pipe motion, which motion could be unacceptable on systems required to function post-accident or to prevent pipe motion which could cause an accident or increase the severity of an accident. This listing of hydraulic snubbers was requested by Mr. J. D. Neighbors of your staff. This listing is being supplied to clarify which hydraulic snubbers installed in the Kewaunee Plant would be required to be operable by proposed Technical Specification 3.14.

Very truly yours,

A handwritten signature in cursive script, appearing to read "E. W. James".

E. W. James
Senior Vice President
Power Supply & Engineering

EWJ:sna
Attach.

12512

<u>System Name</u>	<u>Snubber I.D. Number</u>	<u>Approximate Location & Elevation</u>
Reactor Coolant	Anchor Holth 900K custom suppressors 1 through 8	Lateral restraint for steam generators (4 on each)
Steam Supply to Aux. FW Pump 1C (SS)	SS-H67	1'-10 3/4" S of col. 9 6'-1 3/4" E of col. E EL. 593'-0"
(SS)	SS-H76	1'-6" S of col. 4 2'-6" E of col. HE EL. 603'-1"
(SS)	SS-H-86	0'-0" N of col. 8 8'-7" E of col. G EL. 588'-1"
(SS)	SS-H87	0'-0" N of col. 8 9'-10" E of col. G EL. 588'-1"
(SS)	SS-H88	0'-0" N of col. 8 9'-10" E of col. G EL. 588'-0"
(SS)	SS-H129	0'-0" N of col. 6 2'-6" E of col. GW EL. 638'-2 3/4"
(SS)	SS-H150	3" N of col. 65 1'-11" W of col. LW EL. 635'-0"
(SS)	SS-H103	3'-0" N of col. 5 2'-4" E of col. G EL. 593'-3"
(SS)	SS-H146	10'-8" W of col. K 2'-5 1/2" S of col. 6 EL. 634'-9 1/2"
Residual Heat Removal (RHR)	RHR-H10H	20'-9" N of col. 6 21'-0" E of col. K EL. 601'-0"
(RHR)	RHR-H12B	9'-7 1/2" N of col. 6 22'-2" E of col. 95 EL. 598'-6"
(RHR)	RHR-H14	36'-1" N of col. W 18'-6 5/8" E of col. N EL. 607'-6"

<u>System Name</u>	<u>Snubber I.D. Number</u>	<u>Approximate Location & Elevation</u>
(RHR)	RHR-H15	36'-0 3/8" N of col. W 18'-6 5/8" E of col. N EL. 607'-6"
(RHR)	RHR-H16A	5'-2 1/2" N of col. 6 12'-8 1/2" E of col. K EL. 617'-9"
(RHR)	RHR-H18	27'-2 7/16" N of col. E 23'-4 7/16" E of col. N EL. 611'-0"
(RHR)	RHR-H49	20'-0" N of col. 6 22'-1" E of col. 95 EL. 601'-6"
Safety Injection (SI)	SI-H35	2'-0" N of col. 6 15'-11 3/8" E of col. K EL. 606'-9"
(SI)	SI-H60	3'-0" S of Col. 6 1'-6" W of Col. HW EL. 629'-11 5/4"
(SI)	2180	Inside Containment EL. 620'-5" NE Quadrant
(SI)	2243	Inside Containment EL. 614'-0" NE Quadrant
(SI)	2295	Inside Containment NE Quadrant EL. 620'-5"
(SI)	2513	Inside Containment NE Quadrant EL. 630'-2"
(SI)	RSI-H2A	46'-11 1/2" N of col. W 16'-15 3/8" E of col. N EL. 607'-0"
(SI)	RSI-15A	1'-6" N of col. W 22'-2" W of col. N EL. 602'-2"
(SI)	RSI-H20B	25'-7 1/2" S of col. W 35'-3" W of col. N EL. 600'

<u>System Name</u>	<u>Snubber I.D. Number</u>	<u>Approximate Location & Elevation</u>
(SI)	RSI-H38	31'-2 3/4" N of col. E 3'-5 1/2" E of col. N EL 607'-5"
(SI)	RSI-H78	34'-7 1/4" N of col. W 15'-9 1/2" E of col. N EL. 601'
(SI)	RSI-H83	17'-5" N of col. W 0'-5 3/4" E of col. N EL 601'-0"
Reactor Coolant RTD Line (RTD)	RTD-H2	7'-10" E from \bar{C} of stm. gen. 1A 6'-10" S from \bar{C} of stm. gen. 1A
(RTD)	RTD-H6	15'-3 1/2" E from \bar{C} of stm. gen. 1A 11'-9" S from \bar{C} of stm. gen. 1A EL 615'-3 3/16"
(RTD)	RTD-H11	6'-2" N from \bar{C} of stm. gen. 1B 6'-3" W from \bar{C} of stm. gen. 1B EL 616'-10 1/4"
Internal Contain- ment Spray (ICS)	ICS-H7	13'-8 5/16" E of col. N 47'-10" N of \bar{E} of cont. vessel EL. 626'-8"
(ICS)	ICS-H8	13'-8 5/16" E of col. N 97'-10" N of \bar{E} of cont. vessel EL. 627'-0"
(ICS)	ICS-H9	8'-7 1/8" E of col. N 52'-2" N of col. E EL. 644'-6"
(ICS)	ICS-H10	49'-6" R from \bar{E} of cont. vessel 8'-7 1/8" N of col. E EL. 626'-8"
(ICS)	ICS-H11	49'-6" R from \bar{C} of cont. vessel 8'-7 1/8" N of col. 5 EL. 627'-0"

<u>System Name</u>	<u>Snubber I.D. Number</u>	<u>Approximate Location & Elevation</u>
(ICS)	ICS-H12	52'-1 7/8" from E of cont. vessel 9'-0 5/8" N from E of cont. vessel EL. 649'-6"
Main Steam (MS)	MS-H15A	4'-8" N of col. 6 1'-0 5/16" W of col. J EL. 664'-6"
(MS)	MS-H80	0'-9" S of col. 6 6'-8 3/8" W of col. F EL. 619'-2"
(MS)	MS-H85	4'-11 1/2" N of col. 5 4'-0 1/4" E of col. G EL. 619'-6"
(MS)	MS-H86	11'-0" N of col. 7 8'-9 7/8" E of col. G EL. 619'-5 15/16"
(MS)	MS-H87	12'-6" N of col. 7 9'-6" E of col. G EL. 619'-5 7/8"
(MS)	MS-H95	5'-0" N of col. 6 1'-10" E of col. L EL. 664'-10 1/2"
(MS)	MS-H96	3'-6" S of col. SN 6'-5 1/16" W of col. H EL. 664'-4 1/8"
(MS)	MS-H97	6'-6" N of col. 7N 5'-11 15/16" W of col. H EL. 664'-2 1/4"
(MS)	MS-H98	8'-0" N of col. 7 1'-4" W of col. G EL. 652'-6"
(MS)	MS-H99	23'-6 13/16" N of col. 7 2'-11" + W of col. E EL. 619'-1 13/16"
(MS)	MS-H94	13' N of col. 6 6' W of col. LW EL. 664'-11"

<u>System Name</u>	<u>Snubber I.D. Number</u>	<u>Approximate Location & Elevation</u>
Aux. Coolant (AC)	RAC-H-75	36'-0" N of col. W 1'-9 5/8" E of col. N EL. 601'-3 1/4"
(AC)	RAC-H-76	6'-6" N of col. W 24'-5 21/32" W of col. N EL 601'-1 1/4"
(AC)	RAC-H-39	9'-9 5/16" S of col. W 34'-1 1/16" W of col. EL. 559'-8 1/4"
(AC)	RAC-H-38	9'-4 5/16" S of col. W 34'-1 8/16" W of col. EL. 559'-1 1/8"
(AC)	RAC-H-21	39'-9 3/4" N of col. E 9'-8 1/16" E of col. N EL 600'-8 1/4"