

Docket file

SEP 28 1973

Docket No. 50-305

Mr. E. W. James  
Senior Vice President  
Wisconsin Public Service  
Corporation  
P. O. Box 1200  
Green Bay, Wisconsin 54305

Dear Mr. James:

Recently, it has come to the attention of the staff that there exists a potential for possible energy addition to the containment during the period after the core has been recovered with water following a postulated LOCA. This subject has been discussed with Westinghouse on a generic basis and it is my understanding that analyses currently are underway to examine the extent of the problem as it applies to Kewaunee as well as to other plants.

While the problem, reportedly, is not serious for Kewaunee, in order that we may complete our records, it is requested that as soon as possible you file in the FSAR a reply to the following request for additional information:

The containment pressure response analysis should be expanded to include the effects of possible energy addition during the period when the core has been recovered with water. Considering that a break in a cold leg at the pump suction has occurred, the core will be cooled by boiling and a two-phase mixture of steam and water will exist in the core. Provide the results of an analysis showing the height as a function of time for the two-phase mixture level above the core. If any entrained liquid is determined to exit the core and enter the steam generators, provide the ensuing energy release rate into the containment and the results of an analysis of the containment pressure response for this release.

*Copy*  
*CS*

OFFICE ▶						
SURNAME ▶						
DATE ▶						

Mr. E. W. James

-2-

In view of the short period of time remaining before the filing of testimony in preparation for resumption of the Kewaunee hearing, and with the concurrence of your Mr. Giesler, I am forwarding copies of this letter directly to Mr. DeLong at Pioneer Service & Engineering and to Mr. Santoro at Westinghouse.

Sincerely,

Karl Kniel, Chief  
Pressurized Water Reactors Branch No. 2  
Directorate of Licensing

cc: Mr. C. Giesler  
Superintendent of Nuclear Power  
Wisconsin Public Service Corporation  
P. O. Box 1200  
Green Bay, Wisconsin 54305

Mr. Max DeLong  
Pioneer Service & Engineering  
2 North Riverside Plaza  
Chicago, Illinois 60606

Mr. Joe Santoro  
Manager, Kewaunee Project  
Westinghouse Electric Corporation  
PWR Systems Division  
Pittsburgh, Pennsylvania 15230

Steven E. Keane, Esq.  
Foley, Sammand and Lardner  
735 North Water Street  
Milwaukee, Wisconsin 53202

G. Charnoff, Esq.  
Shaw, Pittman, Potts, Trowbridge  
910-17th Street, N.W.  
Washington, D. C. 20006

OFFICE ▶					
SURNAME ▶					
DATE ▶					

Mr. E. W. James

-3-

cc: Robert Vollen, Esq.  
109 North Dearborn Street  
Suite 10005  
Chicago, Illinois 60602

Joseph Gallo, Esq.  
Regulatory Staff Counsel  
United States Atomic Energy  
Commission  
Washington, D. C. 20545

DISTRIBUTION:

AEC PDR  
Local PDR  
Docket File  
RP Reading  
R. C. DeYoung  
PWR Branch Chiefs  
R. W. Klecker  
R. Tedesco  
L. Kintner  
P. B. Seiffert, OGC  
L. Crocker  
M. Service  
PWR-2 Reading  
ACRS (16)

OFFICE ▶	L:PWR-2	L:PWR-2				
SURNAME ▶	<i>MC</i> LCrocker:eg	<i>KK</i> KKniel				
DATE ▶	9/27/73	9/28/73				