6.0 ADMINISTRATIVE CONTROLS

6.1 RESPONSIBILI

6.1.1 The Plant Manager has overall on-site responsibility for plant operation. In the absence of the Plant Manager, the succession to this responsibility shall be in the following order:

a. Maintenance Superintendent

- b. Operations Superintendent
- c. Assistant Superintendent Operations
- d. Nuclear Plant Services Superintendent

6.2 ORGANIZATION

OFFSITE

6.2.1 The offsite organization for plant management and technical support shall be basically as shown on Figure TS 6.2-1.

42

42

42

42

FACILITY STAFF

- 6.2.2 The plant organization shall basically be as shown on Figure TS 6.2-2 and:
 - a. Each on-duty shift complement shall consist of at least:
 - (1) One Shift Supervisor (SRO)
 - (2) Two licensed Reactor Operators
 - (3) One Auxiliary Operator
 - (4) One Equipment Operator
 - incapacitated due to illness or injury, reactor
 operations may continue with the reduced complement
 until his replacement arrives. In all but severe
 weather conditions, a replacement is required within
 two hours.

Proposed Amendment No. 42 9/8/80

TS 6-1

Manager on matters related to nuclear safety.

COMPOSITION

6.5.1.2 The PORC shall be composed of, but not necessarily limited to:

Chairman:

Plant Manager

Required Members:

Maintainance Superintendent Operations Superintendent Assistant Superintendent-

Operations

Reactor Supervisor Technical Supervisor

Quality Control Supervisor Nuclear Plant Services

Superintendent

42

42

ALTERNATES

6.5.1.3 Alternate members shall be appointed in writing by the PORC Chairman to serve on a temporary basis; however, no more than two alternates shall participate in PORC meetings at any one time.

MEETING FREQUENCY

6.5.1.4 The PORC shall meet at least once per calendar month and as convened by the Chairman.

QUORUM

6.5.1.5 A quorum of the PORC shall consist of the Chairman or his designated successor plus three members of which not more than two shall be alternates.

RESPONSIBILITIES

- 6.5.1.6 The PORC shall be responsible for:
 - other procedures or changes to those procedures as determined by the Plant Manager to affect nuclear safety.

42

- b. Review of all proposed tests and experiments that affect nuclear safety.
- c. Review of all proposed changes to the Technical Specifications.
- d. Review of all proposed changes or modifications to plant systems or equipment that affect nuclear safety.
- e. Review all reports covering the investigation of all violations of the Technical Specifications and the recommendations to prevent recurrence.
- f. (Deleted)

42

- g. Performance of special reviews and investigations and prepare reports thereon as requested by the Chairman of the Nuclear Safety Review and Audit Committee.
- h. Review of the Security Plan and Emergency Plan and their respective implementing procedures and shall submit recommended

AUTHORITY

6.5.1.7 The PORC shall:

- a. Recommend to the Plant Manager approval or disapproval of items considered under 6.5.1.6a through d above.
- b. Make determinations with regard to whether or not each item considered under 6.5.1.6a through e above constitutes an unreviewed safety question.
- c. Provide immediate notification in the form of draft meeting minutes to the Manager

 -Nuclear Power and the ChairmanNuclear Safety Review and Audit Committee of disagreement between the PORC and the Plant Manager. The Plant
 Manager shall have responsibility for resolution of such disagreements

RECORDS

6.5.1.8 Minutes shall be kept of all meetings of the PORC and copies shall be sent to the Manager -Nuclear Power and the Chairman-Nuclear Safety Review and Audit Committee.

pursuant to 6.1.1 above.

27

27

42

6.5.2 CORPORATE NUCLEAR ENGINEERING STAFF (CNES)

FUNCTION

6.5.2.1 The CNES shall function to provide engineering,

technical and quality assurance activities in support of the Kewaunee Plant Staff.

ORGANIZATION

- 6.5.2.2 The CNES consists of the following groups:
 - a. Licensing and Nuclear Systems
 - b. Nuclear Services
 - c. Steam Plant Engineering
 - d. Quality Assurance
 - e. Power Plant Design
 - f. Document Control

ACTIVITIES

- 6.5.2.3 1. Investigate and report all violations of the Technical Specifications, codes, regulations, and statutes.
 - 2. Review all activities associated with nuclear safety for technical adequacy and compliance with internal procedures or instructions.
 - 3. Investigate and report significant operating abnormalities or deviations from normal and expected performance of plant equipment that affect nuclear safety.
 - 4. Investigate and report all events which are required by regulations or Technical Specifications to be reported to the NRC in writing within 24 hours. (The plant staff performs the initial investigation and after consultation with CNES reports events).
 - pated deficiency in some aspect of design or operation of safety related structures, systems or components.

TS 6-6 Proposed Amendment No. 42 9/8/80

- Review and/or prepare safety evaluations of all plant design changes.
- 7. Audits as required by the Quality Assurance Program and as outlined in Section 6.5.3.8.

AUTHORITY

6.5.2.4 Quality Assurance is responsible to the Superintendent - Power Plant Design and Construction

A CONSTRUCTION OF A

Although not directly responsible to the Manager -Nuclear Power, they are available for special projects and support as it applies to the Kewaunee Plant.

 $(x_0, x_0, \dots, x_0) = PPO(x_0, x_0)$

6.5.3 NUCLEAR SAFETY REVIEW AND AUDIT COMMITTEE (NSRAC)

- 6.5.3.1 The NSRAC shall function to provide independent review and audit of designated activities in the areas of:
 - a. Nuclear Power Plant Operations
 - b. Nuclear Engineering
 - c. Chemistry and Radio-Chemistry
 - d. Metallurgy
 - e. Instrumentation
 - f. Radiological Safety
 - g. Mechanical and Electrical Engineering
 - h. Quality Assurance Practices
 - i. Other appropriate fields as determined by the Committee, to be associated with the unique characteristics of the nuclear power plant.

COMPOSITION

6.5.3.2 The NSRAC shall be composed of, but not necessarily limited to:

42

- f. Reports covering sinficant operating abnormalities or deviations from normal and expected performance of plant equipment that affect nuclear safety.
- g. Reports covering all events which are required by regulations or Technical Specifications to be reported to the NRC in writing within 24 hours.
- h. Reports covering any indication of an unanticipated deficiency in some aspect of design or operation of safety related structures, systems, or components.
- i. Reports and meeting minutes of the PORC.

AUDITS

- 6.5.3.8 Audits of plant activities shall be performed under the cognizance of the NSRAC; these audits shall include:
 - a. Conformance of plant operation to the provisions contained within the Technical Specifications and applicable license conditions at least annually.
 - b. Performance, training and qualifications of the entire plant staff at least annually.
 - c. Results of all actions taken to correct deficiencies occurring in plant equipment, structures, systems or method of operation that affect nuclear safety at least semiannually.
 - d. Performance of all activities required by the Quality Assurance Program to meet the criteria of Appendix "B", 10 CFR 50, at least once every two years.
 - e. Plant Emergency Plan and Security Plan and their implementing procedures at least once every two years.
 - f. The Plant Fire Protection Program, implementing procedures and the independent fire protection and loss prevention program at least once every 24 months.


SAFETY LIMIT VIOLATION


- 6.7.1 The following actions shall be taken in the event a safety limit is violated:
 - The reactor shall be shutdown and operation shall not be resumed until authorized by the Commission.
 - The Safety Limit violation shall be reported to the Commission, the Manager :-Nuclear Power, and to the NSRAC-Chairman.
 - c. The Report shall be prepared in accordance with Section 6.9 of the Technical Specifications.

PROCEDURES

- 6.8.1 Written procedures and administrative policies shall be established, implemented and maintained that meet the requirements and recommendations of Section 5.1 and 5.3 of ANSI N18.7-1972.
- 6.8.2 Each procedure and administrative policy of 6.8.1 above, and changes thereto, shall be reviewed by the Plant Manager prior to implementation and periodically as determined by the Plant Manager.
- 6.8.3 Temporary changes to procedures of 6.8.1 above may be made provided:
 - The intent of the original procedure is not altered.
 - The change is approved by two members of the Plant Management Staff, at least one of which holds a Senior Reactor Operator's License, if the procedure affects nuclear safety.
 - The change is documented, reviewed by the PORC, and approved by the Plant Manager.

27





KEWAUNEE NUCLEAR POWER PLANT

ORGANIZATION CHART UNIT NO. 1

STREAM TO SUBLIC SERVICE CONFORATION

Operating Shift Complement (5)

1 Shift Supervisor

1 A Control Operator

1 B Control Operator

1 Auxiliary Operator

1 Equipment Operator

Key or Technical Personnel

*Reactor Operator License

**Senior Reactor Operator
License

Figure TS 6.2-2

Proposed Amendment No. 42

September 8. 1980