TABLE 4.1-3

MINIMUM FREQUENCIES FOR EQUIPMENT TESTS

	Equipment Tests***	Test	Frequency	Maximum Time Between Test (Days)
1.	Control Rods	Rod drop times of all full length rods	Each refueling outage	N.A.
		Partial movement of all rods	Every 2 weeks	17
1a.	Reactor Trip Breakers	Open trip	Monthly	37
1b.	Reactor Coolant Pump Breakers-Open-Reactor Trip	Operability	Each refueling outage	N.A.
2.	Pressurizer Safety Valves	Set point	One each refueling outage	N.A.
3.	Main Steam Safety Valves	Set point	Two each refueling outage	N.A.
4.	Containment Isolation Trip	Operability	Each refueling outage	N.A.
5.	Refueling System Interlocks	Operability	Prior to each refueling outage	N.A.
6.	Ventilation System a. Sheild Building b. Auxiliary Building SV Zone c. Spent Fuel Pool	Halide, DOP and Methyl Iodide Pressure Drop Test Visual Inspection	During each refueling outage except as specified in Note**	N.A.
7.	Fire Protection Pump and Power Supply	*Operability	Monthly	37
8.	Containment Leak Detect	Operability	Weekly	8
9.	Diesel Fuel Supply	*Fuel inventory	Weekly	8
10.	Turbine Stop and Governor Valves	Operability	Monthly (1) (2)	37 (1)(2)
11.	Fuel Assemblies	Visual Inspection	Each refueling outage	N.A.
12.	Guard Pipes	Visual Inspection	Each refueling outage	N.A.

NOTES:

* See Specification 4.1.d

** Tests and frequency shall be in accordance with Specifications 4.4.d and 4.12.

*** Following maintenance on the above equipment that could affect the operation of the equipment tests should be performed to verify operability.

(1) This test may be waived for end of cycle operations when boron concentrations are less than 150 ppm, due to operational limitations.

(2) A temporary extension of this requirement to 4 months is granted for a period from January 1, 1981 to April 30, 1981.

8102200131