

- c. When the reactor is above 350°F, one auxiliary feedwater pump may be inoperable provided the pump is restored to operable status within 72 hours, or the reactor shall be shutdown and cooled below 350°F using normal operating procedures. 45

TS 3.4-1a

Amendment No. 45
06/02/82

8206280451 820621
PDR ADOCK 05000305
P PDR