

6.15 CONTAINMENT PURGING

6.15.1 While at operation, containment purging is limited to 90 hours per cycle using the 36-inch purge and vent valves. If this limit is exceeded, the NRC shall be notified in writing within 30 days.

51a