

# REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8510150392 DOC. DATE: 85/10/09 NOTARIZED: YES DOCKET #  
 FACIL: 50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Service 05000305  
 AUTH. NAME: AUTHOR AFFILIATION  
 GIESLER, C. W. Wisconsin Public Service Corp.  
 RECIP. NAME: RECIPIENT AFFILIATION  
 DENTON, H. R. Office of Nuclear Reactor Regulation, Director

SUBJECT: Revised application for amend to DPR-43, revising 850924  
 administrative changes to Tech Specs 3.7.a.8 & 3.7.b.4, Pages  
 3.7-1 & 3.7-2, respectively. Revs do not affect significant  
 hazards analysis.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+3  
 TITLE: OR Submittal: General Distribution

## NOTES:

05000305

OL: 12/21/73

	RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL
	NRR ORB1 BC 01		7 7				
INTERNAL:	ACRS 09		6 6		ADM/LFMB		1 0
	ELD/HDS3		1 0		NRR/DE/MTEB		1 1
	NRR/DL DIR		1 1		NRR/DL/ORAB		1 0
	NRR/DL/TSRG		1 1		NRR/DSI/METB		1 1
	NRR/DSI/RAB		1 1		<u>REG FILE</u> 04		1 1
	RGN3		1 1				
EXTERNAL:	24X		1 1		EG&G BRUSKE, S		1 1
	LPDR 03		1 1		NRC PDR 02		1 1
	NSIC 05		1 1				

**WISCONSIN PUBLIC SERVICE CORPORATION**

P.O. Box 19002, Green Bay, WI 54307-9002



October 9, 1985

Dr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Gentlemen:

Docket 50-305  
Operating License DPR-43  
Kewaunee Nuclear Power Plant  
Proposed Amendment No. 69A

Reference: 1) Letter from C. W. Giesler to H. R. Denton, Proposed Amendment  
No. 69, dated September 24, 1985

Proposed Amendment No. 69A is being submitted as an administrative change to the wording proposed for the Technical Specifications, 3.7a.8 and 3.7.b.4, affected by proposed amendment No. 69 (reference 1).

Description of Proposed Change, Technical Specification 3.7.a.8, Page TS 3.7-1

The sentence, "At least two physically independent transmission lines serving the substation are in service." was changed to "At least one pair of physically independent transmission lines serving the substation is operable."

Safety Evaluation, Technical Specification 3.7.a.8, Page TS 3.7-1

Changing the word "two" to "one pair" is purely administrative as both terms can be used interchangeably. This revision will also clarify Technical Specification 3.7.a.8 as the second sentence of 3.7.a.8 refers to the three combinations of two physically independent transmission lines as "pairs".

Changing the words "are in service" to "is operable" is an administrative revision that provides consistency with this proposed specification and the definition of operable-operability (TS 1.e) added to the KNPP Technical Specifications with Amendment No. 63, dated September 3, 1985.

8510150392 851009  
PDR ADDOCK 05000305  
P PDR

A001  
y1

This revision does not alter the safety evaluation of Proposed Technical Specification 3.7.a.8 in reference 1.

Significant Hazards Determination, Technical Specification 3.7.a.8, Page TS 3.7-1

This revision is purely administrative and does not alter the significant hazards analysis of proposed Technical Specification 3.7.a.8 in reference 1.

Description of Proposed Change, Technical Specification 3.7.b.4, Page TS 3.7-2

The words "in service" were changed to "operable".

Safety Evaluation, Technical Specification 3.7.b.4, Page TS 3.7-2

Changing the words "in service" to "operable" is an administrative revision that develops consistency between this specification and the definition of operable-operability (TS 1.e), added to the KNPP Technical Specifications by Amendment No. 63, dated September 3, 1985.

This revision does not affect the safety analysis of proposed Technical Specification 3.7.b.4 in reference 1.

Significant Hazards Determination, Technical Specification 3.7.b.4, Page TS 3.7-2

This is an administrative revision and it does not affect the significant hazards analysis of proposed Technical Specification 3.7.b.4 in Reference 1.

As required by 10 CFR 50.91(b)(i), a copy of this application and significant hazards determination is being sent to the Public Service Commission of Wisconsin. This application is exempt from fees because it is purely administrative; it does not affect the safety analyses or significant hazards analyses for proposed Technical Specifications 3.7.a.8 and 3.7.b.4 in reference 1.

The Technical Specification pages enclosed in this letter replace those submitted with reference 1.

Sincerely,




Carl W. Giesler  
Vice President - Power Production

GWH/jks

cc - Mr. S. A. Varga, US NRC  
Mr. Robert Nelson, US NRC  
Mr. R. S. Cullen, PSCW

Subscribed and Sworn to  
Before Me This 9<sup>th</sup> Day  
of October 1985

  
Notary Public, State of Wisconsin

My Commission Expires:  
June 28, 1987