

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: B609230280 DDC DATE: 86/09/11 NOTARIZED: NO DOCKET #  
 FACIL: 50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Service 05000305  
 AUTH. NAME AUTHOR AFFILIATION  
 HINTZ, D. C. Wisconsin Public Service Corp.  
 RECIP. NAME RECIPIENT AFFILIATION  
 Division of Rules and Records

SUBJECT: Supports NRC decision that NSHC warranted in issuing license  
 amend to Duke Power Co allowing performance of mass-plot  
 calculations. NRC should issue guidance that mass-plot method  
 acceptable to show compliance w/App J.

DISTRIBUTION CODE: DS09D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 3  
 TITLE: Public Comment on Proposed Rule (PR)- Misc. Notice; eg. Reg Guide, NU

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
INTERNAL: ELD/DR	1	ELD/SAIP	1
GC	1	NRR/DSRO DIR	1
<u>REG FILE</u>	1	RES DIR	1
RES/DAE/CSRB	1	RES/PPCS/PPCB	1
EXTERNAL: NRC PDR 01	1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 9 ENCL 2

DS09  
1/0



DOCKETED USNRC  
RULES & PROCEDURES BR  
ADMIN

NRC-86-125  
TELEX 51010 12698 WPSC GRB  
EASYLINK 62891993

WISCONSIN PUBLIC SERVICE CORPORATION

600 North Adams • P.O. Box 19002 • Green Bay, WI 54307-9002

'86 SEP 15 10:48

8/27/86  
51 FR 30591  
86-1

September 11, 1986

Rules & Procedures Branch  
Division of Rules and Records  
Office of Administration  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Gentlemen:

Docket 50-305  
Operating License DPR-43  
Kewaunee Nuclear Power Plant  
Comments on Consideration of Issuance of Amendments to  
Facility Operating Licenses for Duke Power Company,  
Federal Register 30592, Wednesday, August 27, 1986,  
Vol. 51 No. 166

WPSC supports the NRC in their decision that no significant hazards considerations are warranted in issuing a license amendment to the Duke Power Company which would allow them to perform mass-plot calculations on data acquired during a Containment Integrated Leak Rate Test (CILRT). We also agree with the NRC's conclusion that the mass-plot calculation provides a more accurate determination of containment leakage than either the total-time, or point-to-point methods.

An accurate representation of containment leakage is the ultimate goal of a CILRT. Unnecessarily conservative calculation; i.e., total time or mass point, may lead utilities to unnecessarily suspect the integrity of their containment structures. ANSI N56.8, which discusses the mass-plot method, was a result of the industry striving to improve in the area of containment leakage testing.

In review of Duke's proposed license amendment the NRC states, "Licensees who wish to use the mass-plot must submit an application for exemption from the Appendix J requirement that containment integrated leak rate tests will conform to N45.4." It is unfortunate when a technically superior alternative exists and is yet unacceptable to satisfy current regulatory requirements without an exemption. This type of situation undermines the drive for excellence expected of licensees by regulators.

BKG-9/15/86

8609230280 860911  
PDR ADOCK 05000305  
PDR

We feel it would be appropriate for the commission to issue guidance that the mass-plot method of data reduction is acceptable, without specific exemption to Appendix J, to show compliance with Appendix J. It would also be appropriate to consider the mass-plot method with the reduced duration CILRT discussed in BN-TOP-1, "Testing Criteria for Integrated Leakage Rate Testing of Primary Containment Structures for Nuclear Power Plants."

Sincerely,

*Carl Hintz*  
*for*

D. C. Hintz  
Vice President - Nuclear Power


GWH/jms

cc - Mr. G. E. Lear, US NRC  
Mr. Robert Nelson, US NRC

#383



**Wisconsin Public Service Corporation**  
P.O. Box 19002, Green Bay, WI 54307-9002



Rules & Procedures Branch  
Division of Rules and Records  
Office of Administration  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

