

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8804120470 DOC. DATE: 88/04/06 NOTARIZED: NO DOCKET #
 FACIL: 50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Service 05000305
 AUTH. NAME AUTHOR AFFILIATION
 HINTZ, D. C. Wisconsin Public Service Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Notifies that steam generator sleeving operations performed during current refueling outage required adjustment in one of process control variables. Lower hard roll shortened. Change presented to NRC at 880331 meeting.

DISTRIBUTION CODE: IE47D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: 50.59 Annual Report of Changes, Tests or Experiments Made W/out Approv

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD3-3 LA	1 0	PD3-3 PD	5 1
	QUAY, T	1 0		
INTERNAL:	ACRS	10 10	AEOD/DCA	1 1
	AEOD/DSP/TPAB	1 1	NRR/DLPQ/HFB 10	1 1
	NRR/DCEA/EAB 11	1 1	NRR/DREP/RPB 10	2 2
	NRR/DRIS/SGB 9D	1 1	NRR/PMAS/ILRB12	1 1
	<u>REG FILE</u> 02	1 1	RGN3 FILE 01	1 1
EXTERNAL:	LPDR	1 1	NRC PDR	1 1
	NSIC	1 1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 30 ENCL 0



WISCONSIN PUBLIC SERVICE CORPORATION

600 North Adams • P.O. Box 19002 • Green Bay, WI 54307-9002

April 6, 1988

10 CFR 50.59

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Docket 50-305
Operating License DPR-43
Kewaunee Nuclear Power Plant
Steam Generator Sleeve

The steam generator sleeving operations performed during the current Kewaunee refueling outage required an adjustment in one of the process control variables; specifically, the lower hard roll length was shortened.

This change, the attendant engineering analyses, and safety evaluation were presented to the NRC staff during a meeting at NRC's headquarters on March 31, 1988.

This change was determined not to involve an unreviewed safety question, and was incorporated into the sleeving program under the provisions of 10 CFR 50.59.

Sincerely,

Mark March

D. C. Hintz *for*
Vice President - Nuclear Power

DR/jms

cc - Mr. Robert Nelson, US NRC
US NRC, Region III

8804120470 880406
PDR ADDCK 05000305
P PDR

1847
1/0