



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

May 1, 1979

OFFICE OF THE
SECRETARY

Director
Office of the Federal Register
National Archives and Records Service
Washington, D.C. 20403

Dear Sir:

Enclosed for publication in the Federal Register are an original and two certified copies of a document entitled:

WISCONSIN PUBLIC SERVICE CORPORATION, ET AL.

Docket No. 50-305

NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE

Publication of the above document at the earliest possible date would be appreciated.

This material is to be charged to requisition number E-146.

Sincerely,

Samuel J. Chilk
Secretary of the Commission

Enclosures:
Original and 2 certified copies

bcc: ~~Records Facility Branch~~
Office of Public Affairs
Executive Legal Director
Office of Congressional Affairs
Office of the General Counsel
SECY - C&R Branch

UNITED STATES NUCLEAR REGULATORY COMMISSIONDOCKET NO. 50-305WISCONSIN PUBLIC SERVICE CORPORATIONWISCONSIN POWER AND LIGHT COMPANYMADISON GAS AND ELECTRIC COMPANYNOTICE OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE

The U.S. Nuclear Regulatory Commission (the Commission) has issued Amendment No. 29 to Facility Operating License No. DPR-43 issued to Wisconsin Public Service Corporation, Wisconsin Power and Light Company, and Madison Gas and Electric Company (the licensee) which revised Technical Specifications for operation of the Kewaunee Nuclear Power Plant located in Kewaunee, Wisconsin. The amendment is effective as of the date of issuance.

The amendment revises the Technical Specifications to require safety injection actuation based on low pressurizer pressure, 2 out of 3 channels.

The application for the amendment complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR Chapter I, which are set forth in the license amendment. Prior public notice of this amendment was not required since the amendment does not involve a significant hazards consideration.

- 2 -

The Commission has determined that the issuance of this amendment will not result in any significant environmental impact and that pursuant to 10 CFR §51.5(d)(4) an environmental impact statement or negative declaration and environmental impact appraisal need not be prepared in connection with issuance of this amendment.

For further details with respect to this action, see (1) the application for amendment dated April 20, 1979, (2) Amendment No. 29 to Facility Operating License No. DPR-43, and (3) the Commission's related Safety Evaluation. All of these items are available for public inspection at the Commission's Public Document Room, 1717 H Street, NW., Washington, D.C. 20555, and at the Kewaunee Public Library, 822 Juneau Street, Kewaunee, Wisconsin 54216. A copy of items (2) and (3) may be obtained upon request addressed to the U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Director, Division of Operating Reactors.

Dated at Bethesda, Maryland, this 27th day of April 1979.

FOR THE NUCLEAR REGULATORY COMMISSION



A. Schwencer, Chief
Operating Reactors Branch #1
Division of Operating Reactors