

446 50-305

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

TO:

NRC

FROM:

Wis. Public Service Corp.
Green Bay, Wis. 54305
E.W. James

DATE OF DOCUMENT

2-10-76

DATE RECEIVED

2-13-76

☒ LETTER☐ NOTORIZED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

1

☒ ORIGINAL
☐ COPY☒ UNCLASSIFIED

DESCRIPTION

Ltr furn info on ECCS evaluation
& info on fuel rod bow for the
Kewaunee Plant.....

ENCLOSURE

PLANT NAME: Kewaunee Plant

Do Not Remove

ACKNOWLEDGED

SAFETY

FOR ACTION/INFORMATION

ENVIRO

DHL 2-19-76

ASSIGNED AD :

BRANCH CHIEF :

PROJECT MANAGER:

LIC. ASST. :

PURPLE (2)
Neighbors
SHEPPARD

ASSIGNED AD :

BRANCH CHIEF :

PROJECT MANAGER :

LIC. ASST. :

INTERNAL DISTRIBUTION

☒ REG FILE		SYSTEMS SAFETY		PLANT SYSTEMS		ENVIRO TECH
☒ NRC PDR		HEINEMAN	☒	TEDESCO		ERNST
☒ I & E (2)		SCHROEDER	☒	BENAROYA		BALLARD
☒ OELD			☒	LAINAS		SPANGLER
☒ GOSSICK & STAFF		ENGINEERING		IPPOLITO		
☒ MIPC		MACCARY				SITE TECH
☒ CASE		KNIGHT		OPERATING REACTORS		CAMMILL
☒ HANAUER		SIHWEIL		STELLO		STEPP
☒ HARLESS		PAWLICKI				HULMAN
				OPERATING TECH		
☒ PROJECT MANAGEMENT		REACTOR SAFETY	☒	EISENHUT		SITE ANALYSIS
☒ BOYD	☒	ROSS		SHAO		VOLLMER
☒ P. COLLINS	☒	NOVAK (3)	☒	BAER		BUNCH
☒ HOUSTON	☒	ROSZTOCZY		SCHWENCER		J. COLLINS
☒ PETERSON		CHECK		GRIMES		KREGER
☒ MELTZ						
☒ HELTEMES		AT & I		SITE SAFETY & ENVIRO		
☒ SKOVHOLT		SALTZMAN		ANALYSIS		
		RUTBERG		DENTON & MULLER		

EXTERNAL DISTRIBUTION

CONTROL NUMBER

☒ LPDR: Kewaunee, Wis.	NATL LAB	BROOKHAVEN NATL LAB
☒ TIC	REG. V-IE	ULRIKSON(ORNL)
☒ NSIC	LA PDR	
☒ ASLB	CONSULTANTS	
☒ ACRS 16 HOLDING/SENT	To L.A.	


2 1446

WISCONSIN PUBLIC SERVICE CORPORATION



P.O. Box 1200, Green Bay, Wisconsin 54305

February 10, 1976



Division of Operating Reactors
Office of Nuclear Reactors Regulation
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. R. A. Purple, Chief
Operating Reactors Branch #1

Gentlemen:

Subject: Docket 50-305
Operating License DPR-43
ECCS Evaluation

On January 26, 1976, we were informed by telephone that the consequences of fuel rod bow are required to be addressed prior to completion of the review of the ECCS evaluation and reanalysis for the Kewaunee Plant. Although three specific ECCS analyses have been provided since issuance of Appendix K to Title 10 CFR Part 50, this was the first request we had received for information regarding rod bow as it specifically applies to the Kewaunee Plant.

The generic issue of rod bow effects has been addressed by Westinghouse in WCAP 8692, non-proprietary and WCAP 8691, proprietary. The analyses provided in these documents are presently being evaluated by the Commission's staff. A review of this analysis has been performed by our engineering personnel. This review indicated that the Kewaunee Plant is enveloped by the analyses provided in these WCAP reports.

Since the above-mentioned Westinghouse generic analyses result in no additional penalties for the Kewaunee Plant, a specific analysis for Kewaunee at this time would not be justified. Specific commitments concerning operating limits or monitoring at this time would also be premature in view of the generic evaluation presently in progress.

During our review of the WCAP analysis, it was noted that:

1. Fuel rod inspections of Westinghouse operating plants have discovered rod bow; however, rod bow has not been observed in the uppermost span of fuel rods (between grids 6 and 7).

February 10, 1976

2. The maximum effect of rod bow is in the 16 x 16 element which results in a penalty of 5.6%. The penalty of 14 x 14 element employed at Kewaunee is 4.25%.

Although we consider any action to reduce the operating margin of the Kewaunee facility premature in view of the generic evaluation presently in progress, we note that an adequate margin exists between the $F_Q \times P_{Rel}$ limits assumed in the safety analyses and the maximum predicted $F_Q \times P_{Rel}$ for CAOC operation as presented in our submittal of January 22, 1976. This margin would be adequate to accommodate the 4.25% worst case penalty of a 14 x 14 element over all fuel element grid spans where rod bow has been observed.

Yours very truly,



E. W. James, Senior Vice-President
Power Supply and Engineering

EWJ/ml