

CATEGORY 1

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9704290044 DOC. DATE: 96/12/31 NOTARIZED: NO DOCKET #
 FACIL: 50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Service 05000305
 AUTH. NAME AUTHOR AFFILIATION
 MARCHI, M.L. Wisconsin Public Service Corp. *See Environment Reports*
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: "Kewaunee Nuclear Power Plant Annual Radioactive Effluent Release Rept, for 960101-1231." W/970423 ltr.

DISTRIBUTION CODE: IE48D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 102
 TITLE: 50.36a(a)(2) Semiannual Effluent Release Reports

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD3-3 LA LAUFER, R	1 1	PD3-3 PD	1 1
INTERNAL:	ACRS	1 1	<u>FILE CENTER 01</u>	1 1
	NRR/DRPM/PERB/A	1 1	RGN3 DRS/RSE	1 1
	RGN3 FILE	1 1		
EXTERNAL:	NRC PDR	1 1		

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 9 ENCL 9



WIBCONSIN PUBLIC SERVICE CORPORATION

600 North Adams • P.O. Box 19002 • Green Bay, WI 54307-9002

April 23, 1997

10 CFR 50.36a(a)(2)

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

JEK
|
|

Ladies/Gentlemen:

Docket 50-305
Operating License DPR-43
Kewaunee Nuclear Power Plant
Radioactive Effluent Release Report January - December, 1996

Enclosed please find a copy of the Kewaunee Nuclear Power Plant Radioactive Effluent Release Report for January through December, 1996. This report is submitted to meet the requirements of Technical Specification 6.9.b.2.

Sincerely,

M L Marchi

M. L. Marchi
Manager - Nuclear Business Group

DFS/jmf

Enc.

000070

cc - US NRC Senior Resident Inspector
US NRC Region III

9704290044 961231
PDR ADOCK 05000305
R PDR



50-305

KEWAUNEE

WPSC

ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT
JAN. 1, 1996 THRU DEC. 31, 1996

Rec'd w/ ltr dtd 4/23/97.....9704290044

- NOTICE -

THE ATTACHED FILES ARE OFFICIAL RECORDS OF THE INFORMATION & RECORDS MANAGEMENT BRANCH. THEY HAVE BEEN CHARGED TO YOU FOR A LIMITED TIME PERIOD AND MUST BE RETURNED TO THE RECORDS & ARCHIVES SERVICES SECTION, T5 C3. PLEASE DO NOT SEND DOCUMENTS CHARGED OUT THROUGH THE MAIL. REMOVAL OF ANY PAGE(S) FROM DOCUMENT FOR REPRODUCTION MUST BE REFERRED TO FILE PERSONNEL.

- NOTICE -

KEWAUNEE NUCLEAR POWER PLANT

**RADIOACTIVE
EFFLUENT RELEASE REPORT
JANUARY - DECEMBER 1996**

**WISCONSIN PUBLIC SERVICE CORPORATION
WISCONSIN POWER & LIGHT COMPANY
MADISON GAS & ELECTRIC COMPANY**

DOCKET 50-305

KEWAUNEE NUCLEAR POWER PLANT

**ANNUAL RADIOACTIVE
EFFLUENT RELEASE REPORT**

January 1 - December 31, 1996

Wisconsin Public Service Corporation
Green Bay, Wisconsin
April 9, 1997

Table of Contents

Section	Description	
0.0	Summary.....	3
1.0	Introduction.....	3
1.1	Effluent Dose	3
2.0	Gaseous Effluents	4
2.1	Lower Limits of Detection (LLD) for Gaseous Effluents	4
2.2	Gaseous Batch Release Statistics.....	6
2.3	Gaseous Effluent Data	6
	Table 2.1 Gaseous Effluents - Summation of all Releases	7
	Table 2.2 Gaseous Effluents - Elevated Releases.....	8
	Table 2.3A Gaseous Release Total	10
	Table 2.3B Gaseous Release Continuous	18
	Table 2.3C Gaseous Release Batch	26
	Table 2.4 Dose From Gaseous Effluents	30
3.0	Liquid Effluents.....	36
3.1	Lower Limits of Detection (LLD) for Liquid Effluents	36
3.2	Liquid Batch Release Statistics	38
3.3	Liquid Effluent Data	38
	Table 3.1 Liquid Effluents - Summation of all Releases.....	39
	Table 3.2A Liquid Effluents - Batch Releases 1st Quarter.....	40
	Table 3.2B Liquid Effluents - Batch Releases 2nd Quarter	42
	Table 3.2C Liquid Effluents - Batch Releases 3rd Quarter	44
	Table 3.2D Liquid Effluents - Batch Releases 4th Quarter	46
	Table 3.3A Liquid Effluents - Continuous Releases 1st Quarter	48
	Table 3.3B Liquid Effluents - Continuous Releases 2nd Quarter	50
	Table 3.3C Liquid Effluents - Continuous Releases 3rd Quarter	52
	Table 3.3D Liquid Effluents - Continuous Releases 4th Quarter	54
	Table 3.4 Dose From Liquid Effluents	56
4.0	Unplanned Releases.....	57
5.0	Meteorological Data	58
6.0	Solid Waste Disposal.....	58
	Table 6.1 Solid Waste and Irradiated Fuel Shipments.....	59
7.0	Program Revisions.....	61
8.0	Reportable Occurrences.....	61
 Appendix A Meteorological Data		

0.0 SUMMARY

During 1996 all solid, liquid, and gaseous radioactive effluents from the Kewaunee Nuclear Plant were well below regulatory limits. For individual effluent streams, the quarterly limit most closely approached was:

<u>GASEOUS:</u>	Ingestion Pathway-Organ	Total Body	
	Quarterly Limit (mRems)	7.5	
	Actual Dose (mRems)	0.0002482	(3 rd Quarter)
	% of Specification	0.00331	
<u>LIQUID:</u>	Ingestion Pathway-Organ	GI-LLI	
	Quarterly Limit (mRems)	5	
	Actual Dose (mRems)	0.01252	(4 th Quarter)
	% of Limit	0.25	
<u>SOLID:</u>	No upper limit for solid radioactive waste applies.		
	Cubic Meters Shipped	18.4 m ³ (650 ft ³)	

1.0 INTRODUCTION

This report is being submitted in accordance with the requirements of Kewaunee Technical Specifications, Section 6.9.b.2 and the Offsite Dose Calculation Manual, Section 3/4.7. It includes data from all effluent releases made from January 1 - December 31, 1996. The report contains summaries of the gaseous and liquid releases made to the environment including the quantity, characterization, time duration and calculated radiation dose at the site boundary resulting from these releases. The report also includes a summation of solid waste disposal, revisions to the Process Control Program and the Offsite Dose Calculation Manual, and addresses the cumulative meteorological data.

1.1 Effluent Dose Limits

Specifications are set to insure that offsite doses are maintained as low as reasonably achievable while still allowing for practical and dependable operation of the Kewaunee Plant.

The Kewaunee Offsite Dose Calculation Manual (ODCM) describes the methodology and parameters used in:

- 1.) The calculation of radioactive liquid and gaseous effluent monitoring instrumentation alarm/trip setpoints.
- 2.) The calculation of radioactive liquid and gaseous concentrations, dose rates and cumulative quarterly and annual doses. The ODCM methodology is acceptable for use in demonstrating compliance with 10 CFR 20.106; 10 CFR 50, Appendix 1; and 40 CFR 190.

2.0 GASEOUS EFFLUENTS

2.1 Lower Limits of Detection (LLD) for Gaseous Effluents

Gaseous radioactive effluents are released in both the continuous mode and the batch mode. The auxiliary building stack is sampled continuously for particulates, halogens and Strontium by an "off-line" sample train. This stack is also grab-sampled daily for gaseous gamma emitters. Batch releases are sampled prior to release for principal gaseous and particulate gamma emitters, halogens and tritium.

The LLD's for gaseous radioanalyses, as listed in Table 4.4 of the Kewaunee ODCM are:

Analysis	LLD ($\mu\text{Ci/ml}$)
Gaseous Gamma Emitters	1.00 E-04
Iodine 131	3.00 E-12
Particulate Gamma Emitters	1.00 E-11
Particulate Gross Alpha	1.00 E-11
Strontium 89, 90	1.00 E-11
Noble Gases, Gross Beta or Gamma	1.00 E-06

The nominal "a priori" LLD values are shown below.

Isotope	a priori LLD ($\mu\text{Ci/ml}$)
---------	------------------------------------

a. Gaseous emissions:

Kr-87	5.61E-08
Kr-88	1.02E-07
Xe-133	6.68E-08
Xe-133m	2.75E-07
Xe-135	2.99E-08
Xe-138	1.13E-07

b. Particulate emissions:

Mn-54	1.11E-13
Fe-59	2.27E-13
Co-58	2.28E-13
Co-60	3.57E-13
Zn-65	1.68E-13
Mo-99	2.73E-13
Cs-134	4.69E-13
Cs-137	1.68E-13
Ce-141	2.08E-13
Ce-144	1.24E-12

c. Other identifiable gamma emitters:

Ar-41	3.97E-10
Kr-85	8.63E-05
Kr-85m	4.62E-08
Kr-89	2.04E-06
Xe-127	4.20E-08
Xe-131m	1.82E-06
Xe-135m	1.90E-08
Xe-137	2.88E-07
I-131	1.32E-13

d. Composite particulate samples:

Sr-89	1 E-14
Sr-90	1 E-14
Gross Alpha	1.00 E-14

These "a priori" LLDs represent the capabilities of the counting systems in use, not an after the fact "a posteriori" limit for a particular measurement.

2.2 Gaseous Batch Release Statistics

The following is a summation of all gaseous batch releases made during 1996.

Number of batch releases.....13

Total time for all batch releases (sec)..... 5.449E+005

Maximum time for a batch release (sec)..... 8.646E+004

Average time for a batch release (sec)..... 4.191E+004

Minimum time for a batch release (sec)..... 4.800E+002

2.3 Gaseous Effluent Data

The following table 2.1 presents a quarterly summation of the total activity released and average release rates of four categories of gaseous effluents. Table 2.2 lists the quarterly sums of individual gaseous radionuclides released by continuous and batch modes. Table 2.3 is essentially the same data, but is presented as monthly summations. Table 2.4 presents the dose limits for gaseous effluents, and the calculated doses this year from gaseous effluents.

Table 2.1
Annual Radioactive Effluent Release Report 1996
Gaseous Effluents - Summation of all Releases

Fission and Activation Gases	1st Quarter	2nd Quarter	3rd Quarter	4th Quarter
Total Activity Released (Ci)	0.000E+000	0.000E+000	3.937E-002	0.000E+000
Average Release Rate (μ Ci/sec)	0.000E+000	0.000E+000	5.007E-003	0.000E+000

Iodines

Total Activity Released (Ci)	0.000E+000	0.000E+000	3.868E-003	0.000E+000
Average Release Rate (μ Ci/sec)	0.000E+000	0.000E+000	4.920E-004	0.000E+000

Particulates

Total Activity Released (Ci)	1.238E-005	4.286E-006	7.905E-006	1.082E-005
Average Release Rate (μ Ci/sec)	1.575E-006	5.451E-007	1.005E-006	1.377E-006
Gross Alpha Released (Ci)	1.276E-007	0.000E+000	9.870E-005	6.930E-007

Tritium

Total Activity Released (Ci)	1.891E+000	1.982E+000	1.080E+001	7.463E+000
Average Release Rate (μ Ci/sec)	2.404E-001	2.521E-001	1.373E+000	9.492E-001

Table 2.2
Annual Radioactive Effluent Release Report 1996
Gaseous Effluents

Nuclides Released (Ci)
Continuous Mode

	1st Quarter	2nd Quarter	3rd Quarter	4th Quarter
Fission Gases				
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Iodines				
I-132	0.000E+000	0.000E+000	3.868E-003	0.000E+000
Total	0.000E+000	0.000E+000	3.868E-003	0.000E+000
Particulates				
Co-58	0.000E+000	1.002E-006	1.190E-006	4.139E-006
Co-60	0.000E+000	0.000E+000	1.065E-006	1.701E-006
Sr-89	1.179E-005	0.000E+000	3.126E-007	9.846E-007
Sr-90	5.884E-007	0.000E+000	1.416E-007	3.853E-007
Sb-125	0.000E+000	0.000E+000	1.377E-006	0.000E+000
Cs-134	0.000E+000	0.000E+000	0.000E+000	1.310E-008
Cs-137	0.000E+000	0.000E+000	0.000E+000	3.600E-006
Total	1.238E-005	1.002E-006	4.085E-006	1.082E-005

Table 2.2(cont)
Annual Radioactive Effluent Release Report 1996
Gaseous Effluents

Nuclides Released (Ci)
Batch Mode

Fission Gases

Ar-41	0.000E+000	0.000E+000	3.288E-002	0.000E+000
Xe-133	0.000E+000	0.000E+000	6.484E-003	0.000E+000
Total	0.000E+000	0.000E+000	3.937E-002	0.000E+000

Iodines

Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000
-------	------------	------------	------------	------------

Particulates

Co-60	0.000E+000	3.284E-006	3.819E-006	0.000E+000
Total	0.000E+000	3.284E-006	3.819E-006	0.000E+000

Table 2.3A
Annual Radioactive Effluent Release Report 1996
1st Quarter Gaseous Release
Total of all Releases

Noble Gases (Curies)

Isotope	January	February	March	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Particulates (Curies)

Isotope	January	February	March	Total
Sr-89	0.000E+000	1.135E-005	4.433E-007	1.179E-005
Sr-90	0.000E+000	5.884E-007	0.000E+000	5.884E-007
Total	0.000E+000	1.194E-005	4.433E-007	1.238E-005

Halogens (Curies)

Isotope	January	February	March	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3A (Con't)
Annual Radioactive Effluent Release Report 1996
1st Quarter Gaseous Release
Total of all Releases

Summary	January	February	March	Total
Total Noble Gases (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Halogens (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Particulate Gross Beta-Gamma Half-Lives > 8 Days (Ci)	0.000E+000	1.194E-005	4.433E-007	1.238E-005
Total Tritium (Ci)	5.229E-001	6.178E-001	7.498E-001	1.891E+000
Total Particulate Gross Alpha (Ci)	7.879E-008	0.000E+000	4.878E-008	1.276E-007

Table 2.3A (Con't)
Annual Radioactive Effluent Release Report 1996
2nd Quarter Gaseous Release
Total of all Releases

Noble Gases (Curies)

Isotope	April	May	June	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Particulates (Curies)

Isotope	April	May	June	Total
Co-58	0.000E+000	0.000E+000	1.002E-006	1.002E-006
Co-60	0.000E+000	3.284E-006	0.000E+000	3.284E-006
Total	0.000E+000	3.284E-006	1.002E-006	4.286E-006

Halogens (Curies)

Isotope	April	May	June	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3A (Con't)
Annual Radioactive Effluent Release Report 1996
2nd Quarter Gaseous Release
Total of all Releases

Summary	April	May	June	Total
Total Noble Gases (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Halogens (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Particulate Gross Beta-Gamma Half-Lives>8 Days (Ci)	0.000E+000	3.284E-006	1.002E-006	4.286E-006
Total Tritium (Ci)	1.001E+000	6.730E-001	3.081E-001	1.982E+000
Total Particulate Gross Alpha (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3A (con't)
Annual Radioactive Effluent Release Report 1996
3rd Quarter Gaseous Release
Total of all Releases

Noble Gases (Curies)

Isotope	July	August	September	Total
Ar-41	0.000E+000	0.000E+000	3.288E-002	3.288E-002
Xe-133	0.000E+000	0.000E+000	6.484E-003	6.484E-003
Total	0.000E+000	0.000E+000	3.937E-002	3.937E-002

Particulates (Curies)

Isotope	July	August	September	Total
Co-58	0.000E+000	0.000E+000	1.190E-006	1.190E-006
Co-60	0.000E+000	0.000E+000	4.884E-006	4.884E-006
Sr-89	0.000E+000	3.126E-007	0.000E+000	3.126E-007
Sr-90	0.000E+000	1.416E-007	0.000E+000	1.416E-007
Sb-125	1.377E-006	0.000E+000	0.000E+000	1.377E-006
Total	1.377E-006	4.542E-007	6.074E-006	7.905E-006

Halogens (Curies)

Isotope	July	August	September	Total
I-132	0.000E+000	0.000E+000	3.868E-003	3.868E-003
Total	0.000E+000	0.000E+000	3.868E-003	3.868E-003

Table 2.3A (Con't)
Annual Radioactive Effluent Release Report 1996
3rd Quarter Gaseous Release
Total of all Releases

Summary	July	August	September	Total
Total Noble Gases (Ci)	0.000E+000	0.000E+000	3.937E-002	3.937E-002
Total Halogens (Ci)	0.000E+000	0.000E+000	3.868E-003	3.868E-003
Total Particulate Gross Beta-Gamma Half-Lives > 8 Days (Ci)	1.377E-006	4.542E-007	6.074E-006	7.905E-006
Total Tritium (Ci)	2.600E-003	3.499E-001	1.044E+001	1.080E+001
Total Particulate Gross Alpha (Ci)	5.660E-008	3.920E-008	9.860E-005	9.870E-005

Table 2.3A (Con't)
Annual Radioactive Effluent Release Report 1996
4th Quarter Gaseous Release
Total of all Releases

Noble Gases (Curies)

Isotope	October	November	December	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Particulates (Curies)

Isotope	October	November	December	Total
Co-58	3.794E-006	3.451E-007	0.000E+000	4.139E-006
Co-60	5.760E-008	1.445E-006	1.978E-007	1.701E-006
Sr-89	9.161E-007	0.000E+000	6.858E-008	9.846E-007
Sr-90	3.542E-007	0.000E+000	3.104E-008	3.853E-007
Cs-134	0.000E+000	1.310E-008	0.000E+000	1.310E-008
Cs-137	0.000E+000	3.600E-006	0.000E+000	3.600E-006
Total	5.122E-006	5.403E-006	2.975E-007	1.082E-005

Halogens (Curies)

Isotope	October	November	December	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3A (Con't)
Annual Radioactive Effluent Release Report 1996
4th Quarter Gaseous Release
Total of all Releases

Summary	October	November	December	<u>Total</u>
Total Noble Gases (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Halogens (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Particulate Gross Beta-Gamma Half-Lives > 8 Days (Ci)	5.122E-006	5.403E-006	2.975E-007	1.082E-005
Total Tritium (Ci)	6.207E+000	1.249E+000	6.919E-003	7.463E+000
Total Particulate Gross Alpha (Ci)	5.390E-007	5.368E-008	1.004E-007	6.930E-007

Table 2.3B
Annual Radioactive Effluent Release Report 1996
1st Quarter Gaseous Release
Continuous Mode Only

Noble Gases (Curies)

Isotope	January	February	March	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Particulates (Curies)

Isotope	January	February	March	Total
Sr-89	0.000E+000	1.135E-005	4.433E-007	1.179E-005
Sr-90	0.000E+000	5.884E-007	0.000E+000	5.884E-007
Total	0.000E+000	1.194E-005	4.433E-007	1.238E-005

Halogens (Curies)

Isotope	January	February	March	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3B (Con't)
Annual Radioactive Effluent Release Report 1996
1st Quarter Gaseous Release
Continuous Mode Only

Summary	January	February	March	<u>Total</u>
Total Noble Gases (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Halogens (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Particulate Gross Beta-Gamma Half-Lives > 8 Days (Ci)	0.000E+000	1.194E-005	4.433E-007	1.238E-005
Total Tritium (Ci)	5.229E-001	6.178E-001	7.498E-001	1.891E+000
Total Particulate Gross Alpha (Ci)	7.879E-008	0.000E+000	4.878E-008	1.276E-007

Table 2.3B (Con't)
Annual Radioactive Effluent Release Report 1996
2nd Quarter Gaseous Release
Continuous Mode Only

Noble Gases (Curies)

Isotope	April	May	June	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Particulates (Curies)

Isotope	April	May	June	Total
Co-58	0.000E+000	0.000E+000	1.002E-006	1.002E-006
Total	0.000E+000	0.000E+000	1.002E-006	1.002E-006

Halogens (Curies)

Isotope	April	May	June	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3B (Con't)
Annual Radioactive Effluent Release Report 1996
2nd Quarter Gaseous Release
Continuous Mode Only

Summary	April	May	June	<u>Total</u>
Total Noble Gases (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Halogens (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Particulate Gross Beta-Gamma Half-Lives>8 Days (Ci)	0.000E+000	0.000E+000	1.002E-006	1.002E-006
Total Tritium (Ci)	1.001E+000	6.730E-001	3.081E-001	1.982E+000
Total Particulate Gross Alpha (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3B (con't)
Annual Radioactive Effluent Release Report 1996
3rd Quarter Gaseous Release
Continuous Mode Only

Noble Gases (Curies)

Isotope	July	August	September	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Particulates (Curies)

Isotope	July	August	September	Total
Co-58	0.000E+000	0.000E+000	1.190E-006	1.190E-006
Co-60	0.000E+000	0.000E+000	1.065E-006	1.065E-006
Sr-89	0.000E+000	3.126E-007	0.000E+000	3.126E-007
Sr-90	0.000E+000	1.416E-007	0.000E+000	1.416E-007
Sb-125	1.377E-006	0.000E+000	0.000E+000	1.377E-006
Total	1.377E-006	4.542E-007	2.255E-006	4.085E-006

Halogens (Curies)

Isotope	July	August	September	Total
I-132	0.000E+000	0.000E+000	3.868E-003	3.868E-003
Total	0.000E+000	0.000E+000	3.868E-003	3.868E-003

Table 2.3B (Con't)
Annual Radioactive Effluent Release Report 1996
3rd Quarter Gaseous Release
Continuous Mode Only

Summary	July	August	September	Total
Total Noble Gases (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Halogens (Ci)	0.000E+000	0.000E+000	3.868E-003	3.868E-003
Total Particulate Gross Beta-Gamma Half-Lives > 8 Days (Ci)	1.377E-006	4.542E-007	2.255E-006	4.085E-006
Total Tritium (Ci)	0.000E+000	3.499E-001	4.773E-001	8.272E-001
Total Particulate Gross Alpha (Ci)	5.660E-008	3.920E-008	0.000E+000	9.579E-008

Table 2.3B (Con't)
Annual Radioactive Effluent Release Report 1996
4th Quarter Gaseous Release
Continuous Mode Only

Noble Gases (Curies)

Isotope	October	November	December	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Particulates (Curies)

Isotope	October	November	December	Total
Co-58	3.794E-006	3.451E-007	0.000E+000	4.139E-006
Co-60	5.760E-008	1.445E-006	1.978E-007	1.701E-006
Sr-89	9.161E-007	0.000E+000	6.858E-008	9.846E-007
Sr-90	3.542E-007	0.000E+000	3.104E-008	3.853E-007
Cs-134	0.000E+000	1.310E-008	0.000E+000	1.310E-008
Cs-137	0.000E+000	3.600E-006	0.000E+000	3.600E-006
Total	5.122E-006	5.403E-006	2.975E-007	1.082E-005

Halogens (Curies)

Isotope	October	November	December	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3B (Con't)
Annual Radioactive Effluent Release Report 1996
4th Quarter Gaseous Release
Continuous Mode Only

Summary	October	November	December	<u>Total</u>
Total Noble Gases (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Halogens (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Particulate Gross Beta-Gamma Half-Lives > 8 Days (Ci)	5.122E-006	5.403E-006	2.975E-007	1.082E-005
Total Tritium (Ci)	6.207E+000	1.249E+000	6.919E-003	7.463E+000
Total Particulate Gross Alpha (Ci)	5.390E-007	5.368E-008	1.004E-007	6.930E-007

Table 2.3C
Annual Radioactive Effluent Release Report 1996
1st Quarter Gaseous Release
Batch Mode Only

Noble Gases (Curies)

Isotope	January	February	March	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Particulates (Curies)

Isotope	January	February	March	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Halogens (Curies)

Isotope	January	February	March	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3C (Con't)
Annual Radioactive Effluent Release Report 1996
1st Quarter Gaseous Release
Batch Mode Only

Summary	January	February	March	<u>Total</u>
Total Noble Gases (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Halogens (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Particulate Gross Beta-Gamma Half-Lives>8 Days (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Tritium (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Particulate Gross Alpha (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3C (Con't)
Annual Radioactive Effluent Release Report 1996
2nd Quarter Gaseous Release
Batch Mode Only

Noble Gases (Curies)

Isotope	April	May	June	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Particulates (Curies)

Isotope	April	May	June	Total
Co-60	0.000E+000	3.284E-006	0.000E+000	3.284E-006
Total	0.000E+000	3.284E-006	0.000E+000	3.284E-006

Halogens (Curies)

Isotope	April	May	June	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3C (Con't)
Annual Radioactive Effluent Release Report 1996
2nd Quarter Gaseous Release
Batch Mode Only

Summary	April	May	June	Total
Total Noble Gases (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Halogens (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Particulate Gross Beta-Gamma Half-Lives>8 Days (Ci)	0.000E+000	3.284E-006	0.000E+000	3.284E-006
Total Tritium (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Particulate Gross Alpha (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3C (con't)
Annual Radioactive Effluent Release Report 1996
3rd Quarter Gaseous Release
Batch Mode Only

Noble Gases (Curies)

Isotope	July	August	September	Total
Ar-41	0.000E+000	0.000E+000	3.288E-002	3.288E-002
Xe-133	0.000E+000	0.000E+000	6.484E-003	6.484E-003
Total	0.000E+000	0.000E+000	3.937E-002	3.937E-002

Particulates (Curies)

Isotope	July	August	September	Total
Co-60	0.000E+000	0.000E+000	3.819E-006	3.819E-006
Total	0.000E+000	0.000E+000	3.819E-006	3.819E-006

Halogens (Curies)

Isotope	July	August	September	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3C (Con't)
Annual Radioactive Effluent Release Report 1996
3rd Quarter Gaseous Release
Batch Mode Only

Summary	July	August	September	<u>Total</u>
Total Noble Gases (Ci)	0.000E+000	0.000E+000	3.937E-002	3.937E-002
Total Halogens (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Particulate Gross Beta-Gamma Half-Lives > 8 Days (Ci)	0.000E+000	0.000E+000	3.819E-006	3.819E-006
Total Tritium (Ci)	2.600E-003	0.000E+000	9.967E+000	9.970E+000
Total Particulate Gross Alpha (Ci)	0.000E+000	0.000E+000	9.860E-005	9.860E-005

Table 2.3C (Con't)
Annual Radioactive Effluent Release Report 1996
4th Quarter Gaseous Release
Batch Mode Only

Noble Gases (Curies)

Isotope	October	November	December	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Particulates (Curies)

Isotope	October	November	December	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Halogens (Curies)

Isotope	October	November	December	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3C (Con't)
Annual Radioactive Effluent Release Report 1996
4th Quarter Gaseous Release
Batch Mode Only

Summary	October	November	December	<u>Total</u>
Total Noble Gases (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Halogens (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Particulate Gross Beta-Gamma Half-Lives > 8 Days (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Tritium (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Particulate Gross Alpha (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.4
Annual Radioactive Effluent Release Report 1996
Dose From Gaseous Effluents

The offsite dose limits from radioactive materials in gaseous effluents are specified in Section 3/4.4 of the Kewaunee ODCM and can be summarized as follows:

Limit	Whole Body Gamma	Skin Beta	Organ
Quarterly	5.0 mRad	10.0 mRad	7.5 mRem
Annual	10.0 mRad	20.0 mRad	15.0 mRem

The total release of gaseous effluents during each quarter of 1996 was within limits. The following offsite doses were calculated using equations 2.7, 2.8, and 2.11 from the Kewaunee ODCM. Calculated offsite doses versus quarterly limits are shown below:

	1st Qtr	2nd Qtr	3rd Qtr	4th Qtr
1. Gamma-Whole Body				
Specification (mRads)	5.000E+000	5.000E+000	5.000E+000	5.000E+000
Actual Dose (mRads)	0.000E+000	0.000E+000	3.516E-005	0.000E+000
% of Specification	0.000E+000	0.000E+000	7.032E-004	0.000E+000
2. Beta-Skin				
Specification (mRads)	1.000E+001	1.000E+001	1.000E+001	1.000E+001
Actual Dose (mRads)	0.000E+000	0.000E+000	1.309E-005	0.000E+000
% of Specification	0.000E+000	0.000E+000	1.309E-004	0.000E+000
3. Ingestion Pathway-Organ				
Specification (mRems)	7.500E+000	7.500E+000	7.500E+000	7.500E+000
Actual Dose (mRems)	4.193E-005	5.460E-005	2.482E-004	1.904E-004
% of Specification	5.591E-004	7.280E-004	3.310E-003	2.539E-003
	TBody	G1-LLI	TBody	Liver

Table 2.4 (Con't)
Annual Radioactive Effluent Release Report 1996
Dose From Gaseous Effluents

In addition, the cumulative annual offsite doses for the period January 1 - December 31, 1996 versus the ODCM annual limits were:

	Annual
1. Gamma-Whole Body	
Specification (mRads)	1.000E+001
Actual Dose (mRads)	3.516E-005
% of Specification	3.516E-004
2. Beta-Skin	
Specification (mRads)	2.000E+001
Actual Dose (mRads)	1.309E-005
% of Specification	6.543E-005
3. Ingestion Pathway-Organ	
Specification (mRems)	1.500E+001
Actual Dose (mRems)	5.327E-004
% of Specification	3.552E-003
Liver	

3.0 LIQUID EFFLUENTS

3.1 Lower Limits of Detection (LLD) for Liquid Effluents

Liquid radioactive effluents are released as both batch releases and continuous releases. Each batch is sampled prior to release and analyzed for gamma emitters and tritium. A fraction of each sample is retained for a monthly proportional composite which is then analyzed for Gross Alpha, Strontium 89, Strontium 90 and Iron 55.

The LLD's for liquid batch release radioanalyses, as listed in Table 4.3 of the Kewaunee Nuclear Power Plant Off-Site Dose Calculation Manual, are:

<u>Analysis</u>	<u>LLD (μCi/ml)</u>
Principal Gamma Emitters	1.00 E-06
Iodine 131	1.00 E-06
Tritium	1.00 E-05
Gross Alpha	5.00 E-07
Strontium 89, 90	5.00 E-08
Iron 55	1.00 E-06

The actual obtained "a priori" LLD values for batch releases are shown below.

Isotope	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	Average a priori LLD (μCi/ml)
Mn-54	8.27E-10	8.27E-10	8.27E-10	6.51E-10	7.83E-10
Fe-59	1.79E-10	1.79E-09	1.79E-09	1.45E-09	1.30E-09
Co-58	1.41E-07	8.14E-10	8.14E-10	1.72E-07	7.87E-08
Co-60	1.17E-07	1.30E-07	1.06E-09	1.22E-07	9.25E-08
Zn-65	2.02E-09	2.02E-09	2.02E-09	1.63E-09	1.92E-09
Mo-99	1.32E-06 [†]	5.90E-09	5.90E-09	4.60E-09	3.34E-07
Cs-134	6.64E-10	6.64E-10	6.64E-10	5.08E-10	6.25E-10
Cs-137	8.16E-08	2.21E-07	1.37E-07	6.29E-10	1.10E-07
Ce-141	5.85E-08	1.66E-07	5.29E-10	9.19E-08	7.92E-08
Ce-144	3.88E-07	4.20E-07	2.42E-07	2.64E-07	3.29E-07
I-131	5.30E-10	5.30E-10	5.30E-10	3.91E-08	1.02E-08
H-3	3.29E-06	4.03E-06	3.59E-06	3.38E-06	3.57E-06
Sr-89	8.83E-09	1.50E-08	9.03E-09	1.26E-08	1.14E-08
Sr-90	3.91E-09	6.23E-09	5.10E-09	3.08E-08	1.15E-08
Gross Alpha	1.16E-08	8.60E-09	9.60E-09	1.20E-08	1.04E-08
Fe-55	4.24E-07	6.87E-07	7.10E-07	6.63E-07	6.21E-07

[†] The 1st quarter Mo-99 LLD is slightly above the ODCM listed LLD. A review of the daily background (LLD) samples around this period indicates routine LLD's are less than the ODCM listed LLD. This slightly high LLD is an anomaly.

Continuous liquid releases are grab sampled weekly and analyzed for principal gamma emitters. A fraction of each weekly sample is retained for a monthly proportional composite which is then analyzed for Tritium, Gross Alpha, Strontium 89, Strontium 90 and Iron 55.

The LLD's for liquid continuous release radioanalyses, as listed in Table 4.3 of the Kewaunee Nuclear Power Plant Off-Site Dose Calculation Manual, are:

Analysis	LLD ($\mu\text{Ci/ml}$)
Principal Gamma Emitters	5.00 E-07
Iodine 131	1.00 E-06
Tritium	1.00 E-05
Gross Alpha	5.00 E-07
Strontium 89, 90	5.00 E-08
Iron 55	1.00 E-06

The actual obtained "a priori" LLD values for continuous releases are shown below.

Isotope	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	Average a priori LLD ($\mu\text{Ci/ml}$)
Mn-54	1.38E-08	1.95E-08	1.95E-08	3.52E-08	2.20E-08
Fe-59	8.39E-08	2.99E-08	2.99E-10	3.42E-08	3.71E-08
Co-58	2.35E-08	4.48E-08	1.36E-10	3.84E-08	2.67E-08
Co-60	3.54E-08	2.51E-08	8.44E-10	2.04E-08	2.04E-08
Zn-65	5.82E-08	3.36E-10	3.36E-08	1.89E-08	2.78E-08
Mo-99	2.38E-07	9.85E-08	4.63E-07	2.43E-07	2.61E-07
Cs-134	4.08E-08	1.11E-10	3.27E-07	3.38E-08	1.00E-07
Cs-137	4.86E-08	4.43E-08	6.20E-08	1.05E-08	4.14E-08
Ce-141	5.22E-08	2.88E-08	2.50E-08	2.05E-08	3.16E-08
Ce-144	1.20E-07	2.43E-07	3.10E-07	6.62E-08	1.85E-07
I-131	1.25E-08	2.52E-08	2.00E-08	2.16E-08	1.98E-08
H-3	3.29E-06	4.03E-06	3.59E-06	3.38E-06	3.57E-06
Sr-89	8.20E-09	1.37E-08	1.04E-08	1.07E-08	1.07E-08
Sr-90	4.61E-09	5.70E-09	5.73E-09	6.35E-09	5.60E-09
Gross Alpha	9.58E-09	6.87E-09	8.42E-09	8.20E-09	8.27E-09
Fe-55	4.19E-07	6.27E-07	6.97E-07	6.75E-07	6.04E-07

3.2 Liquid Batch Release Statistics

The following is a summation of all liquid batch releases made during 1996.

<u>Release Type</u>	<u>Number</u>	<u>Gallons Released</u>
A SGBT Monitor Tk.	11	104570.0
B SGBT Monitor Tk.	9	76793.0
A CVC Monitor	19	124285.0
B CVC Monitor	15	97930.0
miscellaneous	16	34228.0
Both WCTs	88	160365.0

Total time for all batch releases 28246.0 Min.

Maximum time for a batch release 570.0 Min.

Minimum time for a batch release 27.0 Min.

Average time for a batch release 178.8 Min.

3.3 Liquid Effluent Data

The following Table 3.1 presents a quarterly summation of the total activity released and average concentration for all liquid effluents. It also presents the gross alpha activity released, volume of waste released and volume of dilution water used. Tables 3.2 and 3.3 are monthly summations of the same information in Table 3.1. Table 3.2 contains the quantity of the individual isotopes released to the unrestricted area for batch releases. Table 3.3 presents a monthly summation of gross radioactivity, tritium, gross alpha and isotopic activity for the secondary blowdown and leakage releases. It also presents the monthly total volume for these releases and dilution volumes. Table 3.4 presents the doses from liquid effluents for each quarter and the calculated doses this year from liquid effluents.

TABLE 3.1
Annual Radioactive Effluent Release Report 1996
Liquid Effluents - Summation of all Releases

	1st Qtr	2nd Qtr	3rd Qtr	4th Qtr
Fission and Activation Products				
Total Release Excluding H3 and Dissolved Gases (Ci)	1.492E-002	5.115E-003	1.870E-002	1.931E-002
Average Concentration (µCi/ml)	1.075E-010	2.812E-011	9.258E-011	8.366E-010
Tritium				
Total Release (Ci)	6.823E+001	1.711E+002	6.789E+001	6.096E+000
Average Concentration (µCi/ml)	4.917E-007	9.407E-007	3.361E-007	2.642E-007
% of Tech. Spec. Limit(3.0E-3 µCi/ml)	1.639E-002	3.136E-002	1.120E-002	8.805E-003
Dissolved Gases				
Total Release (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Average Concentration (µCi/ml)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
% of Tech. Spec. Limit(2.0E-4 µCi/ml)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Gross Alpha Activity				
Total Release (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Volume of Waste Released				
Batch (liters)	2.889E+005	4.785E+005	8.877E+005	6.092E+005
Continuous (liters)	3.156E+007	3.294E+007	3.167E+007	2.582E+007
Total (liters)	3.185E+007	3.342E+007	3.256E+007	2.643E+007
Volume of Dilution Water				
Batch (liters)	3.114E+009	6.667E+009	1.224E+010	2.847E+009
Continuous (liters)	1.356E+011	1.752E+011	1.897E+011	2.023E+010
Total (liters)	1.388E+011	1.819E+011	2.020E+011	2.308E+010

TABLE 3.2A
Annual Radioactive Effluent Release Report 1996
Liquid Effluents - Batch Releases

	January	February	March	Total
Gross Radioactivity				
Total Release Excluding H3 and Dissolved Gases (Ci)				
	4.146E-003	6.612E-003	3.957E-003	1.472E-002
Avg. Conc. (µCi/ml)				
	8.400E-009	4.019E-009	4.058E-009	
Tritium				
Total Release (Ci)				
	4.189E+000	6.030E+001	3.738E+000	6.823E+001
Avg. Conc. (µCi/ml)				
	8.487E-006	3.665E-005	3.833E-006	
Dissolved Gases				
Total Release (Ci)				
	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (µCi/ml)				
	0.000E+000	0.000E+000	0.000E+000	
Gross Alpha Activity				
Total Release (Ci)				
	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (µCi/ml)				
	0.000E+000	0.000E+000	0.000E+000	
Volume of Waste Released				
(liters)	5.150E+004	1.739E+005	6.350E+004	2.889E+005
Volume of Dilution Water				
(liters)	4.936E+008	1.645E+009	9.751E+008	3.114E+009

TABLE 3.2A (Con't)
Annual Radioactive Effluent Release Report 1996
Liquid Effluents - Batch Releases

Isotope (Ci)	January	February	March	Total
H-3	4.189E+000	6.030E+001	3.738E+000	6.823E+001
Fe-55	1.442E-003	5.912E-006	2.667E-003	4.115E-003
Co-57	0.000E+000	4.507E-005	0.000E+000	4.507E-005
Co-58	4.188E-004	1.787E-003	5.481E-005	2.261E-003
Co-60	2.011E-004	2.446E-004	4.554E-004	9.011E-004
Sr-90	0.000E+000	0.000E+000	4.509E-007	4.509E-007
Ag-110m	2.428E-004	3.337E-003	7.796E-004	4.359E-003
Sb-124	1.085E-004	0.000E+000	0.000E+000	1.085E-004
Sb-125	1.688E-003	9.920E-004	0.000E+000	2.680E-003
Cs-137	4.493E-005	2.004E-004	0.000E+000	2.454E-004
Total	4.193E+000	6.031E+001	3.742E+000	6.824E+001

TABLE 3.2B
Annual Radioactive Effluent Release Report 1996
Liquid Effluents - Batch Releases

	April	May	June	<u>Total</u>
Gross Radioactivity				
Total Release Excluding H3 and Dissolved Gases (Ci)				
	3.189E-003	9.975E-004	4.001E-004	4.586E-003
Avg. Conc. (μCi/ml)				
	1.309E-009	3.945E-010	2.351E-010	
Tritium				
Total Release (Ci)				
	1.119E+002	4.200E+001	1.727E+001	1.711E+002
Avg. Conc. (μCi/ml)				
	4.591E-005	1.661E-005	1.015E-005	
Dissolved Gases				
Total Release (Ci)				
	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)				
	0.000E+000	0.000E+000	0.000E+000	
Gross Alpha Activity				
Total Release (Ci)				
	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)				
	0.000E+000	0.000E+000	0.000E+000	
Volume of Waste Released				
(liters)	2.071E+005	1.641E+005	1.074E+005	4.785E+005
Volume of Dilution Water				
(liters)	2.436E+009	2.529E+009	1.702E+009	6.667E+009

TABLE 3.2B (Con't)
Annual Radioactive Effluent Release Report 1996
Liquid Effluents - Batch Releases

Isotope (Ci)	April	May	June	Total
H-3	1.119E+002	4.200E+001	1.727E+001	1.711E+002
Fe-55	2.278E-003	7.218E-004	2.684E-004	3.268E-003
Co-58	4.161E-004	6.591E-005	4.898E-005	5.310E-004
Co-60	2.884E-004	8.702E-005	4.604E-005	4.215E-004
Ag-110m	2.061E-004	1.227E-004	3.668E-005	3.655E-004
Total	1.119E+002	4.200E+001	1.727E+001	1.711E+002

TABLE 3.2C
Annual Radioactive Effluent Release Report 1996
Liquid Effluents - Batch Releases

	July	August	September	Total
Gross Radioactivity				
Total Release Excluding H3 and Dissolved Gases (Ci)				
	9.302E-004	3.487E-004	1.645E-002	1.773E-002
Avg. Conc. (μCi/ml)				
	4.397E-010	6.592E-011	3.406E-009	
Tritium				
Total Release (Ci)				
	2.064E+001	3.622E+001	1.103E+001	6.789E+001
Avg. Conc. (μCi/ml)				
	9.758E-006	6.847E-006	2.284E-006	
Dissolved Gases				
Total Release (Ci)				
	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)				
	0.000E+000	0.000E+000	0.000E+000	
Gross Alpha Activity				
Total Release (Ci)				
	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)				
	0.000E+000	0.000E+000	0.000E+000	
Volume of Waste Released				
(liters)	1.237E+005	2.945E+005	4.696E+005	8.877E+005
Volume of Dilution Water				
(liters)	2.115E+009	5.290E+009	4.829E+009	1.224E+010

TABLE 3.2C (Con't)
Annual Radioactive Effluent Release Report 1996
Liquid Effluents - Batch Releases

Isotope (Ci)	July	August	September	Total
H-3	2.064E+001	3.622E+001	1.103E+001	6.789E+001
Fe-55	8.533E-004	1.826E-004	1.221E-002	1.325E-002
Co-58	1.397E-005	3.086E-005	5.693E-005	1.018E-004
Co-60	1.744E-005	9.516E-005	4.007E-004	5.133E-004
Nb-95	0.000E+000	0.000E+000	8.858E-006	8.858E-006
Ag-110m	4.551E-005	4.014E-005	3.771E-003	3.857E-003
Total	2.064E+001	3.622E+001	1.105E+001	6.791E+001

TABLE 3.2D
Annual Radioactive Effluent Release Report 1996
Liquid Effluents - Batch Releases

	October	November	December	Total
Gross Radioactivity				
Total Release Excluding H3 and Dissolved Gases (Ci)				
	1.700E-002	2.032E-003	2.711E-004	1.931E-002
Avg. Conc. (μCi/ml)				
	6.708E-009	8.054E-009	4.507E-009	
Tritium				
Total Release (Ci)				
	5.703E+000	3.928E-001	3.108E-004	6.096E+000
Avg. Conc. (μCi/ml)				
	2.250E-006	1.557E-006	5.167E-009	
Dissolved Gases				
Total Release (Ci)				
	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)				
	0.000E+000	0.000E+000	0.000E+000	
Gross Alpha Activity				
Total Release (Ci)				
	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)				
	0.000E+000	0.000E+000	0.000E+000	
Volume of Waste Released				
(liters)	4.143E+005	1.250E+005	6.984E+004	6.092E+005
Volume of Dilution Water				
(liters)	2.535E+009	2.523E+008	6.015E+007	2.847E+009

TABLE 3.2D (Con't)
Annual Radioactive Effluent Release Report 1996
Liquid Effluents - Batch Releases

Isotope (Ci)	October	November	December	Total
H-3	5.703E+000	3.928E-001	3.108E-004	6.096E+000
Cr-51	2.493E-003	0.000E+000	0.000E+000	2.493E-003
Mn-54	4.729E-005	1.560E-006	3.655E-006	5.250E-005
Fe-55	3.729E-003	6.624E-004	1.327E-004	4.524E-003
Mn-56	1.286E-006	0.000E+000	0.000E+000	1.286E-006
Co-58	5.386E-003	4.410E-004	7.649E-005	5.903E-003
Fe-59	3.489E-004	0.000E+000	0.000E+000	3.489E-004
Co-60	1.025E-003	1.664E-004	5.827E-005	1.250E-003
Nb-95	2.493E-004	0.000E+000	0.000E+000	2.493E-004
Zr-95	9.321E-005	0.000E+000	0.000E+000	9.321E-005
Ag-110m	1.326E-003	3.084E-004	0.000E+000	1.634E-003
Sn-113	3.200E-005	0.000E+000	0.000E+000	3.200E-005
Sb-124	5.412E-004	1.176E-004	0.000E+000	6.587E-004
Sb-125	1.442E-003	3.346E-004	0.000E+000	1.777E-003
Cs-137	2.894E-004	0.000E+000	0.000E+000	2.894E-004
Total	5.720E+000	3.948E-001	5.819E-004	6.115E+000

TABLE 3.3A
Annual Radioactive Effluent Release Report 1996
Liquid Effluents - Continuous Releases

	January	February	March	Total
Gross Radioactivity				
Total Release Excluding H3 and Dissolved Gases (Ci)				
	1.273E-004	5.588E-005	1.874E-005	2.019E-004
Avg. Conc. (μCi/ml)				
	3.396E-012	1.435E-012	3.164E-013	
Tritium				
Total Release (Ci)				
	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)				
	0.000E+000	0.000E+000	0.000E+000	
Dissolved Gases				
Total Release (Ci)				
	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)				
	0.000E+000	0.000E+000	0.000E+000	
Gross Alpha Activity				
Total Release (Ci)				
	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)				
	0.000E+000	0.000E+000	0.000E+000	
Volume of Waste Released				
(liters)	9.329E+006	9.896E+006	1.234E+007	3.156E+007
Volume of Dilution Water				
(liters)	3.748E+010	3.893E+010	5.923E+010	1.356E+011

TABLE 3.3A (Con't)
Annual Radioactive Effluent Release Report 1996
Liquid Effluents - Continuous Releases

Isotope (Ci)	January	February	March	Total
Co-60	0.000E+000	0.000E+000	1.874E-005	1.874E-005
Sr-90	1.273E-004	0.000E+000	0.000E+000	1.273E-004
I-133	0.000E+000	5.588E-005	0.000E+000	5.588E-005
Total	1.273E-004	5.588E-005	1.874E-005	2.019E-004

TABLE 3.3B
Annual Radioactive Effluent Release Report 1996
Liquid Effluents - Continuous Releases

	April	May	June	Total
Gross Radioactivity				
Total Release Excluding H3 and Dissolved Gases (Ci)				
	7.761E-006	3.244E-004	1.962E-004	5.284E-004
Avg. Conc. (µCi/ml)				
	1.833E-013	4.800E-012	3.003E-012	
Tritium				
Total Release (Ci)				
	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (µCi/ml)				
	0.000E+000	0.000E+000	0.000E+000	
Dissolved Gases				
Total Release (Ci)				
	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (µCi/ml)				
	0.000E+000	0.000E+000	0.000E+000	
Gross Alpha Activity				
Total Release (Ci)				
	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (µCi/ml)				
	0.000E+000	0.000E+000	0.000E+000	
Volume of Waste Released				
(liters)	1.065E+007	1.014E+007	1.216E+007	3.294E+007
Volume of Dilution Water				
(liters)	4.234E+010	6.759E+010	6.532E+010	1.752E+011

TABLE 3.3B (Con't)
Annual Radioactive Effluent Release Report 1996
Liquid Effluents - Continuons Releases

Isotope (Ci)	April	May	June	Total
Co-60	3.707E-006	1.483E-004	0.000E+000	1.520E-004
Sr-90	0.000E+000	0.000E+000	3.533E-005	3.533E-005
I-133	4.055E-006	1.762E-004	1.608E-004	3.411E-004
Total	7.761E-006	3.244E-004	1.962E-004	5.284E-004

TABLE 3.3C
Annual Radioactive Effluent Release Report 1996
Liquid Effluents - Continuous Releases

	July	August	September	Total
Gross Radioactivity				
Total Release Excluding H3 and Dissolved Gases (Ci)				
	1.935E-004	3.691E-004	4.110E-004	9.735E-004
Avg. Conc. (μCi/ml)				
	2.862E-012	5.460E-012	7.534E-012	
Tritium				
Total Release (Ci)				
	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)				
	0.000E+000	0.000E+000	0.000E+000	
Dissolved Gases				
Total Release (Ci)				
	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)				
	0.000E+000	0.000E+000	0.000E+000	
Gross Alpha Activity				
Total Release (Ci)				
	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)				
	0.000E+000	0.000E+000	0.000E+000	
Volume of Waste Released				
(liters)	1.065E+007	1.057E+007	1.045E+007	3.167E+007
Volume of Dilution Water				
(liters)	6.759E+010	6.759E+010	5.456E+010	1.897E+011

TABLE 3.3C (Con't)
Annual Radioactive Effluent Release Report 1996
Liquid Effluents - Continuous Releases

Isotope (Ci)	July	August	September	Total
Cr-51	0.000E+000	0.000E+000	3.514E-004	3.514E-004
Co-58	0.000E+000	0.000E+000	4.990E-007	4.990E-007
Co-60	0.000E+000	9.342E-005	5.907E-005	1.525E-004
I-133	1.935E-004	2.757E-004	0.000E+000	4.691E-004
Total	1.935E-004	3.691E-004	4.110E-004	9.735E-004

TABLE 3.3D
Annual Radioactive Effluent Release Report 1996
Liquid Effluents - Continuous Releases

	October	November	December	Total
Gross Radioactivity				
Total Release Excluding H3 and Dissolved Gases (Ci)				
	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)				
	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Tritium				
Total Release (Ci)				
	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)				
	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Dissolved Gases				
Total Release (Ci)				
	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)				
	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Gross Alpha Activity				
Total Release (Ci)				
	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)				
	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Volume of Waste Released				
(liters)	7.001E+006	1.200E+007	6.816E+006	2.582E+007
Volume of Dilution Water				
(liters)	1.694E+010	2.204E+009	1.087E+009	2.023E+010

TABLE 3.3D (Con't)
Annual Radioactive Effluent Release Report 1996
Liquid Effluents - Continuous Releases

Isotope (Ci)	October	November	December	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 3.4
Annual Radioactive Effluent Report 1996
Dose From Liquid Effluents

The dose to a member of the public from total liquid radioactive releases for each quarter was below the ODCM limits of 1.5 mrems to the total body and less than or equal to 5 mrems to any organ. Additionally, the dose to a member of the public from total liquid radioactive releases for the year was below the ODCM limits of 3 mrems to the total body and less than or equal to 10 mrems to any organ.

Instantaneous release concentrations are limited by the individual radionuclide concentrations established in 10 CFR 20, Appendix B, for unrestricted areas. During the report period, none of the isotopes released exceed the concentrations specified in Appendix B. The following offsite doses were calculated using equation 1.5 from the Kewaunee ODCM.

Organ 1st Qtr Dose	Dose Total mRem	Quarterly Limit mRem	Percent of Limit
Total Body	2.275E-003	1.5	0.15
Bone	2.107E-003	5.0	0.04
Liver	3.258E-003	5.0	0.07
Thyroid	4.020E-004	5.0	0.01
Kidney	1.358E-003	5.0	0.03
Lung	7.360E-004	5.0	0.01
GI-LLI	6.734E-004	5.0	0.01

Organ 2nd Qtr Dose	Dose Total mRem	Quarterly Limit mRem	Percent of Limit
Total Body	1.028E-003	1.5	0.07
Bone	3.695E-005	5.0	0.00
Liver	1.045E-003	5.0	0.02
Thyroid	1.018E-003	5.0	0.02
Kidney	1.018E-003	5.0	0.02
Lung	1.032E-003	5.0	0.02
GI-LLI	1.067E-003	5.0	0.02

Table 3.4 (Con't)
Annual Radioactive Effluent Report 1996
Dose From Liquid Effluents

Organ 3rd Qtr Dose	Dose Total mRem	Quarterly Limit mRem	Percent of Limit
Total Body	2.821E-004	1.5	0.02
Bone	1.375E-004	5.0	0.00
Liver	3.526E-004	5.0	0.01
Thyroid	2.555E-004	5.0	0.01
Kidney	2.556E-004	5.0	0.01
Lung	3.085E-004	5.0	0.01
GI-LLI	6.595E-004	5.0	0.01

Organ 4th Qtr Dose	Dose Total mRem	Quarterly Limit mRem	Percent of Limit
Total Body	2.486E-003	1.5	0.17
Bone	3.024E-003	5.0	0.06
Liver	3.884E-003	5.0	0.08
Thyroid	4.524E-005	5.0	0.00
Kidney	1.181E-003	5.0	0.02
Lung	6.493E-004	5.0	0.01
GI-LLI	1.252E-002	5.0	0.25

Calculated Dose This Year

Organ	Dose Total mRem	Quarterly Limit mRem	Percent of Limit
Total Body	6.071E-003	3.0	0.20
Bone	5.305E-003	10.0	0.05
Liver	8.539E-003	10.0	0.09
Thyroid	1.721E-003	10.0	0.02
Kidney	3.813E-003	10.0	0.04
Lung	2.726E-003	10.0	0.03
GI-LLI	1.492E-002	10.0	0.15

4.0 UNPLANNED RELEASES

No unplanned releases were made from the Kewaunee Plant during the report period.

The January-June 1991 Semi-Annual Effluent Release Report described an unplanned release which occurred on April 25, 1991. Offsite doses attributed to this release were well below the established ODCM (Technical Specifications at the time) limits.

As corrective action, WPSC stated in this report that valves WG-301 and WG-302 were scheduled to be replaced during 1992. Also, a new vent line was added between valves WG-300 and WG-301 to allow local leak rate testing with the Waste Gas Decay Tanks isolated. The valves were to be replaced with like-for-like replacements. However, after receipt inspection, the replacement valves failed to pass the seat leakage tests. WPSC is continuing to evaluate options associated with these valves and will continue to provide status updates in the Effluent Release Reports until resolution of this incident and completion of the corrective actions. A plant design change request, DCR-2349, was issued to address this concern.

5.0 METEOROLOGICAL DATA

Meteorological data for 1996 is retained on file at the Kewaunee Nuclear Power Plant. The data on file includes a continuous strip chart recording and a 15-minute interval listing of wind speed, wind direction and atmospheric stability. This is more conservative than the requirements of ODCM Section 3/4.7. See Appendix A for missing meteorological data and the joint frequency distribution tables.

6.0 SOLID WASTE DISPOSAL

Table 6.1 is a summation of solid wastes shipped during 1996. Presented are the types of wastes, major nuclide composition, disposition of the wastes and shipping containers used.

The containers utilized at Kewaunee Nuclear Power Plant have the following volumes:

High Integrity Container (HIC)	158 ft ³
LSA Box (B-25)	98 ft ³
Compactor Boxes	50 ft ³
DOT-17H Drum	7.5 ft ³

A composite sample from the 1993 dewatered resin shipments was analyzed by a contractor for transuranic nuclides. The results showed an average transuranic concentration of 4.24 E-2 nanocuries/gram, well within the disposal site limit of 10 nanocuries/gram.

Table 6.1 contains the radionuclide content (curies) and percent abundance for each type of waste.

Table 6.1
Annual Radioactive Effluent Report 1996
Solid Waste and Irradiated Fuel Shipments

Isotopes denoted by an asterisk (*) in Table 6.1 are correlated values.

A. Solid Waste Shipped Off-Site for Burial or Disposal
 (Not Irradiated Fuel - m³ is actual waste volume not burial volume)

1. Type of Waste	Unit	Quantity
a. Dewatered resin	m ³	None
Container: HIC	Ci	None
b. Dewatered filter media	m ³	None
Container: HIC	Ci	None
c. DAW (Compactible)	m ³	1.84E+01
Container: Compactor Box	Ci	1.83E-01
d. DAW (Non-Compactible)	m ³	None
Container: Compactor Box	Ci	None

Average Transuranics shipped (all shipments): 0.00E+00 nCi/g

2. Estimate of Major Nuclide by Composition
 (By Type of Waste)

	%	Ci
a. Dewatered resin	None	None
b. Dewatered filter media	None	None
c. DAW (Compactible)	100%	1.83E-01
Mn-54	1.61E+00	2.94E-03
Co-58	2.58E+00	4.72E-03
Co-60	4.79E+01	8.76E-02
Zr-95	8.97E-01	1.64E-03
Nb-95	7.33E-01	1.34E-03
Cs-137	1.74E+01	3.18E-02
Sb-125	4.61E+00	8.43E-03
Sn-113	3.03E-01	5.54E-04
Sr-90	2.40E+01	4.38E-02
d. DAW (Non-Compactible)	None	None

3. Solid Waste Disposition

a.	Date of Shipment	Mode of Transportation	Destination
	03/21/96	CNSI Van	Barnwell, SC

B. Irradiated Fuel Shipments

No irradiated fuel shipments were made from the Kewaunee Nuclear Power Plant during the first six months of 1996.

7.0 **PROGRAM REVISIONS**

In accordance with Technical Specifications 6.18.b.3 and 6.19.a, the revisions to the Process Control Program, Offsite Dose Calculation Manual and radioactive waste treatment systems are listed below.

7.1 Offsite Dose Calculation Manual

The Offsite Dose Calculation Manual (ODCM) has not been revised during this report period.

7.2 Major Changes to the Radioactive Liquid, Gaseous and Solid Waste Treatment Systems

Major changes to the radioactive liquid, gaseous or solid waste systems are submitted in the annual Updated Final Safety Analysis Report consistent with Technical Specification 6.19.

8.0 **REPORTABLE OCCURRENCES**

None.

Appendix A

Kewaunee Nuclear Power Plant

1996 Meteorological Data

Missing Meteorological Data

First Quarter:	31	Hours
Second Quarter:	43.25	Hours
Third Quarter:	31.5	Hours
Fourth Quarter:	95.25	Hours

Kewaunee Nuclear Power Plant Meteorological Data
January 1996 to March 1996
Wind Speed Hourly Average vs. Direction

Stability Class A

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0	0	6	21	10	13	50
NNE	0	0	1	12	37	34	0	84
NE	0	0	10	37	6	1	4	58
ENE	0	0	4	14	5	1	6	30
E	0	2	9	8	11	1	0	31
ESE	0	1	4	2	2	1	0	10
SE	0	0	11	6	8	3	1	29
SSE	0	0	3	8	11	6	7	35
S	0	2	4	30	33	3	0	72
SSW	0	0	9	11	4	1	0	25
SW	0	1	2	5	7	0	0	15
WSW	0	0	4	12	19	10	0	45
W	15	1	4	17	32	18	1	88
WNW	6	0	3	6	14	9	0	38
NW	5	0	2	6	18	5	0	36
NNW	0	0	1	11	21	7	0	40
TOTAL	26	7	71	191	249	110	32	686

Kewaunee Nuclear Power Plant Meteorological Data
 January 1996 to March 1996
 Wind Speed Hourly Average vs. Direction

Stability Class B

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0	0	0	15	4	3	22
NNE	0	0	1	3	1	1	0	6
NE	0	0	3	2	1	0	0	6
ENE	0	1	2	2	0	0	1	6
E	0	0	3	0	2	0	0	5
ESE	0	0	5	0	1	2	0	8
SE	0	0	0	1	1	0	0	2
SSE	0	0	0	1	0	0	2	3
S	0	0	1	8	6	1	0	16
SSW	0	0	3	5	0	0	0	8
SW	0	0	2	1	2	1	0	6
WSW	4	0	1	5	4	1	0	15
W	8	0	1	3	3	8	0	23
WNW	3	0	0	2	1	3	2	11
NW	0	0	1	2	6	1	0	10
NNW	0	0	1	4	9	0	0	14
TOTAL	15	1	24	39	52	22	8	161

Kewaunee Nuclear Power Plant Meteorological Data
 January 1996 to March 1996
 Wind Speed Hourly Average vs. Direction

Stability Class C

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0	0	5	10	6	1	22
NNE	0	0	0	3	1	0	0	4
NE	0	2	2	0	0	0	0	4
ENE	0	0	0	0	0	0	1	1
E	0	0	1	3	2	0	0	6
ESE	0	0	1	0	0	0	0	1
SE	0	1	1	0	0	0	0	2
SSE	0	0	0	2	0	0	1	3
S	0	0	3	5	6	0	0	14
SSW	0	0	2	2	1	0	0	5
SW	0	0	1	4	7	0	0	12
WSW	1	0	4	4	4	1	0	14
W	4	0	0	2	5	1	0	12
WNW	2	0	0	7	1	0	0	10
NW	0	0	1	0	6	2	0	9
NNW	0	0	1	1	9	6	0	17
TOTAL	7	3	17	38	52	16	3	136

Kewaunee Nuclear Power Plant Meteorological Data
January 1996 to March 1996
Wind Speed Hourly Average vs. Direction

Stability Class D

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0	0	7	13	0	0	20
NNE	0	2	3	6	5	1	0	17
NE	0	2	3	2	3	0	0	10
ENE	0	0	3	1	2	0	0	6
E	0	0	2	5	0	1	0	8
ESE	0	0	2	4	2	0	0	8
SE	0	0	5	0	0	1	0	6
SSE	0	0	1	2	5	0	0	8
S	0	1	29	28	20	0	0	78
SSW	0	3	21	12	3	1	0	40
SW	0	3	4	11	10	0	0	28
WSW	2	2	6	14	13	3	0	40
W	13	5	5	13	19	14	2	71
WNW	1	0	5	5	4	7	0	22
NW	0	3	6	7	24	4	0	44
NNW	0	0	7	11	14	0	1	33
TOTAL	16	21	102	128	137	32	3	439

Kewaunee Nuclear Power Plant Meteorological Data
 January 1996 to March 1996
 Wind Speed Hourly Average vs. Direction

Stability Class E

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0	0	6	0	0	0	6
NNE	0	1	1	2	0	0	0	4
NE	0	0	3	1	0	0	0	4
ENE	0	1	1	4	2	0	0	8
E	0	0	3	3	0	0	0	6
ESE	0	1	5	1	1	0	0	8
SE	0	1	3	1	1	0	0	6
SSE	0	0	5	5	1	1	0	12
S	0	2	14	7	8	2	0	33
SSW	0	5	14	3	2	0	0	24
SW	0	2	7	9	7	1	0	26
WSW	1	6	10	10	4	2	0	33
W	6	0	4	10	18	4	1	43
WNW	3	2	9	13	4	0	0	31
NW	0	1	11	9	5	0	0	26
NNW	0	0	4	12	2	0	0	18
TOTAL	10	22	94	96	55	10	1	288

Kewaunee Nuclear Power Plant Meteorological Data
January 1996 to March 1996
Wind Speed Hourly Average vs. Direction

Stability Class F

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0	3	0	0	0	0	3
NNE	0	0	0	1	0	0	0	1
NE	0	0	0	0	0	0	0	0
ENE	0	0	2	0	2	0	0	4
E	0	0	2	1	0	0	0	3
ESE	0	0	3	0	0	0	0	3
SE	0	0	2	1	0	0	0	3
SSE	0	1	4	2	0	6	0	13
S	0	2	4	0	1	2	0	9
SSW	0	5	5	1	0	0	0	11
SW	0	2	8	4	3	0	0	17
WSW	0	2	8	5	5	0	0	20
W	2	4	14	7	9	0	0	36
WNW	5	1	11	8	1	0	0	26
NW	0	3	7	9	5	0	0	24
NNW	0	0	9	15	2	0	0	26
TOTAL	7	20	82	54	28	8	0	199

Kewaunee Nuclear Power Plant Meteorological Data
 January 1996 to March 1996
 Wind Speed Hourly Average vs. Direction

Stability Class G

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0	0	0	0	0	0	0
NNE	0	1	1	2	0	0	0	4
NE	0	0	0	0	0	0	0	0
ENE	0	0	1	0	0	0	0	1
E	0	0	2	0	0	0	0	2
ESE	0	0	1	0	0	0	0	1
SE	0	0	2	0	0	0	0	2
SSE	0	0	0	2	2	0	1	5
S	0	1	2	0	0	0	0	3
SSW	0	2	12	2	0	0	0	16
SW	0	4	5	15	0	0	0	24
WSW	0	4	12	11	1	0	0	28
W	0	1	18	37	8	0	0	64
WNW	0	1	23	15	0	0	0	39
NW	0	2	17	9	4	0	0	32
NNW	0	0	4	17	2	0	0	23
TOTAL	0	16	100	110	17	0	1	244

Kewaunee Nuclear Power Plant Meteorological Data
 April 1996 to June 1996
 Wind Speed Hourly Average vs. Direction

Stability Class A

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0	2.5	11.5	13	4	0	31
NNE	0	0.25	3	45	70.25	23.25	0	141.75
NE	0	0	10.25	31.75	8	3	0	53
ENE	0	0	7.25	7	1.5	0	0	15.75
E	0	1.25	10	5.5	3	2	0	21.75
ESE	0	0.25	4	1.25	1	0	0	6.5
SE	0	0.25	1.75	3	0	0	0	5
SSE	0	0	2.25	10	8	8	0	28.25
S	0	0.5	0.5	3	6	0	0	10
SSW	0	0.5	1.5	0.5	2	0	0	4.5
SW	0	0	0.25	4.75	7.5	3.25	0	15.75
WSW	0	0	4	8.75	8.25	13.5	0	34.5
W	0	0.25	3.25	11.5	13.25	4.25	0	32.5
WNW	0.25	0	4.5	13.25	9.25	0.25	0	27.5
NW	0	0	4.25	12.25	5.5	3	0	25
NNW	0	0	2.25	19.5	5.25	2	0	29
TOTAL	0.25	2.25	61.5	188.5	161.75	66.5	0	481.75

Kewaunee Nuclear Power Plant Meteorological Data
 April 1996 to June 1996
 Wind Speed Hourly Average vs. Direction

Stability Class B

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0	1.25	4	2	0	0	7.25
NNE	0	0	1	7.25	16.5	3.5	2	30.25
NE	0	0	1.25	1.75	1	1	0	5
ENE	0	0	1.5	0.25	0	0	0	1.75
E	0	2	0	3	1	0	0	6
ESE	0	1	0	2	0	0	0	3
SE	0	1	1	0	0	0	0	2
SSE	0	0	0	0	1	0	0	1
S	0	0.25	2	3	0	0	0	5.25
SSW	0	0.75	0	0	0	0	0	0.75
SW	0	0	0	0	0	1	0	1
WSW	0	0	0	1	0	1	0	2
W	0	0	0	0.5	0.25	0	0	0.75
WNW	0	0	0.25	2.5	0.5	0	0	3.25
NW	0	0	1.5	3.75	1.25	0	0	6.5
NNW	0	0	1.5	1.75	0	2	0	5.25
TOTAL	0	5	11.25	30.75	23.5	8.5	2	81

Kewaunee Nuclear Power Plant Meteorological Data
 April 1996 to June 1996
 Wind Speed Hourly Average vs. Direction

Stability Class C

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0	1.25	1	3	2	0	7.25
NNE	0	0.25	1.25	11	16	3.25	7	38.75
NE	0	0	0.75	3.5	1	0	0	5.25
ENE	0	0	1.25	1	1	0	0	3.25
E	0	0	2	2	0	0	0	4
ESE	0	1	0	0	0	0	0	1
SE	0	0	0	0	0	0	0	0
SSE	0	1	1	0	1	0	0	3
S	0	0	1	3	1	0	0	5
SSW	0	0	1	0	0	0	0	1
SW	0	0.25	0	0	0.25	1	0	1.5
WSW	0	0.25	0	1.75	1	0	0	3
W	0	0	0.25	3	0.25	0	0	3.5
WNW	0	0.5	0	0.5	1.5	0	0	2.5
NW	0	0.25	0	3	1	0	0	4.25
NNW	0	0.25	0	1.25	2	1	0	4.5
TOTAL	0	3.75	9.75	31	29	7.25	7	87.75

Kewaunee Nuclear Power Plant Meteorological Data
 April 1996 to June 1996
 Wind Speed Hourly Average vs. Direction

Stability Class D

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0.75	7.5	12.5	16.5	1.75	1	40
NNE	0	0.75	11.5	53.25	35	20.5	8	129
NE	0	0.25	5.25	8.75	1	2	0	17.25
ENE	0	0.5	2.5	3.5	1	0	0	7.5
E	0	1.5	3.25	6	1	0	0	11.75
ESE	0	2.25	2.75	1.25	0	0	0	6.25
SE	0	1	1.5	5	0	0	0	7.5
SSE	0	1.25	5.75	5.25	4	0	0	16.25
S	0	1.25	7.75	5.5	0.5	0	0	15
SSW	0	0	4.5	2	0.5	0	0	7
SW	0	2.75	2	4	1	2	0	11.75
WSW	0	1	5.25	6.25	2.75	3.5	0	18.75
W	0	0	3.5	6.75	8	1	0	19.25
WNW	0	2	3	6.5	0.75	0	0	12.25
NW	0	0	5.25	11.75	4.25	0	0	21.25
NNW	0	0.25	6.75	6	3	2	0	18
TOTAL	0	15.5	78	144.25	79.25	32.75	9	358.75

Kewaunee Nuclear Power Plant Meteorological Data
 April 1996 to June 1996
 Wind Speed Hourly Average vs. Direction

Stability Class E

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0.5	6.75	8.25	7	2	0	24.5
NNE	0	2	17.25	51.75	24	5	1	101
NE	0	3.5	7.5	7	0	0	0	18
ENE	0	0.25	4.5	3.25	0	0	0	8
E	0	7.25	1.25	1.25	0	0	0	9.75
ESE	0	5.5	6.5	0	0	0	0	12
SE	0	3.25	6	1.25	2	0	0	12.5
SSE	0	2.25	11.25	9	4	0	0	26.5
S	0	1.75	13.25	12.25	2.75	0.25	0	30.25
SSW	0	2.75	8	5.25	0	0	0	16
SW	0	1.25	3.5	4	6	2	0	16.75
WSW	0	0.25	4.75	4	3.75	1	0	13.75
W	0	0	5	9	5	0.5	0	19.5
WNW	0	0	6.75	12.75	2.5	0	0	22
NW	0	0.25	2.75	4.75	1.25	1	0	10
NNW	0	0.5	1.25	6	0	0	0	7.75
TOTAL	0	31.25	106.25	139.75	58.25	11.75	1	348.25

Kewaunee Nuclear Power Plant Meteorological Data
 April 1996 to June 1996
 Wind Speed Hourly Average vs. Direction

Stability Class F

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0.5	2	4	0	0	0	6.5
NNE	0	0.5	12	20.5	5.5	2.75	0	41.25
NE	0	2.25	6.75	11.25	1	0	0	21.25
ENE	0	1.5	3.75	0.5	0	1	0	6.5
E	0	1.25	4.25	1	0	0	0	6.5
ESE	0	3.25	2.25	0.75	0.75	0	0	7
SE	0	2.75	3.5	0	0.25	0	0	6.5
SSE	0	1.5	6.75	4.75	2	0.75	0	15.75
S	0	4	12.5	7.25	1	0	0	25.25
SSW	0	3.5	8.25	8.5	1	0	0	21.25
SW	0	1.75	5.75	2.25	2	0	0	11.75
WSW	0	3	3	5.5	4.25	0	0	15.75
W	0	1.25	6.5	3.75	0	0	0	11.5
WNW	0	1.5	4.75	2.5	0	0	0	8.75
NW	0	1.5	4.5	10.75	0	0	0	16.75
NNW	0	3	3.75	0	0	0	0	6.75
TOTAL	0	33	90	83.75	17.75	4.5	0	229

Kewaunee Nuclear Power Plant Meteorological Data
 April 1996 to June 1996
 Wind Speed Hourly Average vs. Direction

Stability Class G

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	2.5	5	0.5	0	0	0	8
NNE	0	1.5	15.75	13.5	1.5	1	0	33.25
NE	0	1	9.25	9.5	0.25	0	0	20
ENE	0	1	4.25	2.25	2	0	0	9.5
E	0	3	8.25	1.75	0.25	0	0	12.25
ESE	0	4.25	5.75	1.5	0.25	0	0	11.75
SE	0	4.5	14.75	2.25	0.5	0	0	22
SSE	0	14	39.25	43	23.25	1	0	120.5
S	0	7.75	39.5	34.25	4	0	0	85.5
SSW	0	12.5	39.5	3.25	3	0	0	58.25
SW	0	14.25	33.5	10.5	4.25	0	0	62.5
WSW	0	7.5	15.5	4.5	0	0	0	27.5
W	0	2.5	16.75	8.5	0	0	0	27.75
WNW	0	6	12	15.75	0	0	0	33.75
NW	0	3.5	9.25	0.25	0	0	0	13
NNW	0	2.75	5	0	0	0	0	7.75
TOTAL	0	88.5	273.25	151.25	39.25	2	0	554.25

Kewaunee Nuclear Power Plant Meteorological Data
 July 1996 to September 1996
 Wind Speed Hourly Average vs. Direction

Stability Class A

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0	4.25	12	7	2.5	0	25.75
NNE	0	0.25	10.75	14.75	6.5	3.75	0	36
NE	0	0	12.25	6	1.25	0	0	19.5
ENE	0	1	9.5	1.5	0	0	0	12
E	0	2.25	20.25	3.5	2	0	0	28
ESE	0	2.5	12.75	0	1.5	3	4	23.75
SE	0	2	8.5	2	4.5	4.5	2.5	24
SSE	0	3.25	8.5	12.25	10.5	0	0	34.5
S	0	0.25	4.25	4.5	1.75	0	0	10.75
SSW	0	1.25	3.75	1.5	0	0	0	6.5
SW	0	0	3	11.5	9.25	0	0	23.75
WSW	0	0	4	22	29.5	0.75	0	56.25
W	0	0	10.25	37	22.5	0.5	0	70.25
WNW	0	0	14.5	26.25	17.25	0.25	0	58.25
NW	0	0.25	13.75	16.5	5.5	0	0	36
NNW	0	0	6.25	21.25	13.5	0.75	0	41.75
TOTAL	0	13	146.5	192.5	132.5	16	6.5	507

Kewaunee Nuclear Power Plant Meteorological Data
 July 1996 to September 1996
 Wind Speed Hourly Average vs. Direction

Stability Class B

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0	0.5	2.25	1	0.25	0	4
NNE	0	0	0	1.5	1.25	0	0	2.75
NE	0	0	2.25	0.25	0	0	0	2.5
ENE	0	0	0.25	0	0	0	0	0.25
E	0	0	1	0	0	1	0	2
ESE	0	0	1	0	0.5	0	0	1.5
SE	0	1	0	1.25	1	0.25	0.25	3.75
SSE	0	0	1	2.5	1.25	0.75	0.75	6.25
S	0	0	0.75	1	0.75	0	0	2.5
SSW	0	0	4.75	0	0	0	0	4.75
SW	0	0	1.25	0.5	0	0	0	1.75
WSW	0	0	0	0.25	0.5	0	0	0.75
W	0	0	1	0.25	0.75	0	0	2
WNW	0	0	0.25	2.5	2.25	0	0	5
NW	0	0	0.5	2	0	0	0	2.5
NNW	0	0	0.5	6.75	5.5	0	0	12.75
TOTAL	0	1	15	21	14.75	2.25	1	55

Kewaunee Nuclear Power Plant Meteorological Data
 July 1996 to September 1996
 Wind Speed Hourly Average vs. Direction

Stability Class C

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0	1.5	8	1.25	0	0	10.75
NNE	0	0	0.5	1.5	0	0	0	2
NE	0	0	0.5	2.5	0.75	0	0	3.75
ENE	0	0	3	2.5	0	0	0	5.5
E	0	0	2.5	0	0	0	0	2.5
ESE	0	0	3	0	0	0	0	3
SE	0	0	3.25	0	0	0	0	3.25
SSE	0	0	0.5	2.5	0	0	0	3
S	0	0	0.75	2	1	0	0	3.75
SSW	0	0	0.25	0	0	0	0	0.25
SW	0	0	0.5	1.5	0	0	0	2
WSW	0	0	1	0	1	0	0	2
W	0	0	0	3	0	0	0	3
WNW	0	0	3	1.5	1	0	0	5.5
NW	0	0	1.75	5.25	3.5	0	0	10.5
NNW	0	0	0	5.25	3	0	0	8.25
TOTAL	0	0	22	35.5	11.5	0	0	69

Kewaunee Nuclear Power Plant Meteorological Data
 July 1996 to September 1996
 Wind Speed Hourly Average vs. Direction

Stability Class D

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0.5	5.5	11.5	3.25	0	0	20.75
NNE	0	0	5.75	4.5	2	0	0	12.25
NE	0	1	8.25	3	0.25	0	0	12.5
ENE	0	1.25	8.5	2.25	0.25	0	0	12.25
E	0	3.25	18.5	2	0	0	0	23.75
ESE	0	3	6.5	0.25	0	0	0	9.75
SE	0	0	4.25	0	0	0	0	4.25
SSE	0	1	7.75	2.5	2	0.25	0	13.5
S	0	2	6	3.75	1.25	0.25	0	13.25
SSW	0	0.75	3.75	3.25	0	0	0	7.75
SW	0	0.75	2.5	5.75	2.75	0	0	11.75
WSW	0	0.25	4.25	8.25	3.75	0	0	16.5
W	0	0.25	3.25	7.75	1	0	0	12.25
WNW	0	1	3	6.75	0.25	0	0	11
NW	0	0.25	7.25	3.5	2.5	0	0	13.5
NNW	0	1	5	6.5	1.25	0	0	13.75
TOTAL	0	16.25	100	71.5	20.5	0.5	0	208.75

Kewaunee Nuclear Power Plant Meteorological Data
 July 1996 to September 1996
 Wind Speed Hourly Average vs. Direction

Stability Class E

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0.5	7.5	6.75	3	0	0	17.75
NNE	0	2.5	6	6.75	1	0	0	16.25
NE	0	2.25	8	0.25	0	0	0	10.5
ENE	0	2	8.5	1	0	0	0	11.5
E	0	7.25	13.75	1	0	0	0	22
ESE	0	3.5	12	0	0	0	0	15.5
SE	0	5	8.25	2.25	0.5	0	0	16
SSE	0	6.25	13.25	11.5	1	0	0	32
S	0	7	20.75	6.75	0	0	0	34.5
SSW	0	4.25	24	5.25	0	0	0	33.5
SW	0	2.25	5.75	9	0.25	0	0	17.25
WSW	0	7.25	8.75	6.25	0	0	0	22.25
W	0	1.5	17	6.5	2	0	0	27
WNW	0	0.75	12.25	13.75	1.25	0	0	28
NW	0	1	16	3	0	0	0	20
NNW	0	0.25	8.5	0.5	0	0	0	9.25
TOTAL	0	53.5	190.25	80.5	9	0	0	333.25

**Kewaunee Nuclear Power Plant Meteorological Data
July 1996 to September 1996
Wind Speed Hourly Average vs. Direction**

Stability Class F

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	1.5	9.75	1.25	0	0	0	12.5
NNE	0	0	8.25	5.25	1	0	0	14.5
NE	0.25	3.25	4.25	1.25	0	0	0	9
ENE	0	1.25	5.75	0	0	0	0	7
E	0.25	5.25	0.5	0	0	0	0	6
ESE	0.5	3	1.75	0	0	0	0	5.25
SE	0	3.25	5.25	2.25	1	0	0	11.75
SSE	0.25	8	12.5	13.5	10.75	0	0	45
S	0	2.5	29.25	4.75	1	0	0	37.5
SSW	0	6.25	15.75	2.75	1	0	0	25.75
SW	0	1.5	4.75	2	1	0	0	9.25
WSW	0	1.25	9.75	7	0	0	0	18
W	0	3.75	15.5	5.5	0	0	0	24.75
WNW	0	4.75	10.75	4.25	0	0	0	19.75
NW	0	2.25	2.25	0.5	0	0	0	5
NNW	0	3.25	10.25	2	0	0	0	15.5
TOTAL	1.25	51	146.25	52.25	15.75	0	0	266.5

Kewaunee Nuclear Power Plant Meteorological Data
 July 1996 to September 1996
 Wind Speed Hourly Average vs. Direction

Stability Class G

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	2.75	6	2.25	0	0	0	11
NNE	0	1	1.5	0	0	0	0	2.5
NE	0.25	0.25	2	3	0	0	0	5.5
ENE	0	1.5	1	0	0	0	0	2.5
E	0.5	3	0	1	0	0	0	4.5
ESE	0	5.5	3	0	0	0	0	8.5
SE	0	3.5	12.25	5	0	0	0	20.75
SSE	0	12.25	58.75	36	7	2	1	117
S	0	13	52	9.75	0.5	0	0	75.25
SSW	0	25.75	30.25	0	1	0	0	57
SW	0	21.5	45.5	5	0	0	0	72
WSW	0	17	66.5	12.75	0	0	0	96.25
W	0	11.75	52.75	17.5	0	0	0	82
WNW	0	9.75	35.75	17.25	0	0	0	62.75
NW	0	11.25	23.25	1	0	0	0	35.5
NNW	0.25	9.5	10.5	0	0	0	0	20.25
TOTAL	1	149.25	401	110.5	8.5	2	1	673.25

Kewaunee Nuclear Power Plant Meteorological Data
 October 1996 to December 1996
 Wind Speed Hourly Average vs. Direction

Stability Class A

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0	3	3	2	1	0	9
NNE	0	0	9	15	13	0	0	37
NE	0	1	4	0	3	0	0	8
ENE	0	0	5	2	2	0	0	9
E	0	1	6	5	3	0	0	15
ESE	0	0	4	3	3	1	1	12
SE	0	1	0	0	1	2	0	4
SSE	0	0	2	2	0	0	15	19
S	0	0	7	11	3	0	1	22
SSW	0	0	8	11	9	0	0	28
SW	0	0	8	27	18	1	0	54
WSW	0	2	11	33	8	4	1	59
W	0	0	9	21	39	6	14	89
WNW	0	0	21	33	8	2	0	64
NW	0	0	4	15	16	5	0	40
NNW	0	0	4	21	6	2	0	33
TOTAL	0	5	105	202	134	24	32	502

Kewaunee Nuclear Power Plant Meteorological Data
 October 1996 to December 1996
 Wind Speed Hourly Average vs. Direction

Stability Class B

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0	0	1	6	0	0	7
NNE	0	0	0	4	5	0	0	9
NE	0	0	0	0	1	0	0	1
ENE	0	0	0	1	4	0	0	5
E	0	0	0	0	0	0	0	0
ESE	0	1	2	3	1	2	0	9
SE	0	0	0	1	0	0	0	1
SSE	0	0	0	0	0	0	1	1
S	0	0	2	2	3	0	0	7
SSW	0	1	1	0	3	0	0	5
SW	0	0	0	2	4	1	0	7
WSW	0	0	0	5	12	0	0	17
W	0	0	0	4	7	0	0	11
WNW	0	0	1	3	5	0	0	9
NW	0	0	2	7	2	1	0	12
NNW	0	0	4	5	0	0	0	9
TOTAL	0	2	12	38	53	4	1	110

Kewaunee Nuclear Power Plant Meteorological Data
 October 1996 to December 1996
 Wind Speed Hourly Average vs. Direction

Stability Class C

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0	1	2	3	0	0	6
NNE	0	0	0	0	4	0	0	4
NE	0	0	0	0	6	0	0	6
ENE	0	0	1	2	3	0	0	6
E	0	0	1	1	2	0	0	4
ESE	0	0	0	0	5	2	0	7
SE	0	0	0	3	0	0	0	3
SSE	0	0	1	0	1	0	2	4
S	0	0	3	3	1	0	0	7
SSW	0	0	1	1	3	0	0	5
SW	0	0	3	2	3	2	0	10
WSW	0	1	3	2	7	1	0	14
W	0	1	3	9	9	5	0	27
WNW	0	0	4	6	0	0	0	10
NW	0	0	6	10	2	1	0	19
NNW	0	0	2	2	0	0	0	4
TOTAL	0	2	29	43	49	11	2	136

Kewaunee Nuclear Power Plant Meteorological Data
 October 1996 to December 1996
 Wind Speed Hourly Average vs. Direction

Wind Direction (from)	Stability Class D							Total
	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	
N	0	0	7	8	1	0	0	16
NNE	0	1	5	0	6	4	1	17
NE	0	4	3	5	14	3	0	29
ENE	0	3	12	5	13	1	0	34
E	0	2	11	6	3	0	0	22
ESE	0	3	2	1	0	2	0	8
SE	0	1	2	3	4	4	0	14
SSE	0	1	4	5	7	2	10	29
S	0	1	18	18	11	4	0	52
SSW	0	5	21	13	6	0	0	45
SW	0	1	14	20	4	0	0	39
WSW	0	2	13	18	9	4	0	46
W	0	3	8	31	37	8	1	88
WNW	0	0	12	23	4	1	0	40
NW	0	1	16	19	3	0	0	39
NNW	0	0	10	7	3	2	0	22
TOTAL	0	28	158	182	125	35	12	540

Kewaunee Nuclear Power Plant Meteorological Data
 October 1996 to December 1996
 Wind Speed Hourly Average vs. Direction

Stability Class E

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	1	3	4	1	0	0	9
NNE	0	1	4	7	1	0	0	13
NE	0	0	4	4	1	0	0	9
ENE	0	0	4	2	0	0	0	6
E	0	3	7	1	6	0	0	17
ESE	0	1	5	1	2	1	1	11
SE	0	0	8	1	8	3	0	20
SSE	0	4	4	6	15	9	3	41
S	0	3	23	17	14	1	0	58
SSW	0	2	8	5	1	0	0	16
SW	0	0	11	7	4	0	0	22
WSW	0	3	13	6	6	0	0	28
W	0	2	14	35	3	2	2	58
WNW	0	1	11	22	0	0	0	34
NW	0	0	9	6	2	0	0	17
NNW	0	0	6	6	1	0	0	13
TOTAL	0	21	134	130	65	16	6	372

**Kewaunee Nuclear Power Plant Meteorological Data
 October 1996 to December 1996
 Wind Speed Hourly Average vs. Direction**

Wind Direction (from)	Stability Class F							Total
	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	
N	0	0	0	1	0	0	0	1
NNE	0	0	0	0	0	0	0	0
NE	0	1	2	1	0	0	0	4
ENE	0	1	1	0	0	0	0	2
E	0	4	2	0	1	0	0	7
ESE	0	4	2	0	0	0	0	6
SE	0	3	6	1	0	0	0	10
SSE	0	3	10	10	17	11	1	52
S	0	2	17	8	1	0	0	28
SSW	0	1	18	7	0	0	0	26
SW	0	6	7	2	2	1	0	18
WSW	0	4	6	0	1	0	0	11
W	0	0	10	15	1	0	0	26
WNW	0	0	12	8	0	0	0	20
NW	0	1	5	4	0	0	0	10
NNW	0	0	1	1	0	0	0	2
TOTAL	0	30	99	58	23	12	1	223

Kewaunee Nuclear Power Plant Meteorological Data
 October 1996 to December 1996
 Wind Speed Hourly Average vs. Direction

Stability Class G

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	1	0	0	0	0	0	1
NNE	0	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0	0
ENE	0	0	1	0	0	0	0	1
E	0	0	1	0	0	0	0	1
ESE	0	2	0	0	0	0	0	2
SE	0	3	2	0	1	0	0	6
SSE	0	1	4	10	7	2	0	24
S	0	3	5	2	0	0	0	10
SSW	0	8	19	0	0	0	0	27
SW	0	9	10	0	0	0	0	19
WSW	0	10	12	2	0	0	0	24
W	0	2	35	20	0	0	0	57
WNW	0	2	36	7	0	0	0	45
NW	0	5	6	0	0	0	0	11
NNW	0	5	4	0	0	0	0	9
TOTAL	0	51	135	41	8	2	0	237

**Kewaunee Nuclear Power Plant Meteorological Data
Wind Speed Hourly Average vs. Direction
Batch Release Summary - Permit 96-001**

Stability Class A

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
WSW	0	0	0	0.5	0	0	0	0.5
W	0	0	0	0.25	0	0	0	0.25
TOTAL	0	0	0	0.75	0	0	0	0.75

Stability Class E

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
WSW	0	0	0	0.75	0	0	0	0.75
W	0	0	0.25	0.25	0.75	0	0	1.25
WNW	0	0	0	0.75	0	0	0	0.75
TOTAL	0	0	0.25	1.75	0.75	0	0	2.75

Stability Class F

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
WSW	0	0	0.25	0.75	0	0	0	1
W	0	0	0.75	1.25	0.5	0	0	2.5
WNW	0	0	0	1.5	1	0	0	2.5
TOTAL	0	0	1	3.5	1.5	0	0	6

Stability Class G

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
WSW	0	0	0	0.25	0	0	0	0.25
WNW	0	0	0.25	0.5	0.25	0	0	1
TOTAL	0	0	0.25	0.75	0.25	0	0	1.25

**Kewaunee Nuclear Power Plant Meteorological Data
Wind Speed Hourly Average vs. Direction
Batch Release Summary - Permit 96-002**

There is no Meteorological Data available for release number 96-002; 983 minute duration.

Kewaunee Nuclear Power Plant Meteorological Data
 Wind Speed Hourly Average vs. Direction
 Batch Release Summary - Permit 96-003

Stability Class D

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
NW	0	0	0	0.25	0	0	0	0.25
TOTAL	0	0	0	0.25	0	0	0	0.25

Kewaunee Nuclear Power Plant Meteorological Data
 Wind Speed Hourly Average vs. Direction
 Batch Release Summary - Permit 96-004

Stability Class A

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
S	0	0	1	3	0	0	0	4
SSW	0	0	0.25	1	0	0	0	1.25
TOTAL	0	0	1.25	4	0	0	0	5.25

Stability Class D

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
S	0	0	0	2.25	0	0	0	2.25
SSW	0	0	0	1	0	0	0	1
TOTAL	0	0	0	3.25	0	0	0	3.25

Stability Class E

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
S	0	0	0	0.5	0	0	0	0.5
SSW	0	0	0	0.5	0	0	0	0.5
TOTAL	0	0	0	1	0	0	0	1

Stability Class F

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
S	0	0	0	0.25	0	0	0	0.25
SSW	0	0	0	0.25	0	0	0	0.25
TOTAL	0	0	0	0.5	0	0	0	0.5

Kewaunee Nuclear Power Plant Meteorological Data
 Wind Speed Hourly Average vs. Direction
 Batch Release Summary - Permit 96-004

Stability Class G

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
SSE	0	0	0	0.25	0	0	0	0.25
S	0	0	0.25	0.25	0	0	0	0.5
SSW	0	0	1	0	0	0	0	1
SW	0	0	0.5	2.75	0	0	0	3.25
TOTAL	0	0	1.75	3.25	0	0	0	5

Kewaunee Nuclear Power Plant Meteorological Data
 Wind Speed Hourly Average vs. Direction
 Batch Release Summary - Permit 96-005

Stability Class A

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0	0	0	1.5	1.75	0	3.25
TOTAL	0	0	0	0	1.5	1.75	0	3.25

Stability Class B

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0	0	0	1.5	0	0	1.5
NNW	0	0	0	0.25	0.25	0	0	0.5
TOTAL	0	0	0	0.25	1.75	0	0	2

Stability Class C

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0	0	0.25	0	0	0	0.25
NNE	0	0	0	0	1	0	0	1
NNW	0	0	0	0.75	0	0	0	0.75
TOTAL	0	0	0	1	1	0	0	2

Kewaunee Nuclear Power Plant Meteorological Data
 Wind Speed Hourly Average vs. Direction
 Batch Release Summary - Permit 96-005

Stability Class D

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0	0	1.5	0	0	0	1.5
NNE	0	0	0	0.25	1.25	0	0	1.5
TOTAL	0	0	0	1.75	1.25	0	0	3

Kewaunee Nuclear Power Plant Meteorological Data
 Wind Speed Hourly Average vs. Direction
 Batch Release Summary - Permit 96-006

Stability Class A

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
S	0	0	0.5	0.5	1.25	0	0	2.25
SSW	0	0	0.75	2	0	0	0	2.75
SW	0	0	0	0	0.5	0	0	0.5
TOTAL	0	0	1.25	2.5	1.75	0	0	5.5

Stability Class C

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
SSE	0	0	0	0	1.25	0	0	1.25
S	0	0	0.25	0	0	0	0	0.25
TOTAL	0	0	0.25	0	1.25	0	0	1.5

Stability Class D

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
SSE	0	0	0	0.75	0	0	0	0.75
S	0	0	0	1	0	0	0	1
SSW	0	0	0.25	0	0	0	0	0.25
TOTAL	0	0	0.25	1.75	0	0	0	2

Kewaunee Nuclear Power Plant Meteorological Data
 Wind Speed Hourly Average vs. Direction
 Batch Release Summary - Permit 96-006

Stability Class E

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
SSE	0	0	0.25	1.5	1.25	0	0	3
S	0	0	0	0	0.25	0	0	0.25
TOTAL	0	0	0.25	1.5	1.5	0	0	3.25

Stability Class F

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
SSE	0	0	0	0	1	0	0	1
TOTAL	0	0	0	0	1	0	0	1

Kewaunee Nuclear Power Plant Meteorological Data
 Wind Speed Hourly Average vs. Direction
 Batch Release Summary - Permit 96-007

Stability Class A

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
SSW	0	0	0.25	0	0	0	0	0.25
WNW	0	0	0.25	0	0	0	0	0.25
TOTAL	0	0	0.5	0	0	0	0	0.5

Stability Class E

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
NNE	0	0	0.75	0.25	0	0	0	1
TOTAL	0	0	0.75	0.25	0	0	0	1

Stability Class F

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
NNE	0	0	0.5	0	0	0	0	0.5
TOTAL	0	0	0.5	0	0	0	0	0.5

Kewaunee Nuclear Power Plant Meteorological Data
 Wind Speed Hourly Average vs. Direction
 Batch Release Summary - Permit 96-007

Stability Class G

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0	0.5	0	0	0	0	0.5
NNE	0	0.25	0.5	0.75	0.25	0	0	1.75
NE	0	0	0.25	0	0	0	0	0.25
E	0	0	0.75	0	0	0	0	0.75
ESE	0	0	0.5	0	0	0	0	0.5
SE	0	0	0.5	0	0	0	0	0.5
SSE	0	0	1.5	1.75	0	0	0	3.25
S	0	0	0.75	0.5	0	0	0	1.25
SSW	0	0	0.25	0	0	0	0	0.25
SW	0	0.25	0	0	0	0	0	0.25
WSW	0	0.5	0.25	0	0	0	0	0.75
W	0	0	0.5	0	0	0	0	0.5
WNW	0	0	0.5	0	0	0	0	0.5
TOTAL	0	1	6.75	3	0.25	0	0	11

Kewaunee Nuclear Power Plant Meteorological Data
 Wind Speed Hourly Average vs. Direction
 Batch Release Summary - Permit 96-008

Stability Class C

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
NE	0	0	0.25	0	0	0	0	0.25
NW	0	0	0.5	0	0	0	0	0.5
TOTAL	0	0	0.75	0	0	0	0	0.75

**Kewaunee Nuclear Power Plant Meteorological Data
Wind Speed Hourly Average vs. Direction
Batch Release Summary - Permit 96-008**

Stability Class D

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
NW	0	0	0.5	0	0	0	0	0.5
TOTAL	0	0	0.5	0	0	0	0	0.5

Stability Class E

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
ENE	0	0.5	0	0	0	0	0	0.5
E	0	0.25	0	0	0	0	0	0.25
SE	0	0.25	0.75	0	0	0	0	1
SSE	0	0	0.5	0	0	0	0	0.5
WNW	0	0	0.25	0	0	0	0	0.25
NW	0	0	0.5	0	0	0	0	0.5
TOTAL	0	1	2	0	0	0	0	3

Stability Class F

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
NNE	0	0.25	0	0	0	0	0	0.25
ESE	0	0	0.75	0	0	0	0	0.75
SE	0	0	0.75	0	0	0	0	0.75
SSE	0	0.25	0.5	0	0	0	0	0.75
S	0	0	0.25	0	0	0	0	0.25
WNW	0	0	0.25	0.25	0	0	0	0.5
NW	0	0	0.5	0.25	0	0	0	0.75
TOTAL	0	0.5	3	0.5	0	0	0	4

Stability Class G

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
NNE	0	0.25	0	0	0	0	0	0.25
NE	0	0	0.5	0	0	0	0	0.5
SE	0	0.25	0	0	0	0	0	0.25
WSW	0	0	0.25	0	0	0	0	0.25
W	0	0	0.75	0	0	0	0	0.75
WNW	0	0	0.25	0	0	0	0	0.25
NNW	0	0.25	0	0	0	0	0	0.25
TOTAL	0	0.75	1.75	0	0	0	0	2.5

Kewaunee Nuclear Power Plant Meteorological Data
 Wind Speed Hourly Average vs. Direction
 Batch Release Summary - Permit 96-009

Stability Class A

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
NE	0	0	0.75	0	0	0	0	0.75
ENE	0	0	0.75	0	0	0	0	0.75
E	0	0.25	0.75	0	0	0	0	1
ESE	0	0.25	0	0	0	0	0	0.25
S	0	0	0.25	0	0	0	0	0.25
SSW	0	0	0.5	0	0	0	0	0.5
TOTAL	0	0.5	3	0	0	0	0	3.5

Stability Class B

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
SE	0	0.25	0.25	0.25	0	0	0	0.75
SSE	0	0	0	0.25	0	0	0	0.25
TOTAL	0	0.25	0.25	0.5	0	0	0	1

Stability Class C

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
NE	0	0	0.25	0	0	0	0	0.25
ENE	0	0	0.75	0	0	0	0	0.75
TOTAL	0	0	1	0	0	0	0	1

Stability Class D

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
NE	0	0	0.25	0	0	0	0	0.25
ENE	0	0	0.75	0	0	0	0	0.75
E	0	0	0.25	0	0	0	0	0.25
TOTAL	0	0	1.25	0	0	0	0	1.25

Kewaunee Nuclear Power Plant Meteorological Data
 Wind Speed Hourly Average vs. Direction
 Batch Release Summary - Permit 96-009

Stability Class E

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
NE	0	0	0.25	0.25	0	0	0	0.5
ENE	0	0	0.25	0	0	0	0	0.25
S	0	0	0.25	0	0	0	0	0.25
SSW	0	0	0.25	0	0	0	0	0.25
SW	0	0	0.25	0	0	0	0	0.25
TOTAL	0	0	1.25	0.25	0	0	0	1.5

Stability Class F

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
NE	0	0	1	0.5	0	0	0	1.5
ENE	0	0	0.25	0	0	0	0	0.25
S	0	0	0.75	0	0	0	0	0.75
SSW	0	0	0.75	0	0	0	0	0.75
TOTAL	0	0	2.75	0.5	0	0	0	3.25

Stability Class G

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
E	0	0.25	0	0	0	0	0	0.25
SE	0	0.25	0	0	0	0	0	0.25
SSE	0	0.5	0.25	0	0	0	0	0.75
S	0	0.25	0.25	0	0	0	0	0.5
SSW	0	1	0.25	0	0	0	0	1.25
WSW	0	0	0.25	0	0	0	0	0.25
TOTAL	0	2.25	1	0	0	0	0	3.25

**Kewaunee Nuclear Power Plant Meteorological Data
Wind Speed Hourly Average vs. Direction
Batch Release Summary - Permit 96-010**

There is 11 hours of missing Meteorological Data regarding release number 96-010.

Stability Class B

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
NW	0	0	0	0.25	0	0	0	0.25
NNW	0	0	0	3	0.75	0	0	3.75
TOTAL	0	0	0	3.25	0.75	0	0	4

Stability Class C

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0	0	0	0.5	0	0	0.5
NW	0	0	0	2.75	2.5	0	0	5.25
NNW	0	0	0	0.75	0	0	0	0.75
TOTAL	0	0	0	3.5	3	0	0	6.5

Stability Class D

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0	0	0	0.25	0	0	0.25
NW	0	0	0	0	1.75	0	0	1.75
NNW	0	0	0	0	0.5	0	0	0.5
TOTAL	0	0	0	0	2.5	0	0	2.5

**Kewaunee Nuclear Power Plant Meteorological Data
Wind Speed Hourly Average vs. Direction
Batch Release Summary - Permit 96-011**

Stability Class A

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
SE	0	0	1	0	0	0	0	1
SSE	0	0	1.25	6	0.75	0	0	8
S	0	0	1.25	1	0.25	0	0	2.5
SW	0	0	0.25	0	0	0	0	0.25
TOTAL	0	0	3.75	7	1	0	0	11.75

Kewaunee Nuclear Power Plant Meteorological Data
 Wind Speed Hourly Average vs. Direction
 Batch Release Summary - Permit 96-011

Stability Class B

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
SSE	0	0	0	1.75	0	0	0	1.75
S	0	0	0.75	0.5	0	0	0	1.25
TOTAL	0	0	0.75	2.25	0	0	0	3

Stability Class C

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
SSE	0	0	0	0.5	0	0	0	0.5
TOTAL	0	0	0	0.5	0	0	0	0.5

Stability Class D

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
N	0	0.5	0	0	0	0	0	0.5
ENE	0	0.25	0.75	0	0	0	0	1
E	0	0	1	0	0	0	0	1
ESE	0	0.5	0.5	0	0	0	0	1
SSE	0	0	0	1.25	1	0	0	2.25
S	0	0	0	0.25	0	0	0	0.25
SW	0	0	0.25	0	0	0	0	0.25
W	0	0	0	0.25	0	0	0	0.25
NW	0	0.25	0	0	0	0	0	0.25
TOTAL	0	1.5	2.5	1.75	1	0	0	6.75

Stability Class E

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
ESE	0	0	0.75	0	0	0	0	0.75
SSE	0	0	0.25	0	0	0	0	0.25
W	0	0	0.25	0	0	0	0	0.25
WNW	0	0.25	0	0	0	0	0	0.25
TOTAL	0	0.25	1.25	0	0	0	0	1.5

**Kewaunee Nuclear Power Plant Meteorological Data
Wind Speed Hourly Average vs. Direction
Batch Release Summary - Permit 96-011**

Stability Class F

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
ENE	0	0.25	0.25	0	0	0	0	0.5
ESE	0	0	0.25	0	0	0	0	0.25
TOTAL	0	0.25	0.5	0	0	0	0	0.75

Stability Class G

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
ESE	0	0.25	0	0	0	0	0	0.25
TOTAL	0	0.25	0	0	0	0	0	0.25

**Kewaunee Nuclear Power Plant Meteorological Data
Wind Speed Hourly Average vs. Direction
Batch Release Summary - Permit 96-012**

Stability Class A

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
SE	0	0	0.25	0	0	0	0	0.25
SSE	0	0	0.5	0.25	0	0	0	0.75
TOTAL	0	0	0.75	0.25	0	0	0	1

**Kewaunee Nuclear Power Plant Meteorological Data
Wind Speed Hourly Average vs. Direction
Batch Release Summary - Permit 96-013**

Stability Class A

Wind Direction (from)	Calm	1 - 3	4 - 7	8 - 12	13-18	19-24	>24	Total
WNW	0	0	0.75	0	0	0	0	0.75
TOTAL	0	0	0.75	0	0	0	0	0.75