

PMComanchePeakPEm Resource

From: Otto, Ngola
Sent: Thursday, June 30, 2011 10:01 AM
To: Woodlan, Don
Cc: Monarque, Stephen; ComanchePeakCOL Resource
Subject: RE: 2011-06-27 Woodlan, Comanche Peak chapter 8 RAI Status

Don,

Our staff is available most of next week for the conference call to discuss the 2 open items in chapter 8. Please propose a couple of dates and times and we'll coordinate.

Thank you

Ngola
301-415-6695

From: Woodlan, Don [<mailto:Donald.Woodlan@luminant.com>]
Sent: Monday, June 27, 2011 11:16 AM
To: Monarque, Stephen; ComanchePeakCOL Resource
Cc: Otto, Ngola; nicholas_kellenberger@mnes-us.com; russell_bywater@mnes-us.com; 'tapia_joseph@mnes-us.com'; Conly, John; Evans, Todd; Bird, Bobby
Subject: 2011-06-27 Woodlan, Comanche Peak chapter 8 RAI Status

Ngola and Steve,

It is somewhat surprising to see these so late in the game but thanks for the heads up. It is my guess that we should have a conference call with the reviewer to obtain a better understanding of the issues. OI 08.01-1 is new so we need to understand the challenge. OI 08.02-1 has been discussed before but the description below does not seem to match our previous discussions. We will do some research on our part and then we will contact Ngola to set up a clarifying conference call. I want to understand the items so that we can initiate action to provide the NRC with what it needs as soon as possible.

Thanks,

Donald R. Woodlan

Manager, Nuclear Regulatory Affairs

Luminant Power

O- 254-897-6887 C- 214-542-7761

From: Otto, Ngola [<mailto:Ngola.Otto@nrc.gov>]
Sent: Monday, June 27, 2011 7:40 AM
To: Woodlan, Don
Cc: ComanchePeakCOL Resource; Monarque, Stephen; Martinez-Navedo, Tania
Subject: FW: Comanche Peak chapter 8 RAI Status

Don,

Based on the review of the Comanche Peak Chapter 8 safety evaluation, I have updated the status of the questions. See attached.

Open Items

RAI 2576, Question 08.01-2 (Open Item 08.01-1) – As stated in the safety evaluation “The staff reviewed the applicant’s response and finds that the applicant has not stated whether or not the sharing of structures,

systems, and components important to safety that are shared among nuclear power units will not significantly impair their ability to perform their safety functions, including in the event of an accident in one unit, or an orderly shutdown and cooldown of the remaining units”.

RAI 5116, Question 08.02-30 (Open Item 08.02-1) – Inconsistency between the DCD chapter 15 language related to anti-monitoring protective relaying for main generator output breaker.

Confirmatory Items

RAI 2577, Question 08.02-24 (Confirmatory Item 08.02-1)
RAI 4538, Question 08.02-27 (Confirmatory Item 08.02-2)
RAI 5116, Question 08.02-29 (Confirmatory Item 08.02-3)
RAI 2581, Question 08.03.01-1 (Confirmatory Item 08.03.01-1)
RAI 5117, Question 08.04-1 (Confirmatory Item 08.04-1)

Please call me if you have any questions.

Ngola Otto
Project Manager, US-APWR Projects Branch
Division of New Reactor Licensing
Office of New Reactors
(301) 415-6695

From: Otto, Ngola
Sent: Thursday, March 31, 2011 10:58 AM
To: 'Woodlan, Don'
Cc: Monarque, Stephen; ComanchePeakCOL Resource; Martinez-Navedo, Tania
Subject: Comanche Peak chapter 8 RAI Status

Don,

I have attached the list of chapter 8 RAIs that shows the status for each question.

RAI 5116, Question 08.02-30 (CP RAI 182), initial response was inadequate, and since supplementary response will be submitted, we have statused the question as “Confirmatory Action Applicant” and the question is currently and “Open Item”. The supplemental response will be evaluated by NRC staff and if accepted the ‘Open Item” will be resolved.

RAI 5117, Question 08.04-01 (CP RAI 183), initial response was inadequate, and since supplementary response will be submitted, we have statused the question as “Confirmatory Action Applicant” and the question is currently and “Open Item”. The supplemental response will be evaluated by NRC staff and if accepted the ‘Open Item” will be resolved.

Please call me if you have any questions.

Ngola Otto
Project Manager, US-APWR Projects Branch
Division of New Reactor Licensing
Office of New Reactors
(301) 415-6695

Confidentiality Notice: This email message, including any attachments, contains or may contain confidential information intended only for the addressee. If you are not an intended recipient of this message, be advised that

any reading, dissemination, forwarding, printing, copying or other use of this message or its attachments is strictly prohibited. If you have received this message in error, please notify the sender immediately by reply message and delete this email message and any attachments from your system.

Hearing Identifier: ComanchePeak_COL_Public
Email Number: 1420

Mail Envelope Properties (6566BAEC3DB1314381965386524904EC357ECF468E)

Subject: RE: 2011-06-27 Woodlan, Comanche Peak chapter 8 RAI Status
Sent Date: 6/30/2011 10:01:03 AM
Received Date: 6/30/2011 10:01:04 AM
From: Otto, Ngola

Created By: Ngola.Otto@nrc.gov

Recipients:

"Monarque, Stephen" <Stephen.Monarque@nrc.gov>

Tracking Status: None

"ComanchePeakCOL Resource" <ComanchePeakCOL.Resource@nrc.gov>

Tracking Status: None

"Woodlan, Don" <Donald.Woodlan@luminant.com>

Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	4745	6/30/2011 10:01:04 AM

Options

Priority: Standard

Return Notification: No

Reply Requested: No

Sensitivity: Normal

Expiration Date:

Recipients Received: