

Client: Wisconsin Public Service Company Calculation No. C-020

Title: Fragility Analysis of the Circulating Water Intake and Discharge Piping

Project: Kewaunee USI A-46 / IPEEE

Method: Hand Calculation

Acceptance Criteria: AISC 8th Edition, ACI 318-89, and EPRI NP-6041

Remarks: _____

REVISIONS

No.	Description	By	Date	Chk.	Date	App.	Date
0	Original Issue	MSL	5/20/94	TMT	5/25/94	WD	5/25/94



CALCULATION
COVER
SHEET

FIGURE 1.3

CONTRACT NO.

91C2683



Stevenson and Associates

A Structural Mechanical
Consulting Engineering Firm

CLIENT WPSC JOB No. 910583 SHEET 1 OF 13

SUBJECT Kewanee A46 / IPEEE
Fragility Analysis of the Circulating
Water Piping
C-020

REVISIONS	1
	ML: 5/20/94 TMT 5/24/94

Objective: The objective of this calculation is to compute the fragility (CDFM) value of the Kewanee circulating water piping (discharge and intake) for the IPEEE activity.

In the absence of direct fault displacement or liquefaction, only the following two effects of earthquake ground motion effects on the structures are considered:

- A. Axial tension/compression and bending strains induced by the traveling seismic wave.
- B. Strain caused by transient horizontal displacement at penetrations.

Conclusion: The CDFM value of the circulating water piping system is 0.418 and it is controlled by the concrete discharge piping at penetration under shear.

References

1. Kewanee Drawings
 - # S613-S "Circulating Water Intake & Discharge Plan"
 - # S614-B "Circulating Water Intake Plan & Profile"
 - # M236-X "Circulating Water Piping"
 - # XK200-96 "Specification: 120" Reinforced Concrete Pipe with Rubber and Steel Joints (CSP-1)"
 - # XK200-101 "Reinforced Concrete Pressure Pipe with Rubber & Steel Expansion Joint (SP-1) 108" thru 144" (Floating Rings)"
 - # XK200-102 "Reinforced Concrete Pipe w/ 5" stirrups"
2. ASCE Standard 4-86 "Seismic Analysis of safety related Nuclear Structures and Commentary on Standard for seismic Analysis of safety-related Nuclear Structures."
3. Tjahjard and Goodling, "Seismic Design of Buried Piping," Second ASCE Specialty Conference on Structural Design of Nuclear Plant Facilities, New Orleans, Louisiana, December 8-10, 1975
4. C. E. Wong & C. E. Salmon, "Reinforced Concrete Design," 3rd edition.



Stevenson and Associates

A Structural-Mechanical Consulting Engineering Firm

CLIENT	WPCSC	JOB No.	9102683	SHEET	2	OF	13
SUBJECT	Kavanaugh AAG / IPEEE Feasibility Analysis of the Circulating Water Piping C-020						
REVISIONS	0	MUL 5/20/94 TMT 5/24/94					

5. ACI 318-89 Building Code Requirements for Reinforced Concrete
6. Bossi, Sidebottom, Seeling & Smith, "Advanced Mechanics of Materials," 3rd edition.
7. Concrete Reinforcing Steel Institute, "Manual of Standard Practice," 23rd edition, 1980.
8. ECI Report, "Kavanaugh IPEEE," March 1994
9. Bowles, "Foundation Analysis and Design," 2nd edition
10. Newmark and Hall, "Development of Criteria for Seismic Review of Selected Nuclear Power Plant," NUREG/CR-0098, May 1978
11. Kavanaugh, "Nuclear Power Plant, USAR"
12. Roark & Young, "Formulas for Stress and Strain," 5th edition.

Assumptions

General

1. Crack developed in the concrete piping is not considered to be failure. It means that leakage is allowed during or after the seismic event.
2. The surcharge due to the soil above the piping structure is ignored in the following calculation.

Discharge Piping

1. Compressive strength of concrete is 3000 psi.
2. Yield strength of reinforcement is 40 ksi.
3. Reinforcing bars are protected against moisture with sufficient concrete cover.
4. Since the gage 6-5 as indicated in Ref. Drawg # XT-200-96 was not found among the old steel description paper of Ref. 7. It is assumed that this designation 6-5 should be understood as W65. Then diameter of a strap is $d = 0.288$ " (Ref. Top Page 2-5).



Stevenson and Associates

A Structural-Mechanical Consulting Engineering Firm

CLIENT WPC JOB No. 91C2683 SHEET 3 OF 13

SUBJECT Review of AAS/PEEE
Fragility Analysis of the Graveling
Water Piping
G-020

REVISIONS	0	MO: 5/20/94
		TMT 5/24/94

Intake Piping

1. Yield strength of the steel material is 36 ksi

In the absence of direct fault displacement or liquefaction, the following effects of earthquake ground motion are considered:

- a. Axial tension/compression and bending due to traveling seismic wave
- b. Strain caused by transient horizontal displacements at connections

Parameters:

Soil: Compacted backfill, $\rho_s = 130 \text{ pcf}$, $\nu_s = 0.3$ (Ref. 8)

IPEEE Review level Earthquake (RLE): [LL - ground motion, $PGA = 0.306g$
max. ground velocity (Ref. 10)
 $V_m = 48 \text{ in/sec} \times PGA = 14.7 \text{ in/sec}$

Soil Wave Velocities (Refs. 2, 3 and 8)

Compressional wave velocity, $C_p = 3000 \text{ fps}$
with $\nu_s = 0.3$ for compacted backfill
Rayleigh wave velocity, $C_R = 0.9 C_p = 1500 \text{ fps}$
Shear wave velocity, $C_s = C_R / 0.93 = 1613 \text{ fps}$

Coefficient of subgrade reaction, R_s

From equation 9-14 in Ref. 6, we have

$$R_s = 36 \frac{q_a}{D} \quad \text{where } q_a = \text{Allowable bearing pressure for soil} = 6 \text{ ksf (Ref. 11 App E)}$$

$$= 216 \text{ pcf}$$

Coefficient of friction between the pipe and the soil

$$f = \pi D \rho_s h \mu \quad \text{Equation 11 of Ref. 3}$$

where D = diameter of the pipe
 ρ_s = soil density = 130 pcf (Ref. 8)
 h = average depth of pipe below grade
 μ = coefficient of friction = $\tan(\phi) = \tan \phi = 0.58$
 * let $\phi = 1$ (conservative assumption)

$$f = 237 D h \quad (\text{pcf})$$



CLIENT	WPSC	JOB No.	9102683	SHEET	4	OF	13
SUBJECT	Kalamazoo ASG/PEEE						
	Feasibility Analysis of the Circulating						
	Water Piping						
	C-020						
REVISIONS	0	MSL 5/20/94					
		TMT 5/24/94					

Peak Transient Horizontal displacement (Ref. 3)

Following conservative assumptions have been made:

1. The peak transient displacement of the soil deposit due to an earthquake were calculated by integrating with respect to depth the peak values of the seismically induced shear strain in the soil. This is conservative, as the peak shear strains at different depths do not occur simultaneously.
2. The differential displacement between a building and the surrounding ground is conservatively taken to be uniform distributed over a distance of about 25 ft from the foundation.

Single-amplitude transient displacement for PFA of 0.78, stiff soil profile - Table 2 of REI report (see page 13).

ground surface 1.2 inches
Screen house 0.5 inches

$$\frac{\text{Screen house disp.}}{\text{ground disp.}} = \frac{0.5}{1.2} = 0.42 \quad \text{This ratio is assumed in the following calculation of screen house displacement.}$$


From Fig. 9 of REI report (see page 12), the single amplitude transient displacement of ground for PFA of 0.458, stiff soil profile is 0.53 inches.

Using the assumption above, the transient displ. of screen house for PFA of 0.458, stiff soil profile is $0.53 \times 0.42 = 0.22$ inches.

SRSS is used to compute the differential displacement between the screen house and the ground.

$$d = \sqrt{0.53^2 + 0.22^2} = 0.58 \text{ inches}$$

As indicated in Fig. 12 of REI report, the transient horizontal displacements for very stiff soil profile are much smaller than those for stiff soil profile. Therefore, the displacements for stiff soil profile is used.

 Stevenson & Associates a structural-mechanical consulting engineering firm	CAL. NO. 91C2683 C-020 SUBJECT: Kewaunee A-46/IPEEE	SHEET # 5 of 13 Revision 0
	Fragility Analysis of the Circulating Water Intake and Discharge Piping	By MSL 5/20/94 Chk. TMT 5/25/94

Moment and Shear Capacities of Discharge Pipe

In accordance with Ref. 4 (page 486) the use of gross moment of inertia (i.e. neglecting reinforcement and concrete cracking) underestimates deflections. Hence using it for the purpose of this calculation is conservative.

$$I_g = \frac{\pi(140^4 - 120^4)}{64} = 8.7 \times 10^8 \text{ in}^4 \quad E_c = 57000\sqrt{3000} = 3.1 \times 10^6 \text{ psi}$$


$$A_g = \frac{\pi(140^2 - 120^2)}{4} = 4080 \text{ in}^2$$

$$A_{sh} = \frac{A_g}{k} = \frac{4080}{2} = 2040 \text{ in}^2 \quad (k = 2 \text{ for a ring from page 173 of Ref. 6})$$

$$G_c = \frac{3.1 \times 10^6}{2(1+0.2)} = 1.29 \times 10^6 \text{ psi} \quad (\text{Poisson ratio} = 0.2)$$

where inside diameter = 10 ft and thickness = 10 in.

Moment capacity of the discharge pipe is calculated similarly to page 410 of Ref. 4:



$$\epsilon_y = \frac{f_y}{E_s} = \frac{40000}{29 \times 10^6} = 0.0014$$

$$\text{So } \alpha_s = 70.22^\circ = 123 \text{ rad.} \quad \alpha_c = 96.56^\circ = 169 \text{ rad.}$$

$$R = 65 \text{ in}$$

$$\cup AB = 65 \times 1.23 \times 2 = 160 \text{ in}$$

$$\cup CD = 70 \times 1.69 \times 2 = 237 \text{ in}$$


$$CD = 70 \times \text{Cos } 6.56^\circ \times 2 = 139 \text{ in}$$

$$OE = \frac{2}{3} \times \frac{70^3 - 60^3}{70^2 - 60^2} \times \frac{139}{237} = 38 \text{ in}$$

Moment due to compression in concrete:

$$A_c = \frac{\pi(140^2 - 120^2) \times 2 \times 96.56}{4 \times 360} = 2190 \text{ in}^2$$

$$M_c = 0.9 \times 2550 \times 2190 \times 38 = 191 \times 10^8 \text{ in-lb}$$

 Stevenson & Associates a structural-mechanical consulting engineering firm	CAL. NO. 91C2683 C-020 SUBJECT: Kewaunee A-46/IPEEE	SHEET # 6 of 13 Revision 0
	Fragility Analysis of the Circulating Water Intake and Discharge Piping	By MSL 5/20/94 Chk. TMT 5/25/94

Moment due to compression in steel which yields:

$$\alpha = \frac{\pi}{2} - \tan^{-1}\left(\frac{21}{65}\right) = 1.242 \text{ rad}$$

$$A_B = \frac{3.37}{12} \times 2\alpha R = \frac{3.37}{12} \times 2 \times 1.242 \times 65 = 45.34 \text{ in}^2$$

C.O.G. of yielded steel in compression in respect to the cross-section center line (page 69 in Ref. 12):

$$c.o.g. = \frac{2R \sin \alpha}{3\alpha} \left(1 - \frac{t}{R} + \frac{1}{2-t/R}\right) = \frac{2 \times 70 \times \sin(1.242)}{3 \times 1.242} \left(1 - \frac{10}{70} + \frac{1}{2-10/70}\right) = 49.63 \text{ in}$$

$$M_T = (22 + 49.63) \times A_B \times f_y = 71.63 \times 45.34 \times 40000 = 130 \times 10^6 \text{ in-lb}$$

Moment due to compression in steel which does not yield:

$$A_S = 2 \times (22 + 21) \times \frac{3.37}{12} = 24.15 \text{ in}^2$$

$$M_i \approx \frac{2}{3} (22 + 21) \times A_S \times f_y = \frac{2}{3} \times 43 \times 24.15 \times 40000 = 27.7 \times 10^6 \text{ in-lb}$$

Moment due to tension in steel:

$$dA_s = \frac{A_s}{\cup AB} R(d\alpha) \quad f_\alpha = \frac{f_y}{43} (65 \cos \alpha - 22)$$

$$\text{Total } A_s = 3.37 \times (\cup AB) = \frac{3.37 \times 160}{12} = 45 \text{ in}^2$$

$$dT = f_\alpha \times (dA_s) = \frac{f_y}{43} (65 \cos \alpha - 22) \times \frac{A_s}{\cup AB} R(d\alpha) = \bar{T} \times (65 \cos \alpha - 22) \times (d\alpha)$$


$$\text{where } \bar{T} \text{ is defined as } \bar{T} = \frac{f_y}{43} \times \frac{A_s}{\cup AB} \times R = \frac{40000 \times 45 \times 65}{43 \times 160} = 17000 \text{ lb/in}$$

$$dM_T = dT \times 65 \cos \alpha = \bar{T} (65^2 \cos^2 \alpha - 1430 \times \cos \alpha) \times d\alpha$$

$$M_T = 0.9 \times 2 \int_0^{\alpha_s} dM_T = 0.9 \times 2 \bar{T} \left\{ 65^2 \left[\frac{\alpha}{2} + \frac{1}{4} \sin 2\alpha \right]_0^{\alpha_s} - 1430 \left[\sin \alpha \right]_0^{\alpha_s} \right\}$$

$$= 0.9 \times 2 \bar{T} \left[65^2 \left(\frac{1.23}{2} + \frac{0.637}{4} \right) - 1430 \times 0.941 \right] = 58.9 \times 10^6 \text{ in-lb}$$

$$\text{Total moment capacity } M = \frac{(191 + 130 + 27.7 + 58.9) \times 10^6}{10^3 \times 12} = 33,967 \text{ k-ft}$$

 Stevenson & Associates a structural-mechanical consulting engineering firm	CAL. NO. 91C2683 C-020 SUBJECT: Kewaunee A-46/IPEEE	SHEET # 7 of 13 Revision 0
	Fragility Analysis of the Circulating Water Intake and Discharge Piping	By MSL 5/20/94 Chk. TMT 5/25/94

Shear strength capacity is calculated as for 'shear and flexure only' in a beam with a thin-wall circular cross-section with shear reinforcement.

C.O.G. of steel A_s in respect to the cross-section center line:

$$\text{c.o.g.} = \frac{2 \int_0^{\alpha_s} dA_s(R \cos \alpha)}{A_s} = \frac{2 \int_0^{\alpha_s} \frac{A_s}{\cup AB} R(d\alpha)R \cos \alpha}{A_s} = \frac{2R^2 \sin \alpha_s}{\cup AB} = \frac{2 \times 65^2 \sin 70.22^\circ}{160} = 49.7 \text{ in}$$

$$d = 49.7 + 70 = 119.7 \text{ in}$$

Circumferential reinforcement (two cages with two bar cross-sections):

$$\text{outside cage } \frac{A_v}{s} = 2 \times 1.92 = 3.84 \text{ in}^2/\text{ft}$$

$$\text{inside cage } \frac{A_v}{s} = 2 \times 1.44 = 2.88 \text{ in}^2/\text{ft}$$

$$\text{total } \frac{A_v}{s} = 6.72 \text{ in}^2/\text{ft}$$

$$\text{From Ref. 9: } V_s = \frac{A_v f_y d}{s} = \frac{6.67 \times 40000 \times 119.7}{12 \times 10^3} = 2680 \text{ kip}$$

The flexure-shear cracking load concept has been used similarly to that for rectangular beams (page 121 of Ref. 4 and Section 11.3.2.1 of Ref. 5).

$$\frac{V_{ud}}{M_u} = \frac{1250 \times d}{13950} = \frac{1250 \times 119.7}{13950 \times 12} = 0.89$$

$$\text{Total } A_s = 3.37 \times \frac{130\pi}{12} + \frac{\pi \times 0.288^2}{4} \times 60 = 118.6 \text{ in}^2$$

where 0.288 in is stirrup diameter and 60 is total number of stirrups (Drwg. No. XK-200-102).

$$A_s = \frac{\pi(140^2 - 120^2)}{4} = 4080 \text{ in}^2 \quad \rho = \frac{118.6}{4080} = 0.029$$


$$v_c = 19\sqrt{f_c'} + 2500\rho \frac{V_{ud}}{M_u} \leq 3.5\sqrt{f_c'}$$

$$v_c = 1.9\sqrt{3000} + 2500 \times 0.029 \times 0.89 = 168 \text{ psi} < 3.5\sqrt{3000} = 190 \text{ psi}$$

Factor $k = 1.5$ for the ratio of the maximum shear stress to the average shear stress V/A_c (page 173 of Ref. 6) is likely to have been taken into consideration in the formula for v_c above. To adjust this formula for a thin-wall circular cross-section the factor $k=2$ should be used. The ratio of $2/1.5$ probably would do the adjustment but since the formula for v_c is based primarily on the experimental information the factor of $k = 2$ is used here for conservatism.

$$\text{Shear capacity } V_c = \frac{v_c A_c}{2} = \frac{168 \times 4080}{2 \times 10^3} = 343 \text{ kip}$$

$$\text{Total shear capacity } V = 0.85(2680 + 343) = 2570 \text{ kip}$$

 Stevenson & Associates a structural-mechanical consulting engineering firm	CAL. NO. 91C2683 C-020 SUBJECT: Kewaunee A-46/IPEEE	SHEET # 8 of 13 Revision 0
	Fragility Analysis of the Circulating Water Intake and Discharge Piping	By MSL 5/20/94 Chk. TMT 5/25/94

Moment and Shear Capacities of Intake Pipe

Steel pipe with thickness of 7/8"

Moment capacity:

$$S = \pi (60 + 0.5 \times 7/8)^2 \times 7/8 = 10040 \text{ in}^3$$

Assume $F_y \geq 36$ ksi Then the allowable stress $\geq 1.7 \times 0.6 F_y \approx F_y = 36$ ksi

Moment capacity is evaluated as $M = 36 \times 10040 = 361 \times 10^3 \text{ kip-in} = 30000 \text{ kip-ft}$

Shear capacity:

$$A = 2 \pi (60 + 0.5 \times 7/8) \times 7/8 = 332.3 \text{ in}^2$$

Assume $F_y \geq 36$ ksi Then the allowable stress $\geq 1.7 \times 0.4 F_y = 24.5$ ksi

Shear capacity with shear shape factor of 2 is evaluated as $V = 24.5 \times 332.3 / 2 = 4070 \text{ kip}$

Steel pipe with thickness of 5/8"

Moment capacity:

$$S = \pi (60 + 0.5 \times 5/8)^2 \times 5/8 = 7142 \text{ in}^3$$

Assume $F_y \geq 36$ ksi Then the allowable stress $\geq 1.7 \times 0.6 F_y \approx F_y = 36$ ksi

Moment capacity is evaluated as $M = 36 \times 7142 = 257 \times 10^3 \text{ kip-in} = 21400 \text{ kip-ft}$

Shear capacity:

$$A = 2 \pi (60 + 0.5 \times 5/8) \times 5/8 = 237 \text{ in}^2$$

Assume $F_y \geq 36$ ksi Then the allowable stress $\geq 1.7 \times 0.4 F_y = 24.5$ ksi

Shear capacity with shear shape factor of 2 is evaluated as $V = 24.5 \times 237 / 2 = 2900 \text{ kip}$



Stevenson and Associates

A Structural-Mechanical
Consulting Engineering Firm

CLIENT	WPSC	JOB No.	91C-683	SHEET	9 OF 13
SUBJECT	KAWKING AFD / IPEE				
	Fragility Analysis of the Circulating				
	Water Piping				
	C-020				
REVISIONS	0	MSL: 5/20/94			
		TMT 5/24/94			

Stress Calculation Due to Traveling Seismic Wave

(1) Axial strain due to traveling seismic wave

Shear $\epsilon_{max,s} = \frac{V_{max}}{2C_s} = \frac{147/12}{2 \times 1613} = 3.8 \times 10^{-4}$

Compressional

$\epsilon_{max,p} = \frac{V_{max}}{C_p} = \frac{147/12}{3000} = 4.08 \times 10^{-4}$

Rayleigh

$\epsilon_{max,R} = \frac{V_{max}}{C_R} = \frac{147/12}{1500} = 8.16 \times 10^{-4}$

(2) Bending strain (Curvature) due to traveling seismic wave

Shear $\kappa_{max,s} = \frac{a_{max}}{C_s^2} = \frac{0.306 \times 32}{1613^2} = 3.76 \times 10^{-6} \frac{1}{ft}$

Compressional

$\kappa_{max,p} = \frac{a_{max}}{(1.6C_p)^2} = \frac{0.306 \times 32}{(1.6 \times 3000)^2} = 1.25 \times 10^{-7} \frac{1}{ft}$

Rayleigh

$\kappa_{max,R} = \frac{a_{max}}{C_R^2} = \frac{0.306 \times 32}{1500^2} = 1.35 \times 10^{-6} \frac{1}{ft}$

(3) Maximum Axial Strain/Stress and Bending Moment

Discharge Piping

Axial Tension / Compression Strain

$\epsilon_{max} = \max\{\epsilon_{max,s}, \epsilon_{max,p}, \epsilon_{max,R}\} = 8.16 \times 10^{-4} < \text{concrete rupture strain } 0.003$

Bending Moment

$M = E_c I_g \max\{\kappa_{max,s}, \kappa_{max,p}, \kappa_{max,R}\} = 3.1 \times 10^9 \text{ ksi} \times 8.7 \times 10^6 \frac{1}{12} \times 1.35 \times 10^{-6} = 9.777 \text{ kip-in.}$

Intake Piping

Axial tension / compression stress

$\sigma_a = E_s \max\{\epsilon_{max,s}, \epsilon_{max,p}, \epsilon_{max,R}\} = 30 \times 10^3 \text{ ksi} \times 8.16 \times 10^{-4} = 24.48 \text{ ksi}$

Bending Moment

$\sigma_b = E_s R \max\{\kappa_{max,s}, \kappa_{max,p}, \kappa_{max,R}\} = 30 \times 10^3 \text{ ksi} \times (60 + \frac{7}{8}) \times 1.35 \times 10^{-6} = 0.66 \text{ ksi}$



Stevenson and Associates

A Structural-Mechanical Consulting Engineering Firm

CLIENT WPSC JOB No. 91C2083 SHEET 10 OF 13

SUBJECT KAWANUKA AFG/FREE
Fragility Analysis of the Circulating
Water Piping
C-020

REVISIONS	0	MSL: 5/20/94
		TMT 5/24/94

Stress Calculation Due to Seismically Induced Transient Horizontal Displacement of Penetrations

(1) Axial Movement

Discharge pipe

Tension / compression

$$\sigma_c = \frac{P}{A} \text{ where } P = \sqrt{2 E_c A_c f \delta} \quad (\text{Equation 44 in Ref. 3})$$

average depth below grade

$$f = 237 D h = 237 \cdot (10' + 20'/2) \cdot 15'$$

$$= 41.5 \times 10^3 \text{ lb/ft} = 3.5 \text{ kips/in}$$

$$A_c = 4084 \text{ in}^2$$

$$\delta = 0.58 \text{ inches for PGA} = 0.45g$$

$$E_c = 31 \times 10^3 \text{ ksi}$$

$$\sigma_c = \frac{\sqrt{2 \times 31 \times 10^3 \times 4084 \times 3.5 \times 0.58}}{4084} = 1.76 \text{ ksi}$$

$$\text{and } P/f = 170 \text{ ft} < \text{length of pipe} = 276 \text{ ft.}$$

Intake Pipe ($t = 7/8"$)

Tension / compression

$$A_s = 2 R t = 27 \cdot 5 \times 12 \cdot 7/8 = 330 \text{ in}^2$$

$$f = 237 D \cdot h = 237 \cdot 10 \times 10 \text{ average depth below grade}$$

$$= 23.7 \times 10^3 \text{ lb/ft}$$

$$= 1.98 \text{ kip/in}$$

$$\sigma_c = \frac{\sqrt{2 \times 30 \times 10^3 \times 330 \times 1.98 \times 0.58}}{330} = 17.45 \text{ ksi}$$

$$\text{and } P/f = 220 \text{ ft} < \text{length of pipe} = 1000 \text{ ft}$$

(2) Lateral Movement

Discharge Pipe

$$M_d = \frac{R \delta}{2 \Delta^2} \text{ and } V_d = \frac{R}{\Delta} f \delta \quad (\text{Equations 45 \& 46 in Ref. 3})$$

$$\text{where } R = R D = 216 \text{ kcf} \cdot (10' + 20'/2) = 2520 \text{ kcf}$$

$$\Delta = \frac{R}{\sqrt{2 E I}} = \frac{2520 \text{ kcf/ft}}{\sqrt{4 \times 31 \times 10^3 \text{ ksi} \cdot 87 \times 10^6 \text{ in}^4}} = 0.0036 \frac{1}{\text{in}}$$

$$\delta = 0.58 \text{ inches for PGA} = 0.45g$$

$$M_d = \frac{2520 \text{ kcf/ft} \cdot 0.58 \text{ in}}{2 \cdot (0.0036 \frac{1}{\text{in}})^2} = 391600 \text{ kip-in} = 32632 \text{ kft}$$

$$V_d = \frac{2520 \text{ kcf/ft} \cdot 0.58}{0.0036} = 2819 \text{ kips}$$



Stevenson and Associates

A Structural-Mechanical Consulting Engineering Firm

CLIENT	WPCSC	JOB No.	91C-0683	SHEET	11	OF	13
SUBJECT	KAWAUNA AAS / IREEE						
	Fragility Analysis of the Circulating						
	Water Piping						
	C-020						
REVISIONS	0	MSL 5/20/94					
		TMT 5/24/94					

Intake Pipe (thickness = 7/8")

$$M_d = \frac{R \delta}{2 \lambda^2} \quad \text{and} \quad V_d = \frac{R \delta}{\lambda}$$

$$\text{where } R = R_0 D = 216 \times 10 = 2160 \text{ ksf}$$

$$\lambda = \sqrt[4]{\frac{R}{4EI}} = \sqrt[4]{\frac{2160/144}{4 \times 30 \times 10^3 \times 60 \times 60}} = 0.0038 \text{ in}^{-1}$$

$$M_d = \frac{2160/144 \times 0.58}{2 \times (0.0038)^2} = 30,250 \text{ kip-ft} = 25,100 \text{ kip-ft}$$

$$V_d = \frac{2160/144 \times 0.58}{0.0038} = 2290 \text{ kips}$$

CDFM Analysis

Capacity of Discharge Pipe

Compression/Tension: As indicated in Drawing # XK-200-101, the concrete pipe is free to slide several inches at each expansion joint.

Moment: 33,967 kip-ft

Shear: 2570 kips

Capacity of Intake Pipe

compression/tension: $\sigma_a = \tau_y = 36 \text{ ksi}$

Moment: 30,000 kip-ft

Shear: 4070 kips


The controlling section is the discharge concrete pipe at penetration.

THUR CDFM = $F \frac{\sigma_u}{\sigma_{CRE}} S_{CRE}$ where $F =$ ductility factor (1.25 if ductile failure, 1.0 if brittle)
 $\sigma_u =$ ultimate capacity applicable to HCLPE calculation
 $\sigma_{CRE} =$ calculated stress due to IREEE BLE
 $S_{CRE} =$ Max. Ground Accel. of IREEE BLE

$$\text{Moment: CDFM} = 1.0 \times \frac{33967}{32632} \times 0.45g = 0.47g$$

$$\text{Shear: CDFM} = 1.0 \times \frac{2570}{2819} \times 0.45g = 0.41g \quad \leftarrow \text{In Control}$$

91C2683-C020
 sheet 12 of 13



- ooooo Amax = 0.14g
- Amax = 0.30g
- ▶▶▶▶▶ Amax = 0.40g
- ◇◇◇◇◇ Amax = 0.50g
- +++++ Amax = 0.60g
- ***** Amax = 0.70g

Stevenson & Associates Woburn, Massachusetts	Soil Failure Analysis Kewaunee IPEEE Carlton, Wisconsin	SHAKE RESULTS STIFF PROFILE
GEI Consultants, Inc.	Project 92151	March 1994 Fig. 9

91C2683-C020
sheet 13 of 13

TABLE 3 - SINGLE-AMPLITUDE AND DIFFERENTIAL TRANSIENT
DISPLACEMENTS (INCHES) FOR PEAK GROUND
SURFACE ACCELERATION OF 0.7 g, STIFF SOIL PROFILE¹⁾
Kewaunee IPEEE
Carlton, Wisconsin

	Single-Amplitude Displacement (inches)	Differential Displacements (inches)			
		Ground Surface	Screenhouse Structure	Turbine and Auxiliary Buildings	Reactor Building
Ground Surface	1.2	0	1.7	2.2	2.1
Screenhouse Structure	0.5	1.7	0	1.5	1.4
Turbine and Auxiliary Buildings	1.0	2.2	1.5	0	1.9
Reactor Building	0.9	2.1	1.4	1.9	0

Note:

- 1) Results for very stiff soil profile are much smaller.

SCREENING EVALUATION WORK SHEET (SEWS)		GIP Rev 2, Corrected, 2/14/92 Status: Yes Sheet 1 of 2
ID : 153-021 (Rev. 0)	Class : 21 - Tanks and Heat Exchangers	
Description : TANK-REFUELING WATER STORAGE TANK		
Building : AUX	Floor El. : 586.00	Room, Row/Col : 5.0/H.0
Manufacturer, Model, Etc. :		

BASIS : External analysis

1. The buckling capacity of the shell of a large, flat-bottom, vertical tank is equal to or greater than the demand.	Yes
2. The capacity of the anchor bolts and their embedments is equal to or greater than the demand.	Yes
3. The capacity of connections between the anchor bolts and the tank shell is equal to or greater than the demand.	Yes
4. Attached piping has adequate flexibility to accommodate the motion of a large, flat-bottom, vertical tank.	Yes
5. A ring-type foundation is not used to support a large, flat-bottom, vertical tank.	Yes

IS EQUIPMENT SEISMICALLY ADEQUATE?

Yes

COMMENTS

Tank is braced with 16 lateral braces, 1 per quadrant on approx 20 ft increments.

Anchorage: is 8 approx. 7/8" diameter. Bolt chairs are flat plate welded to gussets on both sides. Some minute cracking noted in base pad.

No hazards for tank and no cracked concrete.

It is a well braced tank. No overturn moment and base shear are created under seismic loading. Thus, base anchorage, bolt chairs and tank shell buckling do not need to be reviewed.

Two items which needed to be reviewed were the integrity of brace structure under seismic loads and the freeboard clearance vs. slosh height. For tank analysis, see S&A calculation # C-018 Appendix G.

Evaluated by:

Date:

Attachment: Pictures

SCREENING EVALUATION WORK SHEET (SEWS)

GIP Rev 2, Corrected, 2/14/92
Status: Yes
Sheet 2 of 2

ID : 153-021 (Rev. 0)

Class : 21 - Tanks and Heat Exchangers

Description : TANK-REFUELING WATER STORAGE TANK

Building : AUX

Floor El. : 586.00

Room, Row/Col : 5.0/H.0

Manufacturer, Model, Etc. :

PICTURES



Figure 1 : 153-021




Figure 2 : Anchor for 153-021



Figure 3 : 153-021