

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9306020391 DOC. DATE: 93/05/24 NOTARIZED: YES DOCKET #
FACIL: 50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Service 05000305
AUTH. NAME AUTHOR AFFILIATION
STEINHARDT, C.R. Wisconsin Public Service Corp.
RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Suppls Proposed Amend 103 to License DPR-43, submitted on
910628, per 930519 telcon w/NRC, revising TS 3.1.c.2.C re
limit for primary coolant dose equivalent I-131 activity.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+44
TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD3-3 LA HANSEN, A.	1 1 2 2	PD3-3 PD	1 1
INTERNAL:	ACRS	6 6	NRR/DE/EELB	1 1
	NRR/DORS/OTSB	1 1	NRR/DRCH/HICB	1 1
	NRR/DSSA/SPLB	1 1	NRR/DSSA/SRXB	1 1
	NUDOCS-ABSTRACT	1 1	OC/EFMB	1 0
	OGC/HDS1	1 0	REG FILE 01	1 1
EXTERNAL:	NRC PDR	1 1	NSIC	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 21 ENCL 19

R
I
D
S
/
A
D
D
S
/
A
D
D
S

AA 2
2/17

WPSC (414) 433-1598
TELECOPIER (414) 433-5544



NRC-93-087
EASYLINK 62891993

WIBCONSIN PUBLIC SERVICE CORPORATION

600 North Adams • P.O. Box 19002 • Green Bay, WI 54307-9002

May 24, 1993

10 CFR 50.90

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Ladies/Gentlemen:

Docket 50-305
Operating License DPR-43
Kewaunee Nuclear Power Plant
Proposed Amendment 103 to the Kewaunee
Nuclear Power Plant Technical Specifications

Proposed Amendment (PA) 103 was submitted to the NRC staff on June 28, 1991, to incorporate a limit for primary coolant DOSE EQUIVALENT I-131 activity into the Kewaunee Technical Specifications (TSs). This PA also included surveillance requirements and required action statements for DOSE EQUIVALENT I-131 analogous to those in the Westinghouse Standard TSs.

During a telephone conversation on May 19, 1993, between the NRC project manager and WPSC, the staff requested that we consider proposing an increased RCS sampling frequency if the reactor coolant specific activity exceeds ${}^{91}_{\text{E}} \mu\text{ci}/\text{cc}$ gross radioactivity.

To incorporate this request, proposed TS 3.1.c.2.C has been revised to state: "With the specific activity of the reactor coolant $> 1.0 \mu\text{ci}/\text{gram}$ DOSE EQUIVALENT I-131 or $> {}^{91}_{\text{E}} \mu\text{ci}/\text{cc}$ perform the sample and analysis requirements of Table TS 4.1-2, item f, once every 4 hours until restored to within its limits."

9306020391 930524
PDR ADOCK 05000305
P PDR


ADD 1

Document Control Desk
May 24, 1993
Page 2

In addition, since originally submitting PA 103, several TS amendments have been approved which revised the same sections. Therefore, all sections affected by PA 103 are being resubmitted at this time.

In accordance with the requirements of 10 CFR 50.30(b), this has been signed and notarized. A complete copy of this submittal has been transmitted to the State of Wisconsin as required by 10 CFR 50.91(b)(1).

Sincerely,




C. R. Steinhardt
Senior Vice President - Nuclear Power

SLB/cjt

Attach.

cc - US NRC - Region III
NRC Senior Resident
Mr. R. S. Cullen, PSCW

Subscribed and Sworn to
Before Me This 24th Day
of May 1993


Notary Public, State of Wisconsin

My Commission Expires:

June 18, 1995