

PRIORITY 1
ACCELERATED RIDS PROCESSING

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9409190177 DOC. DATE: 94/09/07 NOTARIZED: YES DOCKET #
 FACIL: 50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Service 05000305
 AUTH. NAME AUTHOR AFFILIATION
 STEINHARDT, C.R. Wisconsin Public Service Corp.
 RECIP. NAME RECIPIENT AFFILIATION

Document Control Branch (Document Control Desk) *see Reports*

SUBJECT: Application for amend to license DPR-43, consisting of
 Proposed Amend 132, incorporating guidance statements similar
 to Section 3.0/4.0 from NUREG-0452, "STS for Westinghouse
 PWRs" into TS.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 9+36
 TITLE: OR Submittal: General Distribution

NOTES:

| | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL |
|-----------|---------------------------|---------------------|---------------------------|---------------------|
| | PD3-3 LA LAUFER, R | 1 1 2 2 | PD3-3 PD | 1 1 |
| INTERNAL: | ACRS | 6 6 | <u>FILE CENTER 0.2</u> | 1 1 |
| | NRR/DE/EELB | 1 1 | NRR/DRCH/HICB | 1 1 |
| | NRR/DRPW | 1 1 | NRR/DSSA/SPLB | 1 1 |
| | NRR/DSSA/SRXB | 1 1 | NUDOCS-ABSTRACT | 1 1 |
| | OC/LFDCB | 1 0 | OGC/HDS2 | 1 0 |
| EXTERNAL: | NOAC | 1 1 | NRC PDR | 1 1 |

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
 DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 21 ENCL 19

P
R
I
O
R
I
T
Y

1

D
O
C
U
M
E
N
T



WISCONSIN PUBLIC SERVICE CORPORATION

600 North Adams • P.O. Box 19002 • Green Bay, WI 54307-9002

September 7, 1994

U.S. Nuclear Regulatory Commission
Attention Document Control Desk
Washington, D.C. 20555

10 CFR 50.90

Gentlemen:

Docket 50-305
Operating License DPR-43
Kewaunee Nuclear Power Plant
Proposed Amendment 132 to the Kewaunee
Nuclear Power Plant Technical Specifications

In an effort to improve the quality of the Kewaunee Nuclear Power Plant Technical Specifications (TS), this Proposed Amendment is being submitted to incorporate guidance statements similar to Section 3.0/4.0 from NUREG-0452, Standard Technical Specifications (STS) for Westinghouse Pressurized Water Reactors, into the Kewaunee TS. Two new sections, TS Section 3.0 and TS Section 4.0, will be created. TS Section 3.0 establishes the general requirements applicable to each of the Limiting Conditions for Operation (LCO) within Section 3 of the KNPP TS's. TS Section 4.0 establishes the general requirements applicable to Surveillance Requirements. New basis sections for TS Section 3.0 and 4.0 were also developed and are being submitted for your information.

The frequency notations on Table 1.0-1 are also being revised to resemble the format of the Westinghouse STS. Additionally, specific maximum allowable time extensions to various surveillance intervals are being deleted throughout the TS. New TS 4.0.b, which states the maximum allowable extension is not to exceed 25 percent of the specified surveillance interval, will apply to TS Section 4 in its entirety. Affected sections include TS Section 4.5, 4.6, and 4.7, and Tables TS 4.1-2, and 4.1-3.

Administrative changes are also being made to convert these sections to the Word Perfect format and correct minor typographical and format inconsistencies. Among these changes are renumbering the basis section pages and capitalizing the defined words similar to Westinghouse STS. The practice of renumbering basis section pages and capitalizing defined terms will be

9409190177 940907
PDR ADOCK 05000305
PDR

Aool
111

Document Control Desk
September 7, 1994
Page 2


incorporated throughout the TS as each section is revised and converted to the Word Perfect format. This is part of an ongoing effort to revise each section of the KNPP TS to achieve a consistent format.

Please note PA 109 and PA 127 also affect this proposed amendment. The technical changes associated with PA's 109 and 127 are not included with this submittal.

Attachment 1 to this letter contains a description, a safety evaluation, a significant hazards determination, and environmental considerations for the proposed changes. Attachment 2 contains the affected TS pages.

In accordance with the requirements of 10 CFR 50.30(b), this submittal has been signed and notarized. A complete copy of this submittal has been transmitted to the State of Wisconsin as required by 10 CFR 50.91(b)(1).

Sincerely,




Clark R. Steinhardt
Senior Vice President - Nuclear Power

BJD/san

Attach.

cc - US NRC - Region III
Mr. James Heller, US NRC
Mr. R. S. Cullen, PSCW

Subscribed and Sworn to
Before Me This 7th Day
of September 1994


Notary Public, State of Wisconsin

My Commission Expires:
June 18, 1995