

PRIORITY 1
ACCELERATED RIDS PROCESSING

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9501310217 DOC. DATE: 95/01/23 NOTARIZED: YES DOCKET #
 FACIL: 50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Service 05000305
 AUTH. NAME AUTHOR AFFILIATION
 STEINHARDT, C.R. Wisconsin Public Service Corp.
 RECIPIENT NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Application for amend to license DPR-43, modifying TS 3.1.b.1
 & Figure TS 3.1-4 re LTOP for RCPB.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3740
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD3-3 LA		1	1		PD3-3 PD		1	1
	LAUFER, R		1	1					
INTERNAL:	ACRS		6	6	<u>FILE CENTER 01</u>		1	1	
	NRR/DRCH/HICB		1	1	NRR/DSSA/SPLB		1	1	
	NRR/DSSA/SRXB		1	1	NUDOCS-ABSTRACT		1	1	
	OGC/HDS2		1	0					
EXTERNAL:	NOAC		1	1	NRC PDR		1	1	

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
 DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 17 ENCL 16

P
R
I
O
R
I
T
Y

1

D
O
C
U
M
E
N
T



WISCONSIN PUBLIC SERVICE CORPORATION

600 North Adams • P.O. Box 19002 • Green Bay, WI 54307-9002

January 23, 1995

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Ladies/Gentleman:

Docket 50-305
Operating License DPR-43
Kewaunee Nuclear Power Plant
Proposed Amendment 134 to the Kewaunee
Power Plant Technical Specifications

References: 1) Letter from C.R. Steinhardt (WPSC) to Document Control Desk (NRC)
dated August 24, 1994

Currently, the Nuclear Regulatory Commission (NRC) is reviewing proposed amendment 134 (PA) to the Kewaunee Nuclear Power Plant (KNPP) Technical Specifications (TS) to modify TS 3.1.b.1 and Figure TS 3.1-4 regarding Low Temperature Overpressure (LTOP) protection for the reactor coolant pressure boundary. During the NRC review of this PA, the NRC Project Manager for KNPP requested a copy of WCAP-14042 to aid the staff in their review. WCAP-14042 provides the results from recent drop weight testing conducted to determine the nil ductility transition temperature (NDTT) of a test weld representative of the limiting circumferential weld in the KNPP reactor vessel.

In response to your request, this letter transmits WCAP-14042 Revision 1, titled, "Kewaunee Weld Drop Weight Test Program Results." The original version of this report was initially issued as Westinghouse Proprietary Class 2C and has since been reprinted in its entirety without technical changes as a non-proprietary document.

270077

g:\wpfiles\lic\nrc\pa134a.wp

9501310217 950123
PDR ADOCK 05000305
P PDR

Flood
1/11

Document Control Desk
January 23, 1995
Page 2

In accordance with the requirements of 10 CFR 50.30(b), this submittal has been signed and notarized. A complete copy of this submittal has been transmitted to the State of Wisconsin as required by 10 CFR 50.91(b)(1). Should you require any additional information or clarification for your review, please contact a member of my staff.

Sincerely,

C.A. Schrock
for

C. R. Steinhardt
Senior Vice President - Nuclear Power

CAT/san

Attach.

cc - US NRC - Region III - w/o attach.
US NRC Senior Resident Inspector - w/o attach.
Mr. R. S. Cullen, PSCW

Subscribed and Sworn to
Before Me This 23rd Day
of January 1995

Jeanne M. Ferris
Notary Public, State of Wisconsin

My Commission Expires:

June 18, 1995

ATTACHMENT 1

To

Proposed Amendment No. 134

Letter from C. R. Steinhardt (WPSC)

To

Document Control Desk (NRC)

Dated

January 23, 1995

WCAP-14042 Revision 1

Kewaunee Weld Drop Weight Test Program Results