CATEGORY 1

REGULATION DISTRIBUTION YSTEM (RIDS)

ACCESSION NBR:9609050090 DOC.DATE: 96/08/28 NOTARIZED: YES DOCKET # FACIL:50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Servic 05000305

AUTH.NAME AUTHOR AFFILIATION
STEINHARDT, C.R. Wisconsin Public Service Corp.

RECIP.NAME RECIPIENT AFFILIATION

Document Control Branch (Document Control Desk)

Т

D

IJ

M

E

N

Т

SUBJECT: Provides clarification to proposed TS amend request re steam generator tubesheet region alternate repair criteria.

DISTRIBUTION CODE: A001D COPIES RECEIVED:LTR __I ENCL \ SIZE: 2 + 5

TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT	COPIES		RECIPIENT	COPIES		E
	ID CODE/NAME PD3-3 LA	LTTR	ENCL	ID CODE/NAME PD3-3 PD		ENCL	G
	LAUFER,R	1	1	PD3-3 PD	1	1	0
INTERNAL:	ACRS NRR/DE/EMCB NRR/DSSA/SPLB NUDOCS-ABSTRACT	1 1 1	1 1 1	PILE CENTER 01 NRR/DRCH/HICB NRR/DSSA/SRXB OGC/HDS2	1 1 1	1 1 1 0	R Y
EXTERNAL:	NOAC	1	ĺ	NRC PDR	1	1	1

NOTE TO ALL "RIDS" RECIPIENTS: PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM OWFN 5D-5(EXT. 415-2083) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 13 ENCL 12



WISCONSIN PUBLIC SERVICE CORPORATION

600 North Adams • P.O. Box 19002 • Green Bay, WI 54307-9002

August 28, 1996

10 CFR 50.90

U.S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, D.C. 20555

Ladies/Gentlemen:

Docket 50-305
Operating License DPR-43
Kewaunee Nuclear Power Plant
Proposed Amendment 142a to the Kewaunee Nuclear Power Plant Technical Specifications:
F*/EF* Steam Generator Tubesheet Region Alternate Repair Criteria

Reference: Letter from C.R. Steinhardt (WPSC) to Document Control Desk (NRC) dated July 3, 1996.

On July 3, 1996, Wisconsin Public Service Corporation (WPSC) submitted a Technical Specification (TS) amendment request to revise the acceptance criteria for indications of tube degradation occurring in the tubesheet crevice region of the Kewaunee steam generators (SG). Based on subsequent discussions with the NRC staff, minor administrative changes are required to clarify some of the points in the proposed TS. The following revisions are being proposed:

- Throughout the proposed TS the wording on NDE uncertainty is being revised to state, "plus an allowance for NDE uncertainty,"
- The definition of EF* Distance is being revised to clarify that the distance applies from the bottom of the uppermost roll transition,
- The definition of EF* Tube is being revised to correct an administrative error,
- Proposed TS 4.2.b.2.d is being revised to delete the statement "or until it is determined that the identified degradation has ceased," and
- The basis section has been revised to define the NDE uncertainty value that will be used in conjunction with determining the minimum F* and EF* length.

1/1 Koop

9609050090 960828 PDR ADBCK 05000305 PDR Document Control Desk August 28, 1996 Page 2

Pages TS 4.2-3, 4.2-4, 4.2-8 and B4.2-5 are affected by this change and are included as Attachment 1. These changes do not alter the previously submitted safety evaluation or significant hazards determination.

In accordance with the requirements of 10 CFR 50.36(b), this submittal has been signed and notarized. A copy of this submittal has been transmitted to the State of Wisconsin as required by 10 CFR 50.91(b)(1). Please feel free to contact a member of my staff if you have any questions or require additional information.

Sincerely,

Clark R. Steinhardt 3

Senior Vice President - Nuclear Power

SLB

Attach.

cc - US NRC - Region III
US NRC Senior Resident Inspector
Mr. Lanny Smith, PSCW

Subscribed and Sworn to

Before Me This 28th Day

Planne M. Ferris Notary Public, State of Wisconsin

My Commission Expires:

June 13, 1999