

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9301280292 DOC. DATE: 93/01/22 NOTARIZED: NO DOCKET #
 FACIL: 50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Service 05000305
 AUTH. NAME AUTHOR AFFILIATION
 SCHROCK, C.A. Wisconsin Public Service Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Submits response to request for addl info re IST relief request RR-6A.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: OR Submittal: Inservice Inspection/Testing/Relief from ASME Code

NOTES:

	RECIPIENT	COPIES	RECIPIENT	COPIES
	ID CODE/NAME	LTR ENCL	ID CODE/NAME	LTR ENCL
	PD3-3 LA	1 0	PD3-3 PD	1 1
	HANSEN, A.	2 2		
INTERNAL:	ACRS	6 6	NRR/DET/ECMB 9H	1 1
	NRR/DET/EMEB 7E	1 1	NUDOCS-ABSTRACT	1 1
	OC/LEMB	1 0	OGC/HDS1	1 0
	<u>REG FILE</u> 01	1 1	RES MILLMAN, G	1 1
	RES/DSIR/EIB	1 1		
EXTERNAL:	EG&G BROWN, B	1 1	EG&G RANSOME, C	1 1
	NRC PDR	1 1	NSIC	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 22 ENCL ~~19~~ 0

MAY 4
dbp

R
I
D
S
/
A
D
D
S
/
A
D
D
S

WPSC (414) 433-1598
TELECOPIER (414) 433-5544



EASYLINK 62891993

WISCONSIN PUBLIC SERVICE CORPORATION

600 North Adams • P.O. Box 19002 • Green Bay, WI 54307-9002

January 22, 1993

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Ladies/Gentlemen:

Docket 50-305
Operating License DPR-43
Kewaunee Nuclear Power Plant
Response to Request for Information Regarding IST Relief Request RR-6A

- References:
- 1) Letter from C. R. Steinhardt (WPSC) to Document Control Desk (NRC) dated July 17, 1992
 - 2) Letter from A. G. Hansen (NRC) to C. A. Schrock (WPSC) dated October 15, 1992

On July 17, 1992, Wisconsin Public Service Corporation (WPSC) submitted Revision J of the Inservice Testing (IST) Plan for Pumps and Valves for the Kewaunee Nuclear Power Plant to the NRC for review and approval (reference 1). Upon review, the NRC determined that additional information was required to evaluate Relief Request RR-6A. The NRC requested a response within 60 days (reference 2); however, on December 23, 1992, Mr. Allen G. Hansen of your staff agreed that a January 22, 1993, submittal would be acceptable.

260022

LIC/NRC/RR-6A.WP

9301280292 930122
PDR ADDOCK 05000305
P PDR

ADAM 1/0

Document Control Desk
January 22, 1993
Page 2

Subsequent to the NRC's request for additional information, WPSC re-evaluated the use and testing requirements for the valves in question, SA-471 and SA-472. WPSC has determined that these valves are active and therefore are required to be exercise tested on a quarterly basis in accordance with Section XI of the ASME Boiler and Pressure Vessel Code. WPSC plans to collect base-line data to verify full closure capability during the upcoming refueling outage. Quarterly exercise testing will continue subsequent to the 1993 refueling outage. Because WPSC plans to meet the requirements of Section XI, Relief Request RR-6A is being withdrawn. Appropriate changes will be made to the IST Plan and submitted to the NRC with the next revision to the plan. If you have any further questions regarding this matter, please contact a member of my staff.

Sincerely,



C. A. Schrock
Manager-Nuclear Engineering

KPH/jac

cc - US NRC - Region III
Mr. Patrick Castleman, US NRC