ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9310050322 DOC.DATE: 93/09/30 NOTARIZED: NO DOCKET # FACIL:50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Servic 05000305 AUTHOR AFFILIATION SCHROCK, C.A. Wisconsin Public Service Corp. RECIP.NAME RECIPIENT AFFILIATION Document Control Branch (Document Control Desk) R SUBJECT: Informs NRC of matls received, pre-fabrication work & completion of mod prior to startup following next plant shutdown re AFW pump loss of suction pressure trip. ENCL C DISTRIBUTION CODE: A001D COPIES RECEIVED:LTR SIZE: TITLE: OR Submittal: General Distribution NOTES: RECIPIENT COPIES RECIPIENT COPIES Α LTTR ENCL ID CODE/NAME ID CODE/NAME LTTR ENCL PD3-3 LA PD3-3 PD 1 1 D LAUFER, R 2 D INTERNAL: ACRS 6 NRR/DE/EELB NRR/DORS/OTSB 1 NRR/DRCH/HICB 1 S NRR/DSSA/SPLB 1 NRR/DSSA/SRXB 1 NUDOCS-ABSTRACT 1 OC/LEDCB 1 OGC/HDS1 REG FILE 1 01 1 EXTERNAL: NRC PDR 1 NSIC

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 21 ENCL 19

MA-4

R

Ι

D

D

D

S

NRC-93-140 EASYLINK 62891993

600 North Adams ● P.O. Box 19002 ● Green Bay, WI 54307-9002

September 30, 1993

U.S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, D.C. 20555

Ladies/Gentlemen:

Docket 50-305
Operating License DPR-43
Kewaunee Nuclear Power Plant
Auxiliary Feedwater Pump Loss of Suction Pressure Trip

References:

- Letter from C.A. Schrock (WPSC) to NRC Document Control Desk dated May 7, 1993
- 2) Letter from G.C. Wright (NRC) to C.A. Schrock (WPSC) dated August 3, 1993

In reference 1, Wisconsin Public Service Corporation (WPSC) informed the NRC that we anticipated installing an auxiliary feedwater pump low discharge pressure trip during the first plant shutdown after August 1, 1993, provided all of the materials necessary for the modification were received. During an NRC electrical distribution system followup inspection on July 19-23, 1993, the NRC inspectors reviewed the proposed design for the low discharge pressure trip modification. The inspectors had some questions concerning the complexity of the trip override design. WPSC reexamined the design and decided to substitute a trip bypass feature locally at the pump for the trip override in the control room. While this change reduced the complexity of the design, it also resulted in numerous drawing and field package revisions.

During a telecon on August 3, 1993, WPSC informed Mr. R.J. Laufer of your staff of the change in design and the delay in project completion that would result from this change. During a followup telecon initiated by WPSC on August 10, 1993, Mr. Laufer informed WPSC that he had added a note in the project file and that formal notification of the schedule delay was not necessary. During the same call, WPSC estimated that the modification should be ready for implementation during the first shutdown after October 1, 1993.

Document Control Desk September 30, 1993 Page 2

This letter is to inform the NRC that all materials have been received, pre-fabrication work has begun in the field, and the modification will be completed prior to startup following the next plant shutdown. If you have any questions, please contact a member of my staff.

Sincerely,

C. A. Schrock

C.a. Schock

Manager - Nuclear Engineering

PMF/cjt

cc - US NRC Region III
US NRC Semior Resident Inspector

lic\nrc\39.wp