

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9402020270 DOC. DATE: 94/01/24 NOTARIZED: NO DOCKET #
 FACIL: 50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Service 05000305
 AUTH. NAME AUTHOR AFFILIATION
 SCHROCK, C.A. Wisconsin Public Service Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Notices of completion of commitments made in 920129 ltr re
 Generic Ltr 91-11, "Resolution of Generic Issues 48, 'LCOs
 for Class 1E Vital Instrumentation Buses' & 49, 'Interlocks
 & LCOs for Class 1E Tie Breakers,'" per 10CFR50.54(f).

DISTRIBUTION CODE: A027D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: Generic Ltr 91-11 - Resolutions of Generic Issues 48 & 49

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD3-3	PD	1	1		LAUFER, R		2	2
INTERNAL:	ACRS		6	6		NRR/DORS/OGCB		1	1
	NRR/DRCH/HICB		1	1		NRR/DRPE/PDII-1		1	1
	NRR/DRPW		1	1		NRR/DSSA/SRXB		1	1
	NRR/EELB		1	1		NUDOCS-ABSTRACT		1	1
	OC/LFDCB		1	0		OGC/HDS1		1	0
	<u>REG-FTEE</u>	01	1	1		RES/DSIR/EIB		1	1
EXTERNAL:	NRC	PDR	1	1		NSIC		1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 22 ENCL 20

R
I
D
S
/
A
D
D
S
/
A
D
D
S

MA-4



WISCONSIN PUBLIC SERVICE CORPORATION

600 North Adams • P.O. Box 19002 • Green Bay, WI 54307-9002

January 24, 1994

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Docket 50-305
Operating License DPR-43
Kewaunee Nuclear Power Plant
Generic Letter 91-11: Resolution of Generic Issues 48, LCOs for Class 1E Vital Instrumentation Buses, and 49, Interlocks and LCOs for Class 1E Tie Breakers, Pursuant to 10CFR 50.54(f)

- Reference:
- 1) Letter to Document Control Desk from C. R. Steinhardt dated January 29, 1992
 - 2) Letter to C. A. Schrock from A. G. Hansen dated June 3, 1992

In reference 1, WPSC committed to augment the existing KNPP Technical Specifications by establishing additional controls for specific plant instrument buses. WPSC also committed to performing monthly surveillance requirements on various electrical buses when the supported equipment is required to be operable. Lastly, commitments were made to prohibit cross-connecting four specific safety related buses when supported equipment must be operable.

In reference 2, the USNRC concluded that the proposed commitments met the reporting requirements of Generic Letter 91-11, and that WPSC should provide notification in writing when all the commitments have been met.

WPSC has completed the necessary actions to implement the above commitments. During the implementation of the commitments, WPSC used the KNPP Technical Specifications as the

9402020270 940124
PDR ADCK 05000305
P PDR

A027
1/0

Document Control Desk
January 24, 1994
Page 2

document which would determine when the safety related equipment was required to be operable. This determination was then used to decide when the safety related buses in question could be cross-connected. In accordance with reference 2, this letter fulfills the requirement to provide written notification upon completion of our commitments.

Sincerely,

C.A. Schrock

C.A. Schrock
Manager - Nuclear Engineering

DJM

cc - US NRC - Region III
Senior Resident Inspector, US NRC