

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9403110321      DOC. DATE: 94/03/01      NOTARIZED: NO      DOCKET #  
 FACIL: 50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Service      05000305  
 AUTH. NAME      AUTHOR AFFILIATION  
 SCHROCK, C.A.      Wisconsin Public Service Corp.  
 RECIP. NAME      RECIPIENT AFFILIATION

Document Control Branch (Document Control Desk)

SUBJECT: Provides final schedule for heating steam piping support mod.

DISTRIBUTION CODE: A001D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 4  
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES		
	ID CODE/NAME	LTTR	ENCL		
	PD3-3 LA	1	1		
	LAUFER, R	2	2		
INTERNAL:	ACRS	6	6	NRR/DE/EELB	1 1
	NRR/DORS/OTSB	1	1	NRR/DRCH/HICB	1 1
	NRR/DRPW	1	1	NRR/DSSA/SPLB	1 1
	NRR/DSSA/SRXB	1	1	NUDOCS-ABSTRACT	1 1
	OC/LFDCB	1	0	OGC/HDS1	1 0
	<u>REG FILE</u> 01	1	1		
EXTERNAL:	NRC PDR	1	1	NSIC	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 22 ENCL 20

R  
I  
D  
S  
/  
A  
D  
D  
S  
  
R  
I  
D  
S  
/  
A  
D  
D  
S



**WISCONSIN PUBLIC SERVICE CORPORATION**

600 North Adams • P.O. Box 19002 • Green Bay, WI 54307-9002

March 1, 1994

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Ladies/Gentlemen:

Docket 50-305  
Operating License DPR-43  
Kewaunee Nuclear Power Plant  
Final Schedule for Heating Steam Piping Support Modifications

References: 1) Letter from C.A. Schrock (WPSC) to the NRC Document Control Desk, dated February 19, 1993.

Wisconsin Public Service Corporation (WPSC) submitted a proposed methodology for resolution of the issue concerning the heating steam piping system seismic qualification at the Kewaunee Nuclear Power Plant (KNPP) in reference 1. Reference 1 provided a description of the issue, the proposed methodology for resolution and a preliminary schedule for performing the necessary evaluations and piping system support modifications. WPSC committed in reference 1 to submit a final schedule to the NRC which provides the target completion dates for the piping system support modifications for plant areas including the diesel generator rooms, the screenhouse and areas within the auxiliary building.

Reference 1 also stated that all engineering evaluations, including piping and piping support analyses were expected to be complete by the end of 1993. The engineering evaluations were completed as scheduled for the diesel generator rooms and the screenhouse. At this time, the evaluations are still in progress for areas within the auxiliary building.

9403110321 940301  
PDR ADCK 05000305  
P PDR

ADD 1

Document Control Desk  
March 1, 1994  
Page 2

Attachment I provides the final schedule for heating steam piping system modifications at KNPP. WPSC will keep the NRC apprised of any significant project or schedule changes should they occur and continue to implement the compensatory measures described in reference 1 until the required piping system modifications are complete. If there are any questions concerning this project or schedule, please contact a member of my staff.

Sincerely,



C.A. Schrock  
Manager - Nuclear Engineering

GCR/cjt

Attach.

cc - US NRC, Region III  
US NRC Senior Resident Inspector

lic\nrc\02.wp

ATTACHMENT 1

Letter From C. A. Schrock (WPSC)

To

Document Control Desk

Dated

March 1, 1994

Document Control Desk  
March 1, 1994  
Attachment 1, Page 1

## WPSC FINAL SCHEDULE

### HEATING STEAM PIPING SYSTEM MODIFICATIONS

<u>Plant Area</u>	<u>Target Completion Date</u>
Battery Rooms 1A and 1B	All Work Completed April, 1993
Diesel Generator Rooms 1A and 1B	December 31, 1994
Screenhouse Area	December 31, 1994
Auxiliary Building	December 31, 1995