

PRIORITY 1

(ACCELERATED RIDS PROCESSING)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9506190460 DOC.DATE: 95/06/13 NOTARIZED: NO DOCKET #
 FACIL:50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Service 05000305
 AUTH.NAME AUTHOR AFFILIATION
 STEINHARDT,C.R. Wisconsin Public Service Corp.
 RECIP.NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Notifies of completion of design-basis capability
 verification of safety-related MOVs, in accordance w/
 reporting requirements of GL 89-10, Suppl 6 & GL 89-10.

DISTRIBUTION CODE: A064D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: Response to Generic Ltr 89-10, "Safety-Related MOV Testing & Surveillance"

NOTES:

| | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL |
|-----------|---------------------------|---------------------|---------------------------|---------------------|
| | PD3-3 PD | 1 | LAUFER, R | 1 |
| INTERNAL: | ACRS | 1 | AEOD/SPD/RAB | 1 |
| | FILE CENTER 01 | 1 | NRR/DE/EMEB | 1 |
| | NRR/DISP/PIPB | 1 | NRR/DOIS/OECB | 1 |
| | NRR/PD111-3 | 1 | RES/DSIR | 1 |
| | RES/DSIR/EIB/B | 1 | | |
| EXTERNAL: | NOAC | 1 | NRC PDR | 1 |

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
 DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 13 ENCL 0

P
R
I
O
R
I
T
Y

1

D
O
C
U
M
E
N
T



WISCONSIN PUBLIC SERVICE CORPORATION

600 North Adams • P.O. Box 19002 • Green Bay, WI 54307-9002

June 13, 1995

10 CFR 50.54(f)

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Ladies/Gentlemen:

Docket 50-305
Operating License DPR-43
Kewaunee Nuclear Power Plant
Generic Letter 89-10

- References:
- 1) NRC Memorandum from Mr. B.W. Sheron, "Guidance on Closure of Staff Review of Generic Letter 89-10 Programs," dated July 12, 1994.
 - 2) Letter from Mr. R.J. Laufer to Mr. C.A. Schrock dated June 14, 1994.
 - 3) Letter from Mr. C.R. Steinhardt to U.S. Nuclear Regulatory Commission, dated March 16, 1994.
 - 4) Generic Letter 89-10, Supplement 6, "Information on Schedule and Grouping, and Staff Responses to Additional Public Questions," dated March 8, 1994.
 - 5) Safety-Related Motor-Operated Valve Testing and Surveillance (Generic Letter 89-10) dated June 28, 1989.

In accordance with the reporting requirements of references 4 and 5, this letter is notification of Wisconsin Public Service Corporation's (WPSC) completion of the design-basis capability verification of safety-related motor-operated valves (MOVs). Regarding the four MOVs that were requested for a schedule extension (references 2 and 3), two were diagnostic tested under dynamic conditions and fully meet the recommendations of GL 89-10; however, the two butterfly MOVs have not been diagnostic tested. These two MOVs have been temporarily

g:\wpfiles\lic\nrc\gl8910

9506190460 950613
PDR ADDCK 05000305
P PDR

AD64/10


Document Control Desk
June 13, 1995
Page 2

removed from the scope of WPSC's GL 89-10 program awaiting NRC resolution of the mispositioning issue for PWRs per reference 1. KNPP will take appropriate actions for these two MOVs following resolution of the mispositioning issue.

NRC Region 3 conducted a GL 89-10 closeout inspection during the week of May 22-26, 1995. As a result, NRC staff indicated that the inspection report will include several open items. The NRC staff also agreed these items could be resolved through correspondence with the NRC to closeout Kewaunee's GL 89-10 program.

If you have any questions or need additional information, please contact a member of my staff.

Sincerely,




C. R. Steinhardt
Senior Vice President - Nuclear Power

JRR/jmf

cc - US NRC Region III
US NRC Senior Resident Inspector

Subscribed and Sworn to
Before Me This 13th Day
of June 1995



Jeanne M. Ferris
Notary Public, State of Wisconsin

My Commission Expires:
June 18, 1995

PRIORITY 1
ACCELERATED RIDS PROCESSING

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9506190460 DOC. DATE: 95/06/13 NOTARIZED: NO DOCKET # 05000305
 FACIL: 50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Service
 AUTH. NAME AUTHOR AFFILIATION
 STEINHARDT, C.R. Wisconsin Public Service Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Notices of completion of design-basis capability verification of safety-related MOVs, in accordance w/ reporting requirements of GL 89-10, Suppl 6 & GL 89-10.

DISTRIBUTION CODE: A064D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: Response to Generic Ltr 89-10, "Safety-Related MOV Testing & Surveillance"

NOTES:

| | RECIPIENT ID CODE/NAME | COPIES LTR ENCL | RECIPIENT ID CODE/NAME | COPIES LTR ENCL |
|-----------|------------------------|-----------------|------------------------|-----------------|
| | PD3-3 PD | 1 | LAUFER, R | 1 |
| INTERNAL: | ACRS | 1 | AEOD/SPD/RAB | 1 |
| | <u>FILE CENTER 01</u> | 1 | NRR/DE/EMEB | 1 |
| | NRR/DISP/PIPB | 1 | NRR/DOPS/OECB | 1 |
| | NRR/PD111-3 | 1 | RES/DSIR | 1 |
| | RES/DSIR/EIB/B | 1 | | |
| EXTERNAL: | NOAC | 1 | NRC PDR | 1 |

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 13 ENCL 0

P
R
I
O
R
I
T
Y

1

D
O
C
U
M
E
N
T



WISCONSIN PUBLIC SERVICE CORPORATION

600 North Adams • P.O. Box 19002 • Green Bay, WI 54307-9002

June 13, 1995

10 CFR 50.54(f)

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Ladies/Gentlemen:

Docket 50-305

Operating License DPR-43

Kewaunee Nuclear Power Plant

Generic Letter 89-10

- References:
- 1) NRC Memorandum from Mr. B.W. Sheron, "Guidance on Closure of Staff Review of Generic Letter 89-10 Programs," dated July 12, 1994.
 - 2) Letter from Mr. R.J. Laufer to Mr. C.A. Schrock dated June 14, 1994.
 - 3) Letter from Mr. C.R. Steinhardt to U.S. Nuclear Regulatory Commission, dated March 16, 1994.
 - 4) Generic Letter 89-10, Supplement 6, "Information on Schedule and Grouping, and Staff Responses to Additional Public Questions," dated March 8, 1994.
 - 5) Safety-Related Motor-Operated Valve Testing and Surveillance (Generic Letter 89-10) dated June 28, 1989.

In accordance with the reporting requirements of references 4 and 5, this letter is notification of Wisconsin Public Service Corporation's (WPSC) completion of the design-basis capability verification of safety-related motor-operated valves (MOVs). Regarding the four MOVs that were requested for a schedule extension (references 2 and 3), two were diagnostic tested under dynamic conditions and fully meet the recommendations of GL 89-10; however, the two butterfly MOVs have not been diagnostic tested. These two MOVs have been temporarily

g:\wpfiles\lic\nrc\gl8910

9506190460 950613
PDR ADOCK 05000305
P PDR

AD64/10

Document Control Desk

June 13, 1995


Page 2

removed from the scope of WPSC's GL 89-10 program awaiting NRC resolution of the mispositioning issue for PWRs per reference 1. KNPP will take appropriate actions for these two MOVs following resolution of the mispositioning issue.

NRC Region 3 conducted a GL 89-10 closeout inspection during the week of May 22-26, 1995. As a result, NRC staff indicated that the inspection report will include several open items. The NRC staff also agreed these items could be resolved through correspondence with the NRC to closeout Kewaunee's GL 89-10 program.

If you have any questions or need additional information, please contact a member of my staff.

Sincerely,




C. R. Steinhardt
Senior Vice President - Nuclear Power

JRR/jmf

cc - US NRC Region III
US NRC Senior Resident Inspector

Subscribed and Sworn to
Before Me This 13th Day
of June, 1995


Notary Public, State of Wisconsin

My Commission Expires:

June 18, 1995