

**PRIORITY 1**  
ACCELERATED RIDS PROCESSING

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9511270006    DOC.DATE: 95/11/16    NOTARIZED: YES    DOCKET #  
 FACIL: 50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Service    05000305  
 AUTH.NAME    AUTHOR AFFILIATION  
 STEINHARDT, C.R.    Wisconsin Public Service Corp.  
 RECIP.NAME    RECIPIENT AFFILIATION  
                   Document Control Branch (Document Control Desk)

SUBJECT: Provides util commitment to 90-day requested actions of  
 GL 95-07, including performance of screening evaluation to  
 provide confidence that no short-term safety concerns exist  
 re particular valves as result of pressure locking.

DISTRIBUTION CODE: A056D    COPIES RECEIVED: LTR    / ENCL   0      SIZE:   2    
 TITLE: Generic Ltr 95-07 - Pressure Locking & Thermal Binding of Safety Rela

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	NRR/DRPE/PD1-1 LAUFER, R	1   1	PD3-3 PD	1   1
INTERNAL:	<b>FILE CENTER 01</b>	1   1	NRR/EMEB/B	1   1
EXTERNAL:	NOAC	1   1	NRC PDR	1   1
	NUDOCS ABSTRACT	1   1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL  
 DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM  
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR    8    ENCL    8

P  
R  
I  
O  
R  
I  
T  
Y  
  
1  
  
D  
O  
C  
U  
M  
E  
N  
T



**WISCONSIN PUBLIC SERVICE CORPORATION**

600 North Adams • P.O. Box 19002 • Green Bay, WI 54307-9002

November 16, 1995

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Ladies/Gentlemen:

Docket 50-305  
Operating License DPR-43  
Kewaunee Nuclear Power Plant  
Supplemental Response to Generic Letter 95-07 - Clarification

- References:
- 1) NRC Generic Letter 95-07: Pressure Locking and Thermal Binding of Safety-Related Power-Operated Gate Valves, dated August 17, 1995
  - 2) Letter from C. R. Steinhardt (WPSC) to Document Control Desk (NRC) dated October 16, 1995
  - 3) Letter from R. J. Laufer (NRC) to M. L. Marchi (WPSC) dated November 3, 1995
  - 4) Letter from C. R. Steinhardt (WPSC) to Document Control Desk (NRC) dated November 15, 1995.

Subsequent to the transmittal of Reference 4, the NRC requested clarification on the implementation of actions in response to Generic Letter 95-07. A revised response is provided below and supersedes the response provided in Reference 4.

Reference 1 requested certain actions from licensees on a 90-day and 180-day schedule and a response within 60 days indicating the licensee's intended actions. Wisconsin Public Service Corporation (WPSC) submitted its 60-day response to GL 95-07 for the Kewaunee Nuclear Power Plant in Reference 2. In our response, we discussed the industry effort in developing screening criteria, requested the 90-day actions of GL 95-07 be waived, and stated that WPSC would comply with all actions and responses specified in the 180-day response.

286599  
9511270006 951116  
PDR ADOCK 05000305  
P PDR


Document Control Desk  
November 16, 1995  
Page 2

Reference 3 provided the NRC's review of WPSC's 60-day response and stated that the NRC does not find WPSC's submittal to be fully responsive. The NRC requested WPSC to commit to the 90-day requested actions of GL 95-07 or provide the safety basis for determining the acceptability of the planned alternative course of action by November 15, 1995.

This letter provides WPSC's commitment to the 90-day requested actions of GL 95-07 which are to 1) perform a screening evaluation to provide confidence that no short-term safety concerns exist regarding particular valves as a result of pressure locking and thermal binding and 2) document the basis for operability of these valves, or if operability cannot be supported, take appropriate action in accordance with the Kewaunee Technical Specifications. WPSC also reaffirms our commitment to all actions and responses specified in the 180-day response.

If you have questions or need additional information, please contact a member of my staff.

Sincerely,




Clark R. Steinhardt  
Senior Vice President - Nuclear Power

RPP

cc - US NRC, Region III  
US NRC Senior Resident Inspector  
Mr. Lanny Smith, PSCW

Subscribed and Sworn to  
Before Me This 16<sup>th</sup> Day  
of November 1995

  
Notary Public, State of Wisconsin

My Commission Expires:

June 13, 1999