Docket No. 50-305

Wisconsin Public Service Corporation Mr. C. A. Schrock ATTN: Manager - Nuclear Engineering Post Office Box 19002 Green Bay, WI 54307-9002

Dear Mr. Schrock:

This refers to the inspection conducted by Messrs. J. F. Smith and M. P. Huber and Ms. M. L. McCormick-Barger of this office on August 17 through September 22, 1992. The inspection included a review of activities for your Kewaunee Nuclear Power Plant. At the conclusion of the inspection, the findings were discussed with those members of your staff identified in the enclosed report.

The areas examined during the inspection are identified in the report. These areas consisted primarily of a review of the Kewaunee Nuclear Power Plant's program for inservice testing of pumps and valves established in response to Generic Letter 89-04 and of the activities regarding the performance of check valves. Within this area, the inspection consisted of a selective examination of procedures and representative records, observations, and interviews with personnel.

No violations of NRC requirements were identified during the course of this inspection.

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter and the enclosed inspection report will be placed in the NRC Public Document Room.

We will gladly discuss any questions you have concerning this inspection.

Sincerely,

Original Signed by Mark A. Ring M. A. Ring, Chief Engineering Branch

Enclosure: Inspection Report No. 50-305/92019(DRS)

See Attached Distribution

Mccornlick-Barger 10/05/92 /92 10/1/ /92

Dac //92 10/6 /92 10/⁻

R'i na

9210130084 921007 ADOCK 05000305

Distribution

cc w/enclosure: C. R. Steinhardt, Senior Vice President - Nuclear Power Mark L. Marchi, Manager, Kewaunee Plant DCD/DCB (RIDS) OC/LFDCB Resident Inspector, RIII A. Hansen, LPM, NRR T. Scarbrough, NRR Virgil Kanable, Chief Boiler Section Ms. Cheryl L. Parrino, Public Service Commission of Wisconsin Robert M. Thompson, Admin., WI Div. of Emergency Government