

DOCKET NO: 50-305  
 UNIT NAME: Kewaunee  
 DATE: July 15, 1997  
 COMP BY: Mary L. Anderson  
 TELEPHONE: 414-388-8453

**UNIT SHUTDOWNS AND POWER REDUCTIONS  
 REPORT MONTH - JUNE 1997**

NO.	DATE	TYPE	DURATION	REASON	METHOD	LER NO.	SYS	COMPONENT	COMMENTS
3	6/1/97	S	269.77	C	4	N/A	ZZ	ZZZZZZ	Cycle XXI-XXII Refueling Outage continued until June 12. G-1 was closed on June 12, 1997 at 1737. Full power (94%) was reached on June 29, 1997 at 2055. The unit continues to operate at 94% power, steady state operation.
4	6/12/97	S	1.1	B	1	N/A	ZZ	ZZZZZZ	A short outage was taken to perform the Turbine Overspeed Trip Test

TYPE	REASON	METHOD	SYSTEM & COMPONENT CODES
F: FORCED	A-Equipment Failure (explain)	1-Manual	From NUREG-0161
S: SCHEDULED	B-Maintenance or Test	2-Manual Scram	
	C-Refueling	3-Automatic Scram	
	D-Regulatory Restriction	4-Continuations	
	E-Operator Training & License Examination	5-Load Reductions	
	F-Administrative	9-Other	
	G-Operational Error (explain)		
	H-Other (explain)		

9707230177 970716  
 PDR ADOCK 05000305  
 R PDR