CATEGORY

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9608280056 DOC.DATE: 96/08/23 NOTARIZED: NO DOCKET # FACIL:50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Servic 05000305 AUTHOR AFFILIATION AUTH.NAME Wisconsin Public Service Corp. MARCHI, M.L. RECIPIENT AFFILIATION RECIP.NAME Document Control Branch (Document Control Desk) SUBJECT: Provides update on plant specific actions re Large Break LOCA reevaluation using pre-1991 LBLOCA Model. DISTRIBUTION CODE: A001D COPIES RECEIVED:LTR ENCL SIZE: TITLE: OR Submittal: General Distribution NOTES: COPIES RECIPIENT COPIES RECIPIENT LTTR ENCL ID CODE/NAME LTTR ENCL ID CODE/NAME PD3-3 PD PD3-3 LA 1 LAUFER, R 1 FILE CENTER INTERNAL: ACRS NRR/DRCH/HICB NRR/DE/EMCB 1 NRR/DSSA/SRXB NRR/DSSA/SPLB 1 OGC/HDS2 1 NUDOCS-ABSTRACT 1 NRC PDR

NOTE TO ALL "RIDS" RECIPIENTS: PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM OWFN 5D-5(EXT. 415-2083) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

T

E

G

R

Y

1

D

0

U

M

E

N

T

EXTERNAL: NOAC



WISCONSIN PUBLIC SERVICE CORPORATION

August 23, 1996

U.S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, D.C. 20555

Ladies/Gentlemen:

Docket 50-305
Operating License DPR-43
Kewaunee Nuclear Power Plant
Large Break LOCA Reevaluation Using Pre-1991 LBLOCA Model

Reference: Letter from M. L. Marchi (WPS) to Document Control Desk (NRC) dated

July 23, 1996.

Through ongoing discussions with Siemens Power Corporation (SPC), the Kewaunee Nuclear Plant fuel vendor, WPS has become aware of a number of recent interactions with the Nuclear Regulatory Commission concerning some modifications made to the Siemens PWR Large Break LOCA evaluation model. Siemens is currently the vendor for the large break loss-of-coolant-accident (LBLOCA) analysis of record for the Kewaunee Plant, and this letter is to update you on the plant specific actions taken by Siemens to address the NRC concerns.

As a contingency action, SPC has performed a LBLOCA analyses for the Kewaunee Plant using a pre-1991 evaluation model that did not incorporate the changes under discussion with the NRC. The results of that evaluation were provided to WPS on July 10, 1996 and reflect a peak clad temperature (PCT) of 2148°F continuing to satisfy the acceptance criteria of 10CFR50.46. Performed only as a contingency effort, this is not intended to be a replacement for the current analysis of record which has a PCT of 2050.5°F.

As described in the Reference, WPS continues to pursue the application of a LBLOCA evaluation model that explicitly incorporates the upper plenum injection design. Completion of this effort is anticipated by the Fall of this year.

If you require any additional information or have questions concerning this transmittal, please contact a member of my staff.

Phoesesses 760823 Phoesesses 270137 s transmittal, please AOOI

n:\group\nuclear\wpfiles\lic\nrc\siem.wp

Document Control Desk August 23, 1996 Page 2

Sincerely,

TO THE TO

M. L. Marchi Manager - Nuclear Business Group

RPP/dlf

cc - US NRC, Region III US NRC Senior Resident Inspector