

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9712050181 DOC. DATE: 97/12/01 NOTARIZED: NO DOCKET #
FACIL: 50-305 Kewaunee Nuclear Power Plant, Wisconsin Public Service 05000305
AUTH. NAME AUTHOR AFFILIATION
MARCHI, M.L. Wisconsin Public Service Corp.
RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Provides responses to 971106 RAI re use of high thermal performance DNB correlation in Kewaunee reload methods.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL	ID CODE/NAME		LTTR	ENCL
	PD3-3 LA		1	1	PD3-3 PD		1	1
	TRAN, L		1	1				
INTERNAL:	ACRS		1	1	FILE CENTER 01		1	1
	NRR/DE/ECGB/A		1	1	NRR/DE/EMCB		1	1
	NRR/DRCH/HICB		1	1	NRR/DSSA/SCSB		1	0
	NRR/DSSA/SPLB		1	1	NRR/DSSA/SRXB		1	1
	NUDOCS-ABSTRACT		1	1	OGC/HDS2		1	0
EXTERNAL:	NOAC		1	1	NRC PDR		1	1

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T

NOTE TO ALL "RIDS" RECIPIENTS:
PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 15 ENCL 13



Wisconsin Public Service Corporation
 (a subsidiary of WPS Resources Corporation)
 600 North Adams Street
 P.O. Box 19002
 Green Bay, WI 54307-9002
 1-920-433-5544 fax

December 1, 1997

U.S. Nuclear Regulatory Commission
 Attention: Document Control Desk
 Washington, DC 20555

Gentlemen:

Docket 50-305
 Operating License DPR-43
 Kewaunee Nuclear Power Plant
 Additional Information Regarding the Use of High Thermal
 Performance DNB Correlation in the Kewaunee Reload Methods

- References:
- 1) Letter from M. L. Marchi (WPSC) to NRC Document Control Desk, dated September 4, 1997
 - 2) EMF-92-153(P)(A) and Supplement 1, Siemens Power Corporation Report, HTP: Departure From Nucleate Boiling Correlation for High Thermal Performance Fuel, March 1994
 - 3) Letter from R. J. Laufer (NRC) to M. L. Marchi (WPSC), dated November 6, 1997

In Reference 1, Wisconsin Public Service Corporation requested that the Nuclear Regulatory Commission review the use of the Siemens Power Corporation's High Thermal Performance Departure from Nucleate Boiling Correlation at the Kewaunee Plant. The NRC provided two requests for additional information in Reference 3. WPSC's responses are provided below.

Q1. *How does the 1.47 maximum axial peak used in the HTP data base compare with typical values expected in the Kewaunee core? If values greater than 1.47 are expected in the Kewaunee core, please explain why 1.47 is an acceptable maximum value for the HTP data base; and*

Typical measured axial peak values for Kewaunee are presented in Table 1. These values are derived from Cycle 22 flux map measurements.

050073

ADD'l

9712050181 971201
 PDR ADOCK 05000305
 P PDR



TABLE 1			
Flux Map	Cycle Burnup	Measured Maximum Axial Peak	Measured Maximum Axial Peak With Uncertainties
2205	514	1.22	1.39
2206	1041	1.21	1.37
2207	1715	1.22	1.37
2208	2394	1.20	1.35
2209	3498	1.20	1.33
2210	4437	1.17	1.32

As shown, the highest measured axial peak in Cycle 22 to date is 1.22 without uncertainty and 1.39 with uncertainty. All values are bounded by the maximum axial peak of 1.47 that is used in the HTP data base.

Cycle 22 design maximum axial peak values with and without uncertainties and measured maximum axial peak values with uncertainties are presented in Figure 1. All values are shown to be under the 1.47 limit. Measured values are expected to remain below 1.47, following the design value trend curve, as the fuel cycle burns to end of cycle.

Therefore, based on an evaluation of a typical core's (Cycle 22) design and measured results, axial peak values greater than 1.47 are not expected in the Kewaunee core. The 1.47 limit would also be expected to bound future reload cores that are designed and operated to similar constraints.

Q2. *The largest grid spacer pitch in the HTP test sections was 22.4 inches. The Kewaunee value is 26.2 inches. Since a shorter grid spacing would result in a higher critical heat flux, please explain why the HTP data base is acceptable for Kewaunee.*

The grid spacer pitch, defined as the center-to-center axial distance between adjacent grid spacers, is 26.2 inches for Kewaunee fuel. The test case grid spacer pitch values presented in Reference 1, Attachment 1, represent the distance from the top of the upstream spacer to the bottom of the downstream spacer. The Reference 2 definition of grid spacer pitch was provided in Reference 1, Attachment 1, at the bottom of the table. These two different definitions of grid spacer pitch have contributed to the concern expressed in this question.


The HTP critical heat flux correlation is applicable to fuel assemblies whose design characteristics fall within the correlation data base. The following table is recreated from Supplement 1 of Reference 2:

TABLE 2 Nominal Range of Fuel Design Parameters in HTP Correlation Data Base	
Parameter	Value
Fuel Rod Diameter, in.	0.360 - 0.440
Fuel Rod Pitch, in.	0.496 - 0.580
Axial Spacer Span, in.	10.5 - 26.2
Hydraulic Diameter, in.	0.4571 - 0.5334
Heated Length, ft.	8.0 - 14.0

Test assembly 49 which was incorporated into the WPS HTP CHF qualification analyses does have a center-to-center axial spacer pitch of 26.2 inches as shown in Table 3.1 of Reference 2. The Kewaunee spacer pitch is 26.2 inches; therefore, this correlation database is acceptable for use with Kewaunee fuel.

Should you have any additional questions concerning this information, please contact me.

Sincerely,


Mark L. Marchi
Manager-Nuclear Business Group

JTH/smm

Attach.

cc - US NRC - Region III
US NRC Senior Resident Inspector

FIGURE 1

Cycle 22 Fz vs. Exposure

