

NPL-30118

*Handwritten initials and marks*

Copies to Britt/Gorske/Finke, Burstein, Charnoff, Krieser,  
Lipke, Newton, Zach - CWF 2/2/87



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

JAN 21 1987

Rec'd. 2/2/87

Docket Nos. 50-266  
and 50-301

*Plant 12010100  
GL = 81.4*

Mr. C. W. Fay, Vice President  
Nuclear Power Department  
Wisconsin Electric Power Company  
231 W. Michigan Street, Room 308  
Milwaukee, Wisconsin 53201

Dear Mr. Fay:

SUBJECT: SEISMIC QUALIFICATION OF THE AUXILIARY FEEDWATER SYSTEM AT THE  
POINT BEACH NUCLEAR PLANT UNITS 1 AND 2

We have reviewed your letter of October 31, 1986 addressing the staff's remaining concern identified in our September 16, 1986 Safety Evaluation (SE) on the subject item. We conclude that the modifications you have implemented to protect the diesel generator voltage regulator cabinets from fire protection sprinkler operation at Point Beach adequately address the staff's concern identified in our SE resulting from a postulated condensate storage tank rupture. This concludes our review with respect to this subject.

Sincerely,

*Handwritten signature of Timothy G. Colburn*  
Timothy G. Colburn, Project Manager  
Project Directorate #1  
Division of PWR Licensing-A

cc's: See Next Page

RECEIVED

FEB 03 1987

POINT BEACH

Mr. C. W. Fay  
Wisconsin Electric Power Company

Point Beach Nuclear Plant  
Units 1 and 2

CC:

Mr. Bruce Churchill, Esq.  
Shaw, Pittman, Potts and Trowbridge  
2300 N. Street, N.W.  
Washington, DC 20037

Mr. James J. Zach, Manager  
Point Beach Nuclear Plant  
Wisconsin Electric Power Company  
6610 Nuclear Road  
Two Rivers, Wisconsin 54241

Mr. Gordon Blaha  
Town Chairman  
Town of Two Creeks  
Route 3  
Two Rivers, Wisconsin 54241

Chairman  
Public Service Commission  
of Wisconsin  
Hills Farms State Office Building  
Madison, Wisconsin 53702

Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
Office of Executive Director  
for Operations  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Resident Inspector's Office  
U.S. Nuclear Regulatory Commission  
6612 Nuclear Road  
Two Rivers, Wisconsin 54241