



# V.C. Summer Inadvertent Criticality

## Section 7.2



# Learning Objectives

- Briefly discuss the V.C. Summer startup accident.
- Explain the causes of the accident.
- Explain the safety implications of the accident.
- Explain what procedural limitations and administrative controls should have prevented this accident.

# Background

- 3-loop W plant in South Carolina.
- Commercial operation began 1982.
- In Feb. 1985, the plant had been operating intermittently.
- 2/28/85, during a startup, the Rx tripped due to unexpected criticality.

# Summary of Event (Section 7.2.1)


- The plant had been operating intermittently during the previous month.
- ECP was 168 steps on control bank D.
- Non-licensed trainee performing S/U under supervision of SRO licensed shift supervisor (SS).
- SS directed trainee to w/draw rods to 100 steps on control bank D.

# Summary of Event (continued – 1 )

- The trainee only watched rod positions while withdrawing control banks.
- When power reached P-6, SS blocked SR high flux trip.
- Rx tripped w/ CB-D @ 76 steps.
- Rx tripped on high positive flux rate.
- When Rx tripped, power was ~ 6%.
- 16 – 17 dpm Startup rate (SUR).

# Causes (Section 7.2.2)

- Failure to Follow Procedures.
- Incorrect Calculation of the Estimated Critical Rod Position (ECRP).
- Inadequate Training / Experience Level of Trainee.
- Inadequate Supervision of Trainee by Shift Supervisor (an SRO).



# Failure to Follow Procedures

- Licensed Operator (the SS) responsible for the S/U failed to monitor excore NIs for indications of criticality when positive reactivity was being added (as required by procedures).
- The SS blocked the SR reactor trip when P-6 permissive was received w/o noticing the rate at which power was increasing.

# Incorrect Calculation of the ECP

- The calculation (power block method) for [Xe](#) predicting Xe and Sm reactivity worth can produce significant errors when the Rx had [Sm](#) recently been operating at widely varying power levels. Rx had been critical 3 hours before S/U.

The calculation used MOL Rod Worth Curves rather than BOL curves. The licensee's procedure lacked guidance regarding when to change to the MOL Rod Worth Curves.



# Inadequate Training / Experience Level of Trainee.

- Trainee had no prior plant or simulator startup experience.
- Trainee did not know the indications for a critical Rx. [Critical](#)

Trainee did not know that procedures required the excore NIs should be monitored for indications of criticality any time positive reactivity is being added to the core.

# Inadequate Supervision of Trainee

- SS was responsible for:
  - the Rx S/U (bringing the Rx critical),
  - the startup activities for the entire control room staff as well as S/U activities, and
  - supervision of trainee.

# Consequences


- Rx tripped w/ CB D @ 76 steps.
- Rx tripped on high positive flux rate.
- When Rx tripped, power was ~ 6%.
- 16 – 17 dpm SUR.
- Rx was critical w/ CB D @ ~ 40 steps.
- No fuel damage.

# Safety Implications (Section 7.2.3)

- Uncontrolled rod withdrawal while subcritical was an analyzed event in FSAR.
- FSAR assumed reactivity addition rate of 105 pcm/sec. Actual was 10 pcm/sec.
- FSAR assumed trip on high flux low setpoint (35% @ Summer) rather than high positive flux rate.

# Safety Implications (Continued)

- No fuel or cladding damage.
- DNBR remained above limit.
- Rods were  $>$  RIL when critical.



## Procedural Limitations & Administrative Controls that Should Have Prevented the Inadvertent Criticality.


- Operators monitoring excore NIs for indications of criticality when positive reactivity was being added.
- Operators anticipating criticality whenever positive reactivity is being added.

## Procedural Limitations & Administrative Controls that Should Have Prevented the Inadvertent Criticality. (cont-1)

- Proper supervision of trainee by licensed operators.
- Adequate training / experience of trainee prior to performing tasks.

## Procedural Limitations & Administrative Controls that Should Have Prevented the Inadvertent Criticality (cont-2)

- Procedural guidance stating that the accuracy of the ECRP calculation is limited when the Rx had recently been operating at widely varying power levels.
- Procedural guidance for changing to MOL rod worth curves from BOL curves.





# Corrective Actions

- Procedural inadequacies addressed.
- Inverse multiplication plots used for subsequent startups
  - to predict criticality
  - to verify accuracy of ECP.
- A quick review of inverse multiplication plots.

# Subcritical Reactor

- The equation for  $K_{eff}$  does not account for source neutrons because the number of neutrons are insignificant when compared to the number of fission neutrons in a critical reactor.

$$K_{effective} = \frac{\text{\# of neutrons in this generation}}{\text{\# of neutrons in the previous generation}}$$

$$K_{eff} = \frac{N}{N_0}$$

# Subcritical Multiplication

- Definition: the increase in neutron population in a subcritical reactor.
  - The population increase is caused by the addition of positive reactivity.
    - Adding fuel during refueling evolutions.
    - Withdrawal of control rods
    - Boron concentration dilution.

# Equilibrium Neutron Level in a Subcritical Reactor

$$CR = \frac{S}{(1 - K_{eff})}$$

- CR: Count Rate (total neutron level in counts per second).
- S: source neutron level in counts per second.
- $K_{eff}$  must be  $< 1$ .

# Subcritical Multiplication Factor

- If we add positive reactivity,  $K_{eff}$  gets closer to 1 and  $R_x$  is closer to being critical.

$$CR_1 = \frac{S_1}{(1 - K_{eff1})} \rightarrow S_1 = CR_1(1 - K_{eff1})$$

$$CR_2 = \frac{S_2}{(1 - K_{eff2})} \rightarrow S_2 = CR_2(1 - K_{eff2})$$

*But,  $S_1 = S_2$*

# A Little Algebra

$$CR_1 = \frac{S_1}{(1 - K_{eff1})} \rightarrow S_1 = CR_1(1 - K_{eff1})$$

$$CR_2 = \frac{S_2}{(1 - K_{eff2})} \rightarrow S_2 = CR_2(1 - K_{eff2})$$

*But,  $S_1 = S_2$*

*So,*

$$CR_1(1 - K_{eff1}) = CR_2(1 - K_{eff2})$$

*or*


$$\frac{CR_2}{CR_1} = \frac{(1 - K_{eff1})}{(1 - K_{eff2})}$$

# Subcritical Multiplication Factor (M)

$$M = \frac{(1 - K_{eff 1})}{(1 - K_{eff 2})}$$

$$M = \frac{CR_2}{CR_1}$$

# Plots




$$M = \frac{(1 - K_{eff 1})}{(1 - K_{eff 2})}$$

$$M = \frac{CR_2}{CR_1}$$

As + reactivity is added,  $K_{eff 2}$  approaches 1.  
 $M$  approaches infinity. Can not plot it.



# Plots (continued)



$$M = \frac{(1 - K_{eff 1})}{(1 - K_{eff 2})}$$


$$M = \frac{CR_2}{CR_1}$$

As + reactivity is added,  $K_{eff 2}$  approaches 1.  
 $1/M$  approaches zero.

# Example of 1/M Data

<b>RCCA</b>	<b>CR</b>	<b>1/M</b>
A@0	18	1.00
A@131	20	0.90
B@131	31	0.58
C@118	55	0.33

# 1/M Plot



# Reactivity Management Problems

<b>TABLE 7.2-1      Incorrect ECRPs</b>		
<u>Date</u>	<u>Plant</u>	<u>Primary Cause</u>
5/11/85	V.C. Summer	Incorrect ECRP, went critical below the RIL, inverse multiplication plot failed to identify error.
5/17/85	McGuire 2	Incorrect ECRP, went critical below the RIL, error caused by incorrect Xenon worth program.
8/23/84	Turkey Point 3	Incorrect ECRP, went critical 85 steps below ECRP, calculation error.
5/12/84	Turkey Point 3	Incorrect ECRP, went critical 145 steps below ECRP, calculation error.
10/31/84	Turkey Point 4	Unable to achieve criticality, calculation error resulted in improper boron addition to RCS.
5/15/85	Turkey Point 3	Incorrect ECRP, used wrong RCS temperature in calculation (525°F vs. 535°F)

# Recent Problems

- Fitzpatrick (BWR-4) 3/1997 @ 100%.
  - Performing rod coupling check.
  - RO looked at wrong position indication for selected rod.
  - Selected rod at mid-plane
  - Withdrew rod until auto rod block at 101%.

# Recent Problems (continued - 1)

- Zion (4-loop W ) 2/1997. Rx shutdown to Mode 3 in progress due to CS pump LCO expired.
  - RO continuously inserted rods (~ 4 minutes) until < POAH.
  - Rods below RIL.
  - Rx went subcritical.
  - Operator withdrew rods (~ 2 minutes) to restore power to POAH.

# Recent Problems (continued - 2)

- Beaver Valley (3-loop W) 3/1996.
  - Shutdown in progress.
  - Concurrent rod drop testing in progress.
  - RO withdrew rods trying to maintain no-load Tave.
  - 0.95 SUR occurred.

# Review Learning Objectives

- Briefly discuss the V.C. Summer startup accident.
- Explain the causes of the accident. [Obj-2](#)
- Explain the safety implications of the accident. [Obj-3](#)
- Explain what procedural limitations and administrative controls should have prevented this accident. [Obj-4](#)



# Questions?



# Equivalent Power for Xe Calculations

Hours Prior to Shutdown	Average Power (%)	Multiplier	Product
0 to 1	_____	x6 =	_____
1 to 2	_____	x5 =	_____
2 to 3	_____	x5 =	_____
3 to 4	_____	x5 =	_____
4 to 5	_____	x4 =	_____
5 to 6	_____	x4 =	_____
6 to 7	_____	x4 =	_____
7 to 8	_____	x4 =	_____
8 to 9	_____	x4 =	_____
9 to 10	_____	x3 =	_____
10 to 11	_____	x3 =	_____
11 to 12	_____	x3 =	_____
12 to 13	_____	x3 =	_____
13 to 14	_____	x3 =	_____
14 to 15	_____	x3 =	_____
15 to 16	_____	x3 =	_____
16 to 17	_____	x2 =	_____
17 to 18	_____	x2 =	_____
18 to 19	_____	x2 =	_____
19 to 20	_____	x2 =	_____
20 to 21	_____	x2 =	_____
21 to 22	_____	x2 =	_____
22 to 23	_____	x2 =	_____
23 to 24	_____	x2 =	_____
24 to 25	_____	x2 =	_____
25 to 26	_____	x1 =	_____
26 to 27	_____	x1 =	_____
27 to 28	_____	x1 =	_____
28 to 29	_____	x1 =	_____
29 to 30	_____	x1 =	_____
30 to 31	_____	x1 =	_____
31 to 32	_____	x1 =	_____
32 to 33	_____	x1 =	_____
33 to 34	_____	x1 =	_____
34 to 35	_____	x1 =	_____
35 to 36	_____	x1 =	_____
<b>TOTAL =</b>			_____


Xenon Power =  $\frac{\text{TOTAL}}{91} = \frac{\quad}{91} = \quad\%.$



# Equivalent Power for Sm Calculations

Days Prior to Shutdown	Average Power (%)	Multiplier	Product
Today	_____	x15.6 =	_____
1	_____	x24.7 =	_____
2	_____	x18.1 =	_____
3	_____	x13.2 =	_____
4	_____	x 9.6 =	_____
5	_____	x 7.0 =	_____
6	_____	x 5.2 =	_____
7	_____	x 3.8 =	_____
8	_____	x 2.8 =	_____
		TOTAL =	_____

$$\text{Samarium Power} = \frac{\text{TOTAL}}{100} = \frac{\text{_____}}{100} = \text{_____} \%$$



## Indications that the Rx is Critical

- Increasing neutron population.
- Constant, positive startup rate.
- No reactivity addition:
  - no rod motion.
  - no change in boron concentration.

