

50-331

NRC-DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER
INCIDENT REPORT

TO: James G. Keppler

FROM: Iowa Elec. Light and Power Co.
Cedar Rapids, Iowa 52406
G. G. Hunt

DATE OF DOCUMENT

12-07-76

DATE RECEIVED

12-13-76

☒ LETTER☐ NOTORIZED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

☐ ORIGINAL☒ COPY☒ UNCLASSIFIED1 *519 n 601*

DESCRIPTION Ltr. Trans The Following

**DO NOT REMOVE
ACKNOWLEDGED**

PLANT NAME JANE ARNOLD

ENCLOSURE Licensee Event Report (RO-76-78) on
11-09-76 concerning main steam line D high flow
tripped at 120 PSID...

(1 encl rec'd)

NOTE: IF PERSONNEL EXPOSURE IS INVOLVED
SEND DIRECTLY TO KREGER/J. COLLINS

FOR ACTION/INFORMATION

jem 12-14-76

☒ BRANCH CHIEF:

W/3 CYS FOR ACTION

Lear☒ LIC. ASST.:

W/ 1 CYS

Parrish☒ ACRS 14 CYS HOLDING/SENT*Get 'B' on 12-14-76*

INTERNAL DISTRIBUTION

☒ REG FILE☒ NRC PDR☒ I & E (2)☒ MIPC☒ SCHROEDER/IPPOLITO☒ HOUSTON☒ NOVAK/CHECK☒ GRIMES☒ CASE☒ BUTLER☒ HANAUER☒ TEDESCO/MACCARY☒ EISENHUT☒ BAER☒ SHAO☒ VOLLMER/BUNCH☒ KREGER/J. COLLINS

EXTERNAL DISTRIBUTION

☒ LPDR: Cedar Rapids Ia.☒ TIC:☒ NSIC:

CONTROL NUMBER

12529

a/04


IOWA ELECTRIC LIGHT AND POWER COMPANY

DUANE ARNOLD ENERGY CENTER
P. O. Box 351
Cedar Rapids, Iowa 52406

December 7, 1976
DAEC - 76 - 383

Regulatory Docket File

Mr. James G. Keppler, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission - Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137



Subject: Licensee Event Report No. 76-78
(30 day)

File: A-118a

Dear Mr. Keppler:

In accordance with Appendix A to Operating License DPR-49, Technical Specifications and Bases for Duane Arnold Energy Center and Regulatory Guide 10.1, please find attached a copy of the subject Licensee Event Report. (Total of 3 copies transmitted)

Very truly yours,

G. G. Hunt ELH
G. G. Hunt
Chief Engineer
Duane Arnold Energy Center



Docket 50-331

attachment

GGH/DLW/mg

cc: Director, Office of Inspection and Enforcement (30)
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Director, Management Information and Program Control (3)
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

12529

[PLEASE PRINT ALL REQUIRED INFORMATION]

EVENT DESCRIPTION

SYSTEM CODE		CAUSE CODE	COMPONENT CODE					PRIME COMPONENT SUPPLIER	COMPONENT MANUFACTURER				VIOLATION		
C	D	E	I	N	S	T	R	U	N	B	O	8	O	Y	
9	10	11	12					17	43	44				47	48

08	Instrument drift. The switch is a Barton Model 288 PDIS. This was t	80
09	he first instance of drift with this switch and no further corrective	80
10	action is deemed necessary at this time.	80

11	FACILITY STATUS E	% POWER 064	OTHER STATUS NA	METHOD OF DISCOVERY B	DISCOVERY DESCRIPTION Surveillance Test
7 8	9	10 11 12	13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43	44 45	46 47 48 49 50 51 52 53 54 55 56 57 58 59 60
12	FORM OF ACTIVITY RELEASED Z	CONTENT OF RELEASE Z	AMOUNT OF ACTIVITY NA	LOCATION OF RELEASE NA	
7 8	9	10 11	12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43	44 45	46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

NUMBER			TYPE	DESCRIPTION
1	3	0 0 0	Z	NA

NUMBER			DESCRIPTION
14	0	0	NA

1	5	NA
---	---	----

TYPE		DESCRIPTION
16	Z	NA

17	NA
----	----

18	NA
----	----

19

GPO 861-567

W. Latham

IOWA ELECTRIC LIGHT AND POWER COMPANY

DUANE ARNOLD ENERGY CENTER
P. O. Box 351
Cedar Rapids, Iowa 52406

December 7, 1976
DAEC - 76 - 383

Mr. James G. Keppler, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission - Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Subject: Licensee Event Report No. 76-78
(30 day)

File: A-118a

Dear Mr. Keppler:

In accordance with Appendix A to Operating License DPR-49, Technical Specifications and Bases for Duane Arnold Energy Center and Regulatory Guide 10.1, please find attached a copy of the subject Licensee Event Report. (Total of 3 copies transmitted)

Very truly yours,

G. G. Hunt ELH
G. G. Hunt
Chief Engineer
Duane Arnold Energy Center

Docket 50-331

attachment

GGH/DLW/mg

cc: Director, Office of Inspection and Enforcement (30)
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Director, Management Information and Program Control (3)
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

DEC 9 1976

