

AEC DISTRIBUTION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)

CONTROL NO: 6128

FILE: AJO

FROM: Iowa Electric Light & Power Co. Cedar Rapids, Iowa Mr. G.G. Hunt			DATE OF DOC 6-20-74		DATE REC'D 6-29-74		LTR X	TWX	RPT	OTHER
TO: J. Keppler			ORIG 1 signed		CC	OTHER	SENT AEC PDR <u>XXX</u>		SENT LOCAL PDR <u>XXX</u>	
CLASS	UNCLASS <u>XXX</u>	PROP INFO	INPUT		NO CYS REC'D 1		DOCKET NO: 50-331			

DESCRIPTION:
Ltr reporting an abnormal occurrence at the Duane Arnold Energy Center Unit #1....concerning the DAEC Surveillance Test Procedure No. STP-42A001...Daily and Shift Instrument Control. Checks.....

ENCLOSURES:

ACKNOWLEDGED

DO NOT REMOVE

PLANT NAME: Duane Arnold

FOR ACTION/INFORMATION

7-9-74

JB

BUTLER (L)	SCHWENCER (L)	ZIEMANN (L)	REGAN (E)
W/ CYS	W/ CYS	W/ CYS	W/ CYS
CLARK (L)	STOLZ (L)	DICKER (E)	<u>Lear</u>
W/ CYS	W/ CYS	W/ CYS	W/ 7 CYS
DAPP (L)	VASSALLO (L)	KNIGHTON (E)	
W/ CYS	W/ CYS	W/ CYS	W/ CYS
KNIEL (L)	PURPLE (L)	YOUNGBLOOD (E)	
W/ CYS	W/ CYS	W/ CYS	W/ CYS

INTERNAL DISTRIBUTION

<u>REG FILE</u>	<u>TECH REVIEW</u>	DENTON	<u>LIC ASST</u>	<u>A/T IND</u>
✓ AEC PDR	✓ HENDRIE	GRIMES	DIGGS (L)	BRAITMAN
✓ OGC	✓ SCHROEDER	GAMMILL	GEARIN (L)	SALTZMAN
✓ MUNTZING/STAFF	✓ MACCARY	KASTNER	GOULBOURNE (L)	B. HURT
✓ CASE	✓ KNIGHT	BALLARD	KREUTZER (E)	
GIAMBUSSO	✓ PAWLICKI	SPANGLER	LEE (L)	<u>PLANS</u>
BOYD	✓ SHAO		MAIGRET (L)	MCDONALD
MOORE (L)(LWR-2)	✓ STELLO	<u>ENVIRO</u>	REED (E)	CHAPMAN
DEYOUNG (L)(LWR-1)	✓ HOUSTON	MULLER	SERVICE (L)	DUBE w/input
SKOVHOLT (L)	✓ NOVAK	DICKER	SHEPPARD (L)	E. COUPE
✓ GOLLER (L)	✓ ROSS	KNIGHTON	SLATER (E)	
P. COLLINS	✓ IPPOLITO	YOUNGBLOOD	SMITH (L)	✓ D. THOMPSON (2)
DENISE	✓ TEDESCO	REGAN	✓ TEETS (L)	✓ KLECKER
✓ REG OPR	✓ LONG	PROJECT MGR	WILLIAMS (E)	✓ EISENHUT
FILE & REGION (3)	✓ LAINAS		WILSON (L)	
✓ MORRIS	✓ BENAROYA	HARLESS		
✓ STEELE	✓ VOLLMER			

EXTERNAL DISTRIBUTION

✓ 1 - LOCAL PDR Cedar Rapids, Iowa.	(1)(2)(10)-NATIONAL LABS	1-PDR-SAN/LA/NY
✓ 1 - TIC (ABERNATHY)	1-ASLBP(E/W Bldg, Rm 529)	1-BROOKHAVEN NAT LAB
✓ 1 - NSIC (BUCHANAN)	1-W. PENNINGTON, Rm E-201 GT	1-G. ULRICKSON, ORNL
1 - ASLB	1-B&M SWINEBROAD, Rm E-201 GT	1-AGMED (RUTH GUSSMAN)
1 - P. R. DAVIS	1-CONSULTANTS	Rm B-127 GT
✓ 16 - ACRS HOLDING Sent to Teets	NEWMARK/BLUME/AGBABIAN	1-RD..MUELLER, Rm F-309
7-9-74		GT

86

IOWA ELECTRIC LIGHT AND POWER COMPANY

General Office

CEDAR RAPIDS, IOWA

DUANE ARNOLD ENERGY CENTER

PALO, IOWA

JUNE 20, 1974

DAEC - 74 - 229




50-331

Mr. James Keppler, Director
Regulatory Operations Regional Office
U. S. Atomic Energy Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

SUBJECT: License DPR-49, Duane Arnold Energy Center,
Unit 1, Specification 4.2.F of Appendix A
to the Operating License.

REFERENCE: DAEC Surveillance Test Procedure No. STP-42A001,
Daily and Shift Instrument Checks.

FILE: A-110
A-117



Dear Mr. Keppler:

This letter is to report to you with respect to certain Technical
Specification Surveillance requirements at the Duane Arnold Energy Center.

Problem

On May 30, 1974, it was noted that Appendix A (Control Rod Position
Check) to STP-42A001 was not completed for May 25 and 26 and on June 12, 1974
it was noted that Appendix A was not completed for May 30 and June 2 and 5, 1974.

Investigation

The Control Rod Position Check is to be performed once per shift and
consists of reviewing the computer printout for any unknown rod positions and
verifying the "Full-Out" and "Full-In" indicating lights on the display panel
against the computer printout. A copy of the computer printout showing the
control rod positions is also to be attached to the STP for each shift. On
the dates in question the sign-off sheet was checked-off in some instances,
but the computer printout was not attached for each shift and in some cases the
sign-off sheet was not checked and the printout was not attached either.
The balance of the surveillance test was completed as required. The operator
performing the test feels that he completed all the checks required, but
inadvertently did not check off the step when it was completed and neglected
to attach the computer printout after reviewing it as required.

JUN 27 1974

6123

6/20/74

There is no safety concern involved because Reactor Engineering is providing 24-hour coverage in the control room to monitor all control rod movements. In addition, all of the occurrences except one took place at less than 30% power so that the Rod Sequence Control System and the Rod Worth Minimizer were operable to restrict out-of-sequence rod movement. During the other period when this test was missed the reactor was at 32% power so RSCS and RWM were not operable, but there was coverage by Reactor Engineering.

Corrective Actions

Personnel performing the surveillance tests were cautioned to be sure and complete and check off all steps required by the surveillance test. In addition, the Operations Supervisor issued a directive to the Shift Supervising Engineers to review the surveillance test on completion to assure that every thing was completed as required. If any step has been deleted there will then still be time to go back and complete the test within the time limit specified by the Technical Specifications.

Very truly yours,



G. G. Hunt
Chief Engineer
Duane Arnold Engery Center

OCS/GGH/bh

CC: John O'Leary
Washington, D.C.

C. W. Sandford
J. A. Wallace
E. L. Hammond
B. R. York
D. A. Moen
D. L. Wilson
H. W. Rehrauer-Chairman, Safety Committee
L. D. Root
J. R. Newman
O. C. Schellberg
B. L. Hopkins
T. F. Bresaw