

AEC DISTRIBUTION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)

CONTROL NO: 4661

FILE: A10

FROM: Iowa Electric Light & Power Co. Cedar Rapids, Iowa G. G. Hunt			DATE OF DOC 5-21-74	DATE REC'D 5-24-74	LTR X	MEMO	RPT	OTHER
TO: James G. Keppler			ORIG 1	CC 1	OTHER	SENT AEC PDR <u>XXX</u> SENT LOCAL PDR <u>XXX</u>		
CLASS XXX	UNCLASS	PROP INFO	INPUT	NO CYS REC'D 2		DOCKET NO: 50-331		

DESCRIPTION:

Ltr trans the following.....

PLANT NAME:

ENCLOSURES:

Abnormal Occurrence Rpt #DPR 49/74-5 of 5-14-74 in which safety system pressure switch setting was less conservative than the limiting in Tech Specs

ACKNOWLEDGED
DO NOT REMOVE

FOR ACTION/INFORMATION

BUTLER(L) W/ 7 Copies	SCHWENCER(L) W/ Copies	ZIEMANN(L) W/ Copies	REGAN(E) W/ Copies
CLARK(L) W/ Copies	STOLZ(L) W/ Copies	DICKER(E) W/ Copies	
PARR(L) W/ Copies	VASSALLO(L) W/ Copies	KNIGHTON(E) W/ Copies	
KNIEL(L) W/ Copies	PURPLE (L) W/ Copies	YOUNGBLOOD(E) W/ Copies	

INTERNAL DISTRIBUTION

<u>REG FILE</u> AEC PDR OGC, ROOM P-506A MUNTZING/STAFF CASE <u>W</u> GIAMBUSO BOYD MOORE (L) (FWR) DEYOUNG (L) (FWR) SKOVHOLT (L) GOLLER(L) P. COLLINS DENISE REG OPR FILE & REGION(3) MORRIS	<u>TECH REVIEW</u> HENDRIE SCHROEDER MACCARY <u>W</u> KNIGHT PAWLICKI SHAO STELLO <u>W</u> HOUSTON NOVAK ROSS IPPOLITO TEDESCO <u>W</u> LONG LAINAS BENAROYA VOLLMER	DENTON GRIMES GAMMILL KASTNER BALLARD SPANGLER ENVIRO MULLER DICKER KNIGHTON YOUNGBLOOD REGAN PROJECT LDR HARLESS	LIC ASST DIGGS (L) GEARIN (L) GOULBOURNE (L) LEE (L) MAIGRET (L) REED (E) SERVICE (L) SHEPPARD (L) SLATER (E) SMITH (L) TEETS (L) WADE (E) WILLIAMS (E) WILSON (L)	<u>A/T IND</u> BRAITMAN SALTZMAN B. HURT <u>PLANS</u> MCDONALD DUBE w/Input <u>INFO</u> C. MILES KLECKER EISENHUT <u>AOR FILE</u> D. THOMPSON (2)
---	--	--	--	---

EXTERNAL DISTRIBUTION

1 - LOCAL PDR CEDAR RAPIDS, IOWA	(1) (2X10) NATIONAL LAB'S	1-PDR-SAN/LA/NY
1 - TIC (ABERNATHY)	1-ASLBP (E/W Bldg, Rm 529)	1-GERALD LELLOUCHE
1 - NSIC (BUCHANAN)	1-W. PENNINGTON, Rm E-201 GT	BROOKHAVEN NAT. LAB
1 - ASLB	1-CONSULTANT'S	1-AGMED (Ruth Gussman)
1 - P. R. DAVIS (AEROJET NUCLEAR)	NEWMARK/BLUME/AGBABIAN	RM-B-127, GT.
16 - CYS ACRS HOLDING	1-GERALD ULRICKSON...ORNL	1-RD..MULLER..F-309 GT
Sent to Lic Asst Maigret 5-28-74	1-B & M SWINEBROAD, Rm E-201 GT	



LB

IOWA ELECTRIC LIGHT AND POWER COMPANY

General Office

CEDAR RAPIDS, IOWA
DUANE ARNOLD ENERGY CENTER

PALO, IOWA
MAY 21, 1974
DAEC - 74 - 1934



Mr. James G. Keppler
Regional Director
Directorate of Regulatory Operations
U. S. Atomic Energy Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

50-331

SUBJECT: Abnormal Occurrence No. DPR 49/74-5
FILE: A-118a

Dear Mr. Keppler:

In accordance with Appendix A to Operating License DPR-49, Technical Specifications and Bases for Duane Arnold Energy Center, please find enclosed a written report on the subject abnormal occurrence. Mr. D. Boyd, of your office, was notified of the occurrence by telephone approximately 1645 hours on May 14, 1974.

Very truly yours,

G. G. Hunt
Chief Engineer
Duane Arnold Energy Center

Enclosure
DLW/GGH/bh

CC: John O'Leary
Washington, D.C.
C. W. Sandford
J. A. Wallace
E. L. Hammond
B. R. York
D. L. Wilson
H. W. Rehrauer-Chairman, Safety Committee
L. D. Root
J. Newman
B. Hopkins

REGULATORY DOCKET FILE COPY

4661

IOWA ELECTRIC LIGHT AND POWER COMPANY

General Office

CEDAR RAPIDS, IOWA

DUANE ARNOLD ENERGY CENTER
PALO, IOWA

Subject: Abnormal Occurrence

Report Number: DPR 49/74-5

Report Date: May 18, 1974

Occurrence Date: May 14, 1974

Facility: Duane Arnold Energy Center, Unit No. 1, Palo, Iowa

Identification of Occurrence

Safety System pressure switch setting less conservative than the limiting setting established in the Technical Specifications, Section 3.2.B (Containment High Pressure).

Conditions Prior to Occurrence

1. Routine Startup Operation
2. Reactor Subcritical
3. Reactor Water Temperature (Bottom Head Drain) - 183°F.
4. Reactor Pressure - atmospheric, vents open

Description of Occurrence

During the conduct of Surveillance Test No. 42B004 - Drywell High Pressure (RHR) Instrument Functional Test and Calibration, it was determined that pressure switch 4311C (Channel B1) tripped at 2.12 psig.

Designation of Apparent Cause of Occurrence

The apparent cause of the occurrence was instrument drift. No other cause could be determined.

Analysis of Occurrence

The occurrence has been analyzed and it has been determined that it did not have a deleterious effect on plant safety. This conclusion is based on the following:

Abnormal Occurrence DPR 49/74-5

5/18/74

1. During the Surveillance Test, a redundant pressure switch in the same trip channel was determined to be operable and within Technical Specification limits.
2. During the Surveillance Test, the switch tripped .02 psig above the Technical Specifications limit of 2.1 psig. (Table 3.2-B limit of 2.0 psig plus an instrument tolerance of +.1 psig). This deviation from Technical Specification limits is not considered significant.
3. The subject pressure switch is a component of the logic which prevents inadvertent operation of the Containment Spray System at low drywell pressures. Although the pressure switch trip setting was outside of limits set forth in the Technical Specifications, the deviation was in the conservative direction.
4. In accordance with Section 5.2.9 of Amendment 2 to the Duane Arnold Energy Center Final Safety Analysis Report, the Containment Spray System is not required for plant safety.


Corrective Action

The subject pressure switch was immediately calibrated and functionally tested. The functional test indicated that the switch was operating properly.

A program to monitor trends in Surveillance Test data is now being formulated. Such a program will help identify instruments with excessive drift characteristics and help prevent repetition of like occurrences.

Conclusion

The contents of this report including corrective actions were reviewed and approved by the D.A.E.C. Operations Committee on May 18, 1974. The Committee concluded that the health and safety of the public and plant personnel was not impaired.



G. G. Hunt
Chief Engineer
Duane Arnold Energy Center

DLW/GGH/mg