

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)

CONTROL NO: 3174

FILE: INCIDENT REPORT FILE

FROM: Iowa Elec. Light & Pwr. Co. Cedar Rapids, Iowa G.G. Hunt		DATE OF DOC 3-17-75	DATE REC'D 3-24-75	LTR XX	TWX	RPT	OTHER
TO: James Keppler		ORIG 1 Signed	CC	OTHER	SENT AEC PDR <u>XXX</u> SENT LOCAL PDR <u>XXX</u>		
CLASS	UNCLASS XXX	PROP INFO	INPUT	NO CYS REC'D 1	DOCKET NO: 50-331		

DESCRIPTION: Re: Abnormal Occurrence# 75/12
Ltr. Ref. advising that after subsequent investigation Iowa Elec. has determined that this does not constitute an Abnormal Occurr...

ENCLOSURES:

PLANT NAME: Duane Arnold

DO NOT REMOVE
ACKNOWLEDGED

FOR ACTION/INFORMATION

VCR 3-27-75

BUTLER (L) W/ Copies	SCHWENCER (L) W/ Copies	ZIEMANN (L) W/ Copies	REGAN (E) W/ Copies
CLARK (L) W/ Copies	STOLZ (L) W/ Copies	DICKER (E) W/ Copies	LEAR (L) W/ Copies
PARR (L) W/ Copies	VASSALLO (L) W/ Copies	KNIGHTON (E) W/ Copies	SPELS W/ Copies
KNIEL (L) W/ Copies	PURPLE (L) W/ Copies	YOUNGBLOOD (E) W/ Copies	

INTERNAL DISTRIBUTION

<u>REG FILE</u> - NRC PDR - OGC, ROOM P-506A - GOSSICK/STAFF - CASE - GIAMBUSSO - BOYD - MOORE (L) - DEYOUNG (L) - SKOVHOLT (L) - GOLLER (L) (Ltr) - P. COLLINS - DENISE - REG OPR - FILE & REGION (2) - T.R. WILSON (3) - STEELE	<u>TECH REVIEW</u> - SCHROEDER - MACCARY - KNIGHT - PAWLICKI - SHAO - ** STELLO - ** HOUSTON - ** NOVAK - ROSS - IPPOLITO - TEDESCO - LONG - LAINAS - BENAROYA - VOLLMER	<u>DENTON</u> - ** GRIMES - GAMMILL - KASTNER - BALLARD - SPANGLER <u>ENVIRO</u> - MULLER - DICKER - KNIGHTON - YOUNGBLOOD - REGAN - PROJECT LDR <u>HARLESS</u>	<u>LIC ASST</u> - R. DIGGS (L) - H. GEARIN (L) - E. GOULBOURNE (L) - P. KREUTZER (E) - J. LEE (L) - M. MAIGRET (L) - S. REED (E) - M. SERVICE (L) - S. SHEPPARD (L) - M. SLATER (E) - H. SMITH (L) - S. TEETS (L) - G. WILLIAMS (E) - V. WILSON (L) - R. INGRAM (L)	<u>A/T IND.</u> - BRAITMAN - SALTZMAN - MELTZ <u>PLANS</u> - MCDONALD - CHAPMAN - DUBE (Ltr) - E. COUPE - PETERSON - HARTFIELD (2) - KLECKER - EISENHUT - WIGGINTON - F. WILLIAMS - HANAUER
---	---	--	--	--

EXTERNAL DISTRIBUTION

1 - LOCAL PDR <u>CEEDAR RAPIDS, Iowa</u>	1 - NATIONAL LABS	1 - PDR-SAN/LA/NY
1 - TIC (ABERNATHY) (1)(2)(10)	1 - W. PENNINGTON, Rm E-201 GT	1 - BROOKHAVEN NAT LAB
1 - NSIC (BUCHANAN)	1 - CONSULTANTS	1 - G. ULRIKSON, ORNL
1 - ASLB	NEWMARK/BLUME/AGBABIAN	1 - AGMED (RUTH GUSSMAN) Rm B-127 GT
1 - Newton Anderson		1 - J. D. RUNKLES, Rm E-201 GT
5 - ACRS SENT TO LIC ASST		
** SEND ONLY TEN DAY REPORTS		

IOWA ELECTRIC LIGHT AND POWER COMPANY

General Office



CEDAR RAPIDS, IOWA
DUANE ARNOLD ENERGY CENTER

PALO, IOWA

MARCH 17, 1974

DAEC-75-114

Mr. James Keppler, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission-Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137



SUBJECT: Abnormal Occurrence A.O. 50-331/75-12

REFERENCE: Telecopy letter, Mr. G. G. Hunt, Iowa Electric
Light & Power Company to Mr. James Keppler,
Nuclear Regulatory Commission, dated March 11, 1975.
SUBJECT: Abnormal Occurrence No. 50-331/75-12.

FILE: A-110, A-118a

Dear Mr. Keppler:

On March 11, 1975, you were notified of an abnormal occurrence involving an inoperable Standby Gas Treatment System (SGTS) Isolation Damper (AO 50-331/75-12). Subsequent investigation has determined that the subject isolation damper is not a safety related component and not part of the SGTS. The malfunction of the damper did not effect the operability of the SGTS and the system was operable at all times in compliance with Specification 3.7.B.1 of Appendix A to Operating License DPR-49. Therefore, the malfunction of the damper did not constitute an abnormal occurrence as previously reported.

It is our intention that this letter completes reporting action on this item and that a Ten-day Written Report is not required.

The DAEC Operations Committee concurred with this action on March 17, 1975.

We apologize for any inconvenience caused by this action.

Very truly yours,

G. G. Hunt
Chief Engineer
Duane Arnold Energy Center

DLW:GGH:bh

CC: E. G. Case	L. D. Root
C. W. Sandford	H. W. Rehrauer-Chairman, Safety Committee
J. A. Wallace	D. L. Wilson
E. L. Hammond	G. A. Cook
B. R. York	J. R. Newman
R. R. Rinderman	B. L. Hopkins

3174

MAR 20 1975

IOWA ELECTRIC LIGHT AND POWER COMPANY

General Office

CEDAR RAPIDS, IOWA
DUANE ARNOLD ENERGY CENTER

PALO, IOWA

MARCH 17, 1974

DAEC-75-114

Mr. James Keppler, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission-Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

3-17-75
3174

SUBJECT: Abnormal Occurrence A.O. 50-331/75-12

REFERENCE: Telecopy letter, Mr. G. G. Hunt, Iowa Electric
Light & Power Company to Mr. James Keppler,
Nuclear Regulatory Commission, dated March 11, 1975.
SUBJECT: Abnormal Occurrence No. 50-331/75-12.

FILE: A-110, A-118a

Dear Mr. Keppler:


On March 11, 1975, you were notified of an abnormal occurrence involving an inoperable Standby Gas Treatment System (SGTS) Isolation Damper (AO 50-331/75-12). Subsequent investigation has determined that the subject isolation damper is not a safety related component and not part of the SGTS. The malfunction of the damper did not effect the operability of the SGTS and the system was operable at all times in compliance with Specification 3.7.B.1 of Appendix A to Operating License DPR-49. Therefore, the malfunction of the damper did not constitute an abnormal occurrence as previously reported.

It is our intention that this letter completes reporting action on this item and that a Ten-day Written Report is not required.

The DAEC Operations Committee concurred with this action on March 17, 1975.

We apologize for any inconvenience caused by this action.

Very truly yours,



G. G. Hunt
Chief Engineer
Duane Arnold Energy Center

DLW:GGH:bh

CC: E. G. Case ✓	L. D. Root
C. W. Sandford	H. W. Rehrauer-Chairman, Safety Committee
J. A. Wallace	D. L. Wilson
E. L. Hammond	G. A. Cook
B. R. York	J. R. Newman
R. R. Rinderman	B. L. Hopkins