

AEC DISTRIBUTION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)

CONTROL NO: 11290

FILE: _____

FROM: Iowa Elec. Light & Power Co. Palo, Iowa G.G. Hunt		DATE OF DOC 10-25-74	DATE REC'D 11-4-74	LTR X	TWX	RPT	OTHER
TO: E. Case		ORIG 1 signed	CC	OTHER	SENT AEC PDR <u>XX</u>		SENT LOCAL PDR <u>XX</u>
CLASS	UNCLASS XX	PROP INFO	INPUT	NO CYS REC'D 1	DOCKET NO: 50-331		

DESCRIPTION: Ltr reporting that on 10-21-74 it was noted that the off gas stack particulate filter & iodine cartridge had not been monitored & recorded in accordance with Spec. 3.3.1.C.1...

PLANT NAME: Duane Arnold Energy Center

ENCLOSURES:

Do Not Remove
ACKNOWLEDGED

FOR ACTION/INFORMATION

DHL 11-5-74

BUTLER (L) W/ Copies	SCHWENCER (L) W/ Copies	ZIEMANN (L) W/ Copies	REGAN (E) W/ Copies
CLARK (L) W/ Copies	STOLZ (L) W/ Copies	DICKER (E) W/ Copies	LEAR (L) W/ Copies
PARR (L) W/ Copies	VASSALLO (L) W/ Copies	KNIGHTON (E) W/ Copies	YOUNGBLOOD (E) W/ Copies
KNIEL (L) W/ Copies	PURPLE (L) W/ Copies	YOUNGBLOOD (E) W/ Copies	

INTERNAL DISTRIBUTION

REG FILE	TECH REVIEW	DENTON	LIC ASST	A/T IND
AEC PDR	SCHROEDER	GRIMES	DIGGS (L)	BRAITMAN
AGC, ROOM P-506A	MACCARY	GAMMILL	GEARIN (L)	SALTZMAN
MUNTZING/STAFF	NIGHT	KASTNER	GOULBOURNE (L)	B. HURT
CASE	PAWLICKI	BALLARD	KREUTZER (E)	PLANS
GIAMBUSO	CHAO	SPANGLER	LEE (L)	MCDONALD
BOYD	STELLO	ENVIRO	MAIGRET (L)	CHAPMAN
MOORE (L) (BWR)	BOUSTON	MULLER	REED (E)	DUBE w/input
DEYOUNG (L) (PWR)	NOVAK	DICKER	SERVICE (L)	E. COUPE
SKOVHOLT (L)	ROSS	KNIGHTON	SHEPPARD (L)	
GOLLER (L)	PPOLITO	YOUNGBLOOD	SLATER (E)	D. THOMPSON (2)
P. COLLINS	TEDESCO	REGAN	SMITH (L)	KLECKER
DENISE	LONG	PROJECT LDR	TEETS (L)	EISENHUT
REG OPR	AINAS	HARLESS	WILLIAMS (E)	
FILE & REGION (3)	BENAROYA		WILSON (L)	
MORRIS	VOLIMER			
STEELE				

EXTERNAL DISTRIBUTION

- ✓ LOCAL PDR Cedar Rapids, Iowa
- ✓ TIC (ABERNATHY) (1)(2)(10) - NATIONAL LABS
- ✓ 1 - NSIC (BUCHANAN) 1 - ASLBP (E/W Bldg, Rm 529)
- 1 - ASLB 1 - W. PENNINGTON, Rm E-201 GT
- 1 - Newton Anderson 1 - B&M SWINEBROAD, Rm E-201 GT
- 50 - ACRS ~~XXXX~~ SENT TO 1 - CONSULTANTS
- LIC. ASST. XXXX S. TEETS LL-5-NEWMARK/BLUME/AGBABIAN
- 1 - PDR-SAN/LA/NY
- 1 - BROOKHAVEN NAT LAB
- 1 - G. ULRIKSON, ORNL
- 1 - AGMED (RUTH GUSSMAN) Rm B-127 GT
- 1 - R. D. MUELLER, Rm E-201 GT

[Faint, illegible text covering the upper half of the page]

[Faint, illegible text covering the lower half of the page]

50331



IOWA ELECTRIC LIGHT AND POWER COMPANY

General Office

CEDAR RAPIDS, IOWA
DUANE ARNOLD ENERGY CENTER
PALO, IOWA
OCTOBER 25, 1974
DAEC - 74-380

Regulatory ~~File~~ Cy.

Mr. Edson G. Case
U. S. Atomic Energy Commission
Directorate of Licensing
1717 H Street N. W.
Washington, D.C. 20545



SUBJECT: Technical Specification Violation 74-10
FILE: A-110 A-117

Dear Mr. Case:

This letter is to report to you in accordance with Appendix B, Operating License DPR-49, Specification 5.4.2.1A.

Problem

On October 21, 1974, it was noted that the off gas stack particulate filter and iodine cartridge had not been monitored and recorded in accordance with Specification 3.3.1.C.1.

Investigation

The Technical Specifications require that the particulate and iodine activity released from the off gas stack is to be monitored and recorded weekly. The iodine activity (charcoal filter) is analyzed for I-131 and particulate filter for gross beta and gamma scan, in accordance with Table 3.3-2.

A sample was monitored and recorded on October 8, 1974, and not done again until October 18, 1974. The sample date was changed by a Laboratory Technician from Tuesdays to Fridays after the October 8, 1974 sample and the off gas stack requirement was inadvertently overlooked and not performed until October 18, 1974, a time span of ten days.

There was no danger to the health and safety of the public because the off gas stack effluent stream was continuously monitored and analysis on October 18, 1974 indicated the iodine and particulate delivery released over the ten day span did not exceed Technical Specification analysis limits as stated in Table 3.3-2.

11290

Corrective Actions

The Laboratory Technicians have been reinstructed on the requirement to obtain prior permission from the Radiation and Chemistry Department supervisory personnel prior to changing the sampling schedule of collection or analyses to be performed.

Conclusion

This report, including the corrective action, was reviewed and approved by the DAEC Operations Committee on October 29, 1974. The Committee concluded that the violation did not present a significant hazard to the health and safety of the public.

Very truly yours,



G. G. Hunt
Chief Engineer
Duane Arnold Energy Center

GAE:GGH:mg

cc: C. W. Sandford
J. A. Wallace
G. G. Hunt
B. R. York
E. L. Hammond
D. L. Wilson
H. W. Rehrauer-Chairman, Safety Committee
L. D. Root
J. R. Newman
B. L. Hopkins