AEC DISTRIBUTION FOR PART 50 DOCKET MATERIAL (TEMPORARY FORM)

			(TEIM OTT)				CON	TDOL NO	11007
					•		CON	INOLING	11007
				FILI				E:	
POM:	Iowa Electri	c Light & Pwr	DATE OF DOC	DATE	REC'D	LTR	TWX	RPT	OTHER
	Cedar Rapids		10-18-74	10-25		l		'''	0,11211
	GG Hunt	,	10-18-74	10-23	-/4	XX			
O:		ORIG			SE	ENT AEC PDRxx			
Mr. Keppler					none signed	SENT LOCAL PDR XX			
<u> </u>		DD0D 11150		1000	S REC <u>'</u> D	DOCKET NO:			
LASS	UNCLASS	PROP INFO	INPUT	NOCY					
•	XXXXXX			1		50	0-331		
ESCRI	PTION:	<u> </u>		ENCLO	SURES:	 		!	
74 con	ncerning sup h setting le	ccurrence #74 pression cham ss conserativ in Tech Spec	ber level e than the		D	ON	OT R	EMO	VE
					‡ c an	017777		. • •	
LANT	NAME: Duane	Arnold			A	CKI	IOW.	LEDG	ED
			FOR ACTION/	INFORM	IATION	10-29) _ 7/ı	ehf	
ITLE	D / L \	SCHWENCER		· · · · · · · · · · · · · · · · · · ·	REGAN		7-7-4	CIII	
		W/ Copies	W/ Copies W/ Copies						
LARK		STOLZ (L)	DICKER (E	1	LEAR (
		W/ Copies	W/ Copies W/4Copies			ies			•
		VASSALLO (I							
// Copies		W/ Copies	W/ Copies		W/.Cop	ies		-	•
NIEL (L)		PURPLE (L)	YOUNGBLO						
V/ Copies		W/ Copies	W/ Copies			ies			
ООР		- TT/ Copies	INTERNAL D	ICTRID					
	<u></u>	TEOU DEVUE		יםווווטוי		·	· · · · · · · · · · · · · · · · · · ·	Λ/T IN	<u> </u>
EG FILE EC PDR ·		TECH REVIE	<u>N DENTON</u> GRIMES	LIC ASST				<u>A/T IND</u> BRAITMAN	
GC, ROOM P-506A		S SCHROEDER	GAMMILL	*	DIGGS (L)			SALTZMAN	
		MACCARY	KASTNER	•	GEARIN (L)			B. HURT	
		KNIGHT	BALLARD		GOULBOURNE (L)			<i>5.</i> · · · <i>o</i> ·	• •
		PAWLICKI	SPANGLER		KREUTZER (E)			PLANS	
DYD		SHAO			LEE (L		-,	MCDO	
OORE (L) (BWR) STELLO		ENVIRO		MAIGRET (L)			CHAPMAN		
EYOUNG (L) (PWR) PHOUSTON			MULLER		REED (E)			DUBE w/input	
KOVHOLT (L) NOVAK			DICKER,		SERVICE (L)			E. COUPE	
	LLER (L) AROSS		KNIGHTON		SHEPPARD (L)			_	
COLL				YOUNGBLOOD SLATER					
ENISE	SE #TEDESCO					SMITH (L)			KER
EG OPR		PROJECT LDR		TEETS (L)			EISENHUT ,		
ILE & REGION (3) LAINAS			WILLIAMS ()		5 (2.3)	
ORRIS		BENAROYA	HARLESS	•	WILSO		•		
reele		VOLIMER	,		.,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	- 1 #			
	•		EXTERNAL D	ICTPIDI	ITION				
· · -	OAL DED C-	dom Dom 22		ioinib(711014				
1 – LO	CALPOR_Ce	dar Rapids, I	A.						

1 - ASLBP(E/W Bldg, Rm 529) 1 - W. PENNINGTON, Rm E-201 GT

1 - B&M SWINEBROAD, Rm E-201 GT

1 - PDR-SAN/LA/NY

Rm B-127 GT

GT

1 - BROOKHAVEN NAT LAB

1 - AGMED (RUTH GUSSMAN)

1 - R. D. MUELLER, Rm E-201

1 - G. ULRIKSON, ORNL

1 - TIC (ABERNATHY) (1)(2)(10) - NATIONAL LABS_

5-ACRS SENT TO LIC ASSITECTS - CONSULTANTS
NEWMARK/BLUME/AGBABIAN

1 – NSIC (BUCHANAN)

1 - Newton Anderson

1 - ASLB

REGULATORY DOCKET FILE COPY

WA ELECTRIC LIGHT AND POWER COMPANY

General Office

CEDAR RAPIDS. IOWA

DUANE ARNOLD ENERGY CENTER PALO, IOWA OCTOBER 18, 1974 DAEC - 74 - 362

Mr. Lames Keppler, Director Regulatory Operations Regional Office U. S. Atomic Energy Commission 799 Roosevelt Road Glen Ellyn, Illinois 60137

SUBJECT: Abnormal Occurrence No. DPR 50-331/74-42

FILE: A-118a A-110

Dear Mr. Keppler:

OCT 25 1974

In accordance with the DAEC Technical Specifications, Section 6.11.2A.1. this letter is intended as notification of an abnormal occurrence at the Duane Arnold Energy Center on October 18, 1974. This letter, telecopied to your office, is intended to satisfy the requirement for notification by telegram within 24 hours of the abnormal occurrence.

Identification of Occurrence

Suppression chamber level switch setting less conservative than the limiting setting established in the Technical Specifications, Section 3.2.B.

Description of Occurrence

During the conduct of Surveillance Test Procedure No. 42B020, Suppression Chamber High Water Level Instrument Functional Test, it was determined that the trip setting of level switch LS 2319 was 13 feet 3 3/8 inches. Considering a limit of 13 feet 2 3/4 inches and an instrument tolerance of + 1/2 inch, allowed by Technical Specification, paragraph 2, the setting should have been within 13 feet 2 1/4 inches to 13 feet 3 1/4 inches.

A formal written report will be submitted to the Office of the Directorate of Regulatory Operations within 10 days of the subject abnormal occurrence.

G. G. Hunt Chief Engineer

Duane Arnold Energy Center

DLW: GGH: bh

CC: VE. G. Case

C. W. Sandford

J. A. Wallace

E. L. Hammond

B. R. York

L. D. Root

H. W. Rehrauer, Chairman, Safety Committee

B. L. Hopkins

D. L. Wilson

11007