

**AEC DISTRIBUTION FOR PART 50 DOCKET MATERIAL**  
(TEMPORARY FORM)

CONTROL NO: 9401

FILE:

<b>FROM:</b> Iowa Electric Light and Power Co Cedar Rapids, Iowa GG Hunt		<b>DATE OF DOC</b> 9-5-74		<b>DATE REC'D</b> 9-12-74		<b>LTR</b> XX	<b>TWX</b>	<b>RPT</b>	<b>OTHER</b>
<b>TO:</b> Mr Keppler		<b>ORIG</b> 1 signed		<b>CC</b>	<b>OTHER</b>	<b>SENT AEC PDR</b> XX <b>SENT LOCAL PDR</b> XX			
<b>CLASS.</b>	<b>UNCLASS</b> XXXX	<b>PROP INFO</b>	<b>INPUT</b>	<b>NO CYS REC'D</b> 1		<b>DOCKET NO:</b> 50-331			

**DESCRIPTION:**

Ltr trans the following:

**ENCLOSURES:**

REPORT: Abnormal Occurrence #74-34 on kj  
8-26-74 re high suppression chamber water  
level.

**PLANT NAME:**

Duane Arnold Energy Center, Unit 1

(1 cy rec'd)

FOR ACTION/INFORMATION

9-12-74 ehf

BUTLER (L)	SCHWENCER (L)	ZIEMANN (L)	REGAN (E)
W/ CYS	W/ CYS	W/ CYS	W/ CYS
CLARK (L)	STOLZ (L)	DICKER (E)	✓LEAR
W/ CYS	W/ CYS	W/ CYS	W/4 CYS
BAER (L)	VASSALLO (L)	KNIGHTON (E)	
W/ CYS	W/ CYS	W/ CYS	W/ CYS
KNIEL (L)	PURPLE (L)	YOUNGBLOOD (E)	
W/ CYS	W/ CYS	W/ CYS	W/ CYS

**INTERNAL DISTRIBUTION**

✓ <del>REG FILE</del>	<u>TECH REVIEW</u>	DENTON	<u>LIC ASST</u>	<u>A/T IND</u>
✓AEC PDR		GRIMES	DIGGS (L)	BRAITMAN
✓OGC	✓SCHROEDER	GAMMILL	GEARIN (L)	SALTZMAN
✓MUNTZING/STAFF	✓MACCARY	KASTNER	GOULBOURNE (L)	B. HURT
✓CASE	✓KNIGHT	BALLARD	KREUTZER (E)	
GIAMBUSSO	✓PAWLICKI	SPANGLER	LEE (L)	<u>PLANS</u>
BOYD	✓SHAO		MAIGRET (L)	MCDONALD
MOORE (L)(LWR-2)	✓STELLO	<u>ENVIRO</u>	REED (E)	CHAPMAN
✓DEYOUNG (L)(LWR-1)	✓HOUSTON	MULLER	SERVICE (L)	DUBE w/input
SKOVHOLT (L)	✓NOVAK	DICKER	SHEPPARD (L)	E. COUPE
GOLLER (L)	✓ROSS	KNIGHTON	SLATER (E)	
P. COLLINS	✓IPPOLITO	YOUNGBLOOD	SMITH (L)	✓D. THOMPSON (2)
DENISE	✓TEDESCO	REGAN	✓TEETS (L)	✓KLECKER
✓REG OPR	✓LONG	PROJECT MGR	WILLIAMS (E)	✓EISENHUT
FILE & REGION (2)	✓LAINAS		WILSON (L)	
✓MORRIS	✓BENAROYA	HARLESS		
✓STEELE	✓VOLLMER			

**EXTERNAL DISTRIBUTION**


✓1 - LOCAL PDR Cedar Rapids, Ia	(1)(2)(10)-NATIONAL LABS	1-PDR-SAN/LA/NY
✓1 - TIC (ASERNATHY)	1-ASLBP(E/W Bldg, Rm 529)	1-BROOKHAVEN NAT LAB
✓1 - NSIC (BUCHANAN)	1-W. PENNINGTON, Rm E-201 GT	1-G. ULRIKSON, ORNL
1 - ASLB	1-B&M SWINEBROAD, Rm E-201 GT	1-AGMED (RUTH GUESSMAN)
1 - Newton Anderson	1-CONSULTANTS	Rm B-127 GT
5 - ACRS SENT TO LIC ASST		

# Regulatory Docket File

## IOWA ELECTRIC LIGHT AND POWER COMPANY

General Office

CEDAR RAPIDS, IOWA  
DUANE ARNOLD ENERGY CENTER  
PALO, IOWA  
SEPTEMBER 5, 1974  
DAEC - 74 - 315



Mr. James G. Keppler, Director  
Regulatory Operations Regional Office  
U. S. Atomic Energy Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

SUBJECT: Abnormal Occurrence No. DPR 50-331/74-34  
FILE: A-118a

Dear Mr. Keppler:


In accordance with Appendix A to Operating License DPR-49, Technical Specifications and Bases for Duane Arnold Energy Center, please find enclosed a written report on the subject abnormal occurrence.

Very truly yours,

G. G. Hunt  
Chief Engineer  
Duane Arnold Energy Center

JSA:GGH:bh  
Enclosure

CC: E. G. Case  
C. W. Sandford  
J. A. Wallace  
E. L. Hammond  
B. R. York  
D. L. Wilson  
O. C. Schellberg  
L. D. Root  
J. S. Anderson  
H. W. Rehrauer  
J. R. Newman  
G. A. Engle  
B. L. Hopkins



SEP 9 1974

9401

# IOWA ELECTRIC LIGHT AND POWER COMPANY

*General Office*

CEDAR RAPIDS, IOWA

Subject: Abnormal Occurrence

Report Number: AO 50-331/74-34

Report Date: September 5, 1974

Occurrence Date: August 26, 1974

Facility: Duane Arnold Energy Center, Unit #1, Palo, Iowa

## Identification of Occurrence

High Suppression Chamber water level reportable per Appendix A, Operating License DPR-49, Specification 1.0.4.b.

## Conditions Prior to Occurrence

Reactor critical in Hot Standby condition with Main Steam Isolation Valves closed and the Steam Condensing Mode of the RHR System initiated. The purpose of the isolation was to repair minor steam leaks in the secondary side of the plant.

## Description of Occurrence

At 0645 on August 26, 1974, the Steam Condensing Mode of the RHR System was initiated and Suppression Chamber water level began increasing as expected. The level continued to increase because the Radwaste System had insufficient available volume at that time to allow pumping of the Suppression Chamber.

The level reached the trip level setting (5" above normal water level) at 0800 on August 26, 1974. For the next 8 1/2 hours the level fluctuated between 5" and 6 1/2" above normal level as the Suppression Chamber was pumped to the Radwaste System as volume became available. At 1630 on August 26, 1974, the level was pumped to within specification.

## Designation of Apparent Cause of Occurrence

The cause of the occurrence was operating personnel error in initiating the Steam Condensing Mode of the RHR System without prior assurance that the Radwaste System had the capability to process excess water from the Suppression Chamber.

Analysis of Occurrence

The occurrence did not present an unsafe plant condition. During the occurrence the plant was in a hot standby condition and plans were made to place the plant in a cold shutdown condition within 24 hours if Suppression Chamber water level could not be restored to normal.

Corrective Action

Throughout the occurrence, Suppression Chamber water level was maintained as low as that permitted by the available capacity of the Radwaste System and it was returned to within the specified band as soon as possible.

All Operating Personnel have been reinstructed to assure they consider the Radwaste System capacity whenever performing any plant operations involving discharge to the Radwaste System.

Conclusion

On September 4, 1974, the DAEC Operations Committee reviewed and approved this report. The Committee concluded that the occurrence did not present a hazard to the health and safety of the public.



G. G. Hunt  
Chief Engineer  
Duane Arnold Energy Center

JSA:GGH:bh