

50-331

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER
INCIDENT REPORT

TO: Mr. James G. Keppler

FROM: Iowa Electric Light & Power Co.
Cedar Rapids, Iowa.
G. G. Hunt

DATE OF DOCUMENT
4/14/76

DATE RECEIVED
4/27/76

LETTER
 ORIGINAL
 COPY

NOTORIZED
 UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED
one signed

DESCRIPTION

Ltr trans the following:

PLANT NAME:
Duane Arnold

ENCLOSURE

Licensee Event Rpt. (RO 50-331/1976-06) on 11/6/76) concerning error in tech spec limit during surveillance testing on PCIS CV 4300 4303 and 4309.

ACKNOWLEDGED

DO NOT REMOVE

NOTE: IF PERSONNEL EXPOSURE IS INVOLVED SEND DIRECTLY TO KREGER/J. COLLINS

SAFETY

FOR ACTION/INFORMATION

ENVIRO 4/30/76 RJL

<input checked="" type="checkbox"/> BRANCH CHIEF:	<i>LEAR</i>		
W/3 CYS FOR ACTION			
<input checked="" type="checkbox"/> LIC. ASST:	<i>PARASH</i>		
W/1 CYS			
ACRS 16 CYS HOLDING/SENT TO LA			

INTERNAL DISTRIBUTION

<u>REG FILE</u>			
NRC PDR			
I & E (2)			
MIPC (3)			
SCHROEDER/IPPOLITO			
HOUSTON			
NOVAK/CHECK			
GRIMES/SCHWENCER			
CASE			
F. WILLIAMS			
HANAUER			
TEDESCO/MACCARY			
EISENHUT			
BAER			
SHAO			
VOLLMER/BUNCH			
KREGER/J. COLLINS			

EXTERNAL DISTRIBUTION

CONTROL NUMBER

<input checked="" type="checkbox"/> LPDR: <i>CEAR RAPIDS IO</i>			
TIC			
NSIC			

Q


4175

D. Lanham

IOWA ELECTRIC LIGHT AND POWER COMPANY

DUANE ARNOLD ENERGY CENTER
P. O. Box 351
Cedar Rapids, Iowa 52406
April 14, 1976 - 107

Mr. James G. Keppler, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission - Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137



Subject: Licensee Event Report No. 76-06
(30 day) Update Report

File: A-118a


Dear Mr. Keppler:

In accordance with Appendix A to Operating License DPR-49, Technical Specifications and Bases for Duane Arnold Energy Center and Regulatory Guide 10.1, please find attached a copy of the subject Licensee Event Report. (Total of 3 copies transmitted)

Very truly yours,

G. G. Hunt
(G. G. Hunt)

Chief Engineer
Duane Arnold Energy Center



Regulatory Docket File

Docket 50-331
attachment
DLW/GGH/mg

cc: Director, Office of Inspection and Enforcement (30)
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Director, Management Information and Program Control (3)
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

4175

1 6 1976

LICENSEE EVENT REPORT UPDATE REPORT - PREVIOUS REPORT
DATE 021776

CONTROL BLOCK:

--	--	--	--	--	--	--	--	--	--

1 6

(PLEASE PRINT ALL REQUIRED INFORMATION)

01	LICENSEE NAME I A D A C I	LICENSE NUMBER 0 0 - 0 0 0 0 0 0 - 0 0	LICENSE TYPE 4 1 1 1 1	EVENT TYPE 0 3
7 8 9	14	15	25	26 30

01	CATEGORY CONT	REPORT TYPE L	REPORT SOURCE L	DOCKET NUMBER 0 5 0 - 0 3 3 1	EVENT DATE 0 1 1 6 7 6	REPORT DATE 0 4 1 4 7 6
7 8	57 58	59	60	61 68	69 74	75 80

EVENT DESCRIPTION

02	During surveillance testing, PCIS CV 4300, 4303 and 4309 closing	80
7 8 9		
03	times were 2.17, 2.4 and 2.73 seconds respectively. The Tech Spec	80
7 8 9		
04	limit was greater than 3 and less than 5 seconds respectively. Tech	80
7 8 9		
05	Spec has been revised to remove minimum closing time limit. RO-76-06	80
7 8 9		
06		80
7 8 9		

SYSTEM CODE S D	CAUSE CODE E	COMPONENT CODE V A L V O P	PRIME COMPONENT SUPPLIER A	COMPONENT MANUFACTURER F 1 3 0	VIOLATION Y
7 8 9 10	11	12 17	43	44 47	48

CAUSE DESCRIPTION

08	Technical Specification error. A licensee engineering evaluation	80
7 8 9		
09	has confirmed that there is no technical reason why the	80
7 8 9		
10	subject valves should not be allowed to close faster than 3 seconds.	80
7 8 9		

FACILITY STATUS E	% POWER 0 8 3	OTHER STATUS NA	METHOD OF DISCOVERY B	DISCOVERY DESCRIPTION NA
7 8 9	10 12 13	44	45 46	80

FORM OF ACTIVITY RELEASED Z	CONTENT OF RELEASE Z	AMOUNT OF ACTIVITY NA	LOCATION OF RELEASE NA
7 8 9	10 11	44	45 80

PERSONNEL EXPOSURES

NUMBER 0 0 0	TYPE Z	DESCRIPTION NA
7 8 9	11 12 13	80

PERSONNEL INJURIES

NUMBER 0 0 0	DESCRIPTION NA
7 8 9	11 12 80

OFFSITE CONSEQUENCES

DESCRIPTION NA	80
7 8 9	

LOSS OR DAMAGE TO FACILITY

TYPE Z	DESCRIPTION NA
7 8 9	10 80

PUBLICITY

DESCRIPTION NA	80
7 8 9	

ADDITIONAL FACTORS

DESCRIPTION NA	80
7 8 9	

ADDITIONAL FACTORS

DESCRIPTION NA	80
7 8 9	

NAME: D. Wilson PHONE: 319-851-5611