

50-331

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER
INCIDENT REPORT

TO:

NRC

FROM:

IOWA ELECTRIC LIGHT & POWER CO
CEDAR RAPIDS, IOWA
G G HUNT

DATE OF DOCUMENT

2-17-76

DATE RECEIVED

2-23-76

☒ LETTER
☒ ORIGINAL
☐ COPY☐ NOTORIZED
☒ UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

3

DESCRIPTION

LTR TRANS THE FOLLOWING.....

PLANT NAME: DUANE ARNOLD

ENCLOSURE

LICENSE EVENT REPORT 50--331/76-006 ON 1-16-76
RE TECH SPEC ERROR CAUSING VALVES TO PCIS
CV4300, 4303 & 4309 TO CLOSE FASTER THAN 3
SECONDS.....**DO NOT REMOVE
ACKNOWLEDGED**NOTE: IF PERSONNEL EXPOSURE IS INVOLVED
SEND DIRECTLY TO KREGER/J. COLLINS

SAFETY

FOR ACTION/INFORMATION

ENVIRO

2-26-76 RKB

BRANCH CHIEF:

LEAR

W/3 CYS FOR ACTION

LIC. ASST:

PARRISH

W/ CYS

ACRS CYS 16 HOLDING (SENT) TO LA

INTERNAL DISTRIBUTION

~~REG FILE~~

NRC PDR

I & E (2)

MIPC (3)

SCHROEDER/IPPOLITO

HOUSTON

NOVAK/CHECK

GRIMES/SCHWENCER

CASE

F. WILLIAMS

HANAUER

TEDESCO/MACCARY

EISENHUT

BAER

SHAO

VOLLMER/BUNCH

KREGER/J. COLLINS

EXTERNAL DISTRIBUTION

LPDR: CEDAR RAPIDS, IO

TIC

NSIC

CONTROL NUMBER

1624

IOWA ELECTRIC LIGHT AND POWER COMPANY

DUANE ARNOLD ENERGY CENTER

P. O. Box 351

Cedar Rapids, Iowa 52406

February 17, 1976

DAEC - 76 -36



Mr. James G. Keppler, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission - Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Subject: Licensee Event Report No. 76-006
(30 day)

File: A-118a


50-331

Dear Mr. Keppler:

In accordance with Appendix A to Operating License DPR-49, Technical Specifications and Bases for Duane Arnold Energy Center and Regulatory Guide 10.1, please find attached a copy of the subject Licensee Event Report. (Total of 3 copies transmitted)

Very truly yours,

G. G. Hunt
Chief Engineer
Duane Arnold Energy Center



Docket 50-331

attachment

DLW/GGH/mg

cc: Director, Office of Inspection and Enforcement (30)
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Director, Management Information and Program Control (3)
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

1624

FEB 20 1976

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 6

[PLEASE PRINT ALL REQUIRED INFORMATION]

LICENSEE NAME 01 I A D A C 1	LICENSE NUMBER 0 0 - 0 0 0 0 0 - 0 0	LICENSE TYPE 4 1 1 1 1	EVENT TYPE 0 3
CATEGORY 01 CON'T	REPORT TYPE L	REPORT SOURCE L	DOCKET NUMBER 0 5 0 - 0 3 3 1
EVENT DATE 0 1 1 6 7 6	REPORT DATE 0 2 1 7 7 6		

EVENT DESCRIPTION

02	During surveillance testing, PCIS CV4300, 4303 and 4309 closing	80
03	times were 2.17, 2.4 and 2.73 seconds respectively. The Tech Spec	80
04	limit of greater than 3 and less than 5 seconds is in error. Tech Spec	80
05	change will be submitted to remove 3 second limit.	80
06	Supplemental report to be submitted. (RO 76-006)	80

SYSTEM CODE S D	CAUSE CODE E	COMPONENT CODE V A L V O P	PRIME COMPONENT SUPPLIER A	COMPONENT MANUFACTURER F 1 3 0	VIOLATION Y
--	---	---	---	---	--

CAUSE DESCRIPTION

08	Technical Specification error. A licensee engineering evaluation	80
09	has confirmed that there is no technical reason why the	80
10	subject valves should not be allowed to close faster than 3 seconds.	80

FACILITY STATUS E	% POWER 0 8 3	OTHER STATUS NA	METHOD OF DISCOVERY B	DISCOVERY DESCRIPTION NA
--	--	--------------------	--	-----------------------------

FORM OF ACTIVITY RELEASED Z	CONTENT OF RELEASE Z	AMOUNT OF ACTIVITY NA	LOCATION OF RELEASE NA
--	---	--------------------------	---------------------------

PERSONNEL EXPOSURES

NUMBER 0 0 0	TYPE Z	DESCRIPTION NA
---	---	-------------------

PERSONNEL INJURIES

NUMBER 0 0 0	DESCRIPTION NA
---	-------------------

OFFSITE CONSEQUENCES

NA	80
----	----

LOSS OR DAMAGE TO FACILITY

TYPE Z	DESCRIPTION NA
---	-------------------

PUBLICITY

NA	80
----	----

ADDITIONAL FACTORS

NA	80
----	----

NA	80
----	----

NAME: D. Doyel/D. Wilson

PHONE: 319-851-5611