

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 7911010472 DOC. DATE: 79/10/26 NOTARIZED: NO DOCKET #
 FACIL: 50-331 Duane Arnold Energy Center, Iowa Electric Light & Pow 05000331
 AUTH. NAME AUTHOR AFFILIATION
 VANSICKEL, J. Iowa Electric Light & Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Region 3, Chicago, Office of the Director

SUBJECT: LER 79-026-0: on 790926, radiation monitor RM-4101B found to be indicating outside acceptance tolerance of surveillance test procedure. Caused by defective monitor power supply preregulator. Component replaced.

DISTRIBUTION CODE: A002S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+1
 TITLE: Incident Reports

NOTES: -----

ACTION:	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID	CODE/NAME	LTTR	ENCL	ID	CODE/NAME	LTTR	ENCL
	05	BC <i>ORB #3</i>	4	4				
INTERNAL:	01	REG FILE	1	1	02	NRC PDR	1	1
	09	I&E	2	2	11	MPA	3	3
	14	TA/EDO	1	1	15	NOVAK/KNIEL	1	1
	16	EEB	1	1	17	AD FOR ENGR	1	1
	18	PLANT SYS BR	1	1	19	I&C SYS BR	1	1
	20	AD PLANT SYS	1	1	22	REAC SAFT BR	1	1
	23	ENGR BR	1	1	24	KREGER	1	1
	25	PWR SYS BR	1	1	26	AD/SITE ANAL	1	1
	27	OPERA LIC BR	1	1	28	ACCIDENT ANALYS	1	1
	29	AUX SYS BR	1	1		E JORDAN/IE	1	1
		HANAUER, S.	1	1		STS GROUP LEADR	1	1
		TMI-H STREET	1	1				
EXTERNAL:	03	LPDR	1	1	04	NSIC	1	1
	29	ACRS	16	16				

NOV 5 1979

A0/I
4

TOTAL NUMBER OF COPIES REQUIRED: LTTR 48 ENCL 48

60