REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:7904230251 DOC.DATE: 79/04/10 NOTARIZED: NO DOCKET # FACIL:50=331 DUANE ARNOLD ENERGY CENTER, IOWA ELECTRIC LIGHT & POW 05000331 AUTH.NAME AUTHOR AFFILIATION WILSON,D. IOWA ELECTRIC LIGHT & POWER CO. RECIP.NAME RECIPIENT AFFILIATION REGION 3, CHICAGO, OFFICE OF THE DIRECTOR

SUBJECT: LER 79-004/03L=0 ON 790311:DRYWELL TO SUPPRESSION CHAMBER DIFFERENTIAL PRESSURE WAS NOT GREATER THAN 1.3PSID WITHIN 24-H.CAUSED BY PUMP BACK COMPRESSORS DRAWING SUCTION THROUGH CLOSED DRYWELL PURGE INLET VALVE.LINKAGE READJUSTED.

DISTRIBUTION CODE: A002S COPIES RECEIVED: LTR / ENCL / SIZE: / +/

NOTES:						
ACTION:	RECIPIENT ID CODE/NAME 05 BC CRR #3	COPIES LITE	NCL 4	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	
INTERNAL:	01 REG FILE 09 18E 14 TA/EDO 16 EEB 18 PLANT SYS BR 20 AD PLANT SYS 22 REAC SAFT BR 24 KREGER 26 AD/SITE ANAL 28 ACDENT ANLYS E JORDAN/IE	121111111111111111111111111111111111111		02 NRC PDR 11 MPA 15 NOVAK/KNIEL 17 AD FOR ENGR 19 IBC SYS/PROJ 21 AD SYS/PROJ 23 ENGR BR 25 PWR SYS BR 27 OPERA LIC BR 29 AUX SYS BR		
EXTERNAL:	03 LPDR	16	1 6	04 NSIC	1 1	

APR 24 1979

TOTAL NUMBER OF COPIES REQUIRED: LTTR 46 ENCL 46"

Au y

يعني الأوراع في الأراد ال

LICENSEE EVENT REPORT

1	LICENSEE EVENT REPORT
*	CONTROL BLOCK:
0 1	1 A D A C 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5 57 CAT 58
ON'T 0 1 7 8	SOURCE
0 2	During normal operation subsequent to reactor startup, drywell to suppre
03	ssion chamber differential pressure was not greater than 1.3psid within
0 4	24 hours as required by TS 3.7.A.7.a(1) even though pump back system ope
0 5	rable. Per TS, shutdown initiated when DP not established within 6 hours.
0 6	Shutdown terminated when required DP established approx 1 hour later.
0 7	
0878	980
0 9	SYSTEM CAUSE CAUSE COMPONENT CODE SUBCODE SUBC
	LER/RO EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE REPORT TYPE NO. NO. 17 NUMBER 21 22 23 24 26 27 28 29 30 31 31 32
	ACTION FUTURE ON PLANT SHUTDOWN HOURS 22 ATTACHMENT NPRD-4 PRIME COMP. COMPONENT MANUFACTURER SUBMITTED FORM SUB. SUPPLIER MANUFACTURER MANUFACTURER SUBMITTED FORM SUB. SUPPLIER MANUFACTURER MANUFACTURER SUPPLIER SUPPLIER MANUFACTURER MANU
1 0	Pump back compressors drawing suction through closed drywell purge inlet
11	valve caused air loss to seal ring. Seal air valve actuator linkage ou
1 2	t of adjust due to purge valve mod during outage. Maint procedure defici
1 3	ency contributing cause. Linkage readjusted. Other purge valves checked.
1 4	Maint Supervisory personnel to supplement maint proc instruct in future.
1 5	STATUS SPOWER OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32 C 28 0 2 4 29 NA A A STATUS 30 NA A STATUS 30
1 6 A	CTIVITY CONTENT ILEASED OF RELEASE AMOUNT OF ACTIVITY 35 AMOUNT OF ACTIVITY 35 NA PERSONNEL EXPOSURES AMOUNT OF ACTIVITY 35 NA AS AS AS AS AS AS AS AS AS
1 7	PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39 O O O 37 Z 38 NA
1 3	PERSONNEL INJURIES NUMBER DESCRIPTION 41 O O O O AO NA
1 9	LOSS OF OR DAMAGE TO FACILITY 43 TYPE DESCRIPTION Z 42 NA
2 0	PUBLICITY SSUED DESCRIPTION 45 NAC USE ONLY NAC USE ONLY
g	NAME OF PREPARER